

| Classroom ID / Area ID Number | Classroom / Area Type supplied | Actual Outside Air CFM (OA) | Occupancy (OA CFM / 15) |
|-------------------------------|--------------------------------|-----------------------------|-------------------------|
| 1 | CLASSROOM | 93.0 | 6.20 |
| 2 | CLASSROOM | 128.0 | 8.53 |
| 3 | CLASSROOM | 54.0 | 3.60 |
| 4 | CLASSROOM | 0.0 | 0.00 |
| 5 | CLASSROOM | 41.0 | 2.73 |
| 6 | CLASSROOM | 147.0 | 9.80 |
| 7 | CLASSROOM | 312.0 | 20.80 |
| 8 | CLASSROOM | 0.0 | 0.00 |
| 9 | CLASSROOM | 0.0 | 0.00 |
| 10 | CLASSROOM | 0.0 | 0.00 |
| 11 | CLASSROOM | 35.0 | 2.33 |
| 12 | CLASSROOM | 100.0 | 6.67 |
| 13 | CLASSROOM | 195.0 | 13.00 |
| 14 | CLASSROOM | 185.0 | 12.33 |
| 15 | CLASSROOM | 219.0 | 14.60 |
| 16 | CLASSROOM | 96.0 | 6.40 |
| 17 | CLASSROOM | 79.0 | 5.27 |
| 18 | CLASSROOM | 133.0 | 8.87 |
| 19 | CLASSROOM | 89.0 | 5.93 |
| 20 | CLASSROOM | 0.0 | 0.00 |
| 21 | CLASSROOM | 44.0 | 2.93 |
| 22 | CLASSROOM | 70.0 | 4.67 |
| 23 | CLASSROOM | 125.0 | 8.33 |
| 24 | CLASSROOM | 74.0 | 4.93 |
| 25 | CLASSROOM | 126.0 | 8.40 |
| 26 | CLASSROOM | 16.0 | 1.07 |
| 27 | CLASSROOM | 23.0 | 1.53 |
| Cafeteria | CAFE | 0.0 | 0.00 |
| Cafeteria | CAFE | 0.0 | 0.00 |
| Cafeteria | CAFE | 0.0 | 0.00 |

| | Martin | | |
|------------|---------------|-------|------|
| 101 | CLASSROOM | 0.0 | 0.00 |
| Auditorium | AUDITORIUM | 109.0 | 7.27 |
| 102 | CLASSROOM | 0.0 | 0.00 |
| 103 | CLASSROOM | 0.0 | 0.00 |
| 104 | CLASSROOM | 0.0 | 0.00 |
| Cafeteria | CAFE | 0.0 | 0.00 |
| Cafeteria | CAFE | 0.0 | 0.00 |
| Cafeteria | CAFE | 0.0 | 0.00 |
| Hallway | HALLWAY | 0.0 | 0.00 |
| 105 | CLASSROOM | 136.0 | 9.07 |
| 106 | CLASSROOM | 0.0 | 0.00 |
| 106 | CLASSROOM | 0.0 | 0.00 |
| 107A | CLASSROOM | 0.0 | 0.00 |
| 107A | CLASSROOM | 0.0 | 0.00 |
| Gymnasium | GYM | 0.0 | 0.00 |
| Gymnasium | GYM | 0.0 | 0.00 |
| Gymnasium | GYM | 0.0 | 0.00 |
| 110 | CLASSROOM | 0.0 | 0.00 |
| 110 | CLASSROOM | 0.0 | 0.00 |
| 111 | CLASSROOM | 0.0 | 0.00 |
| 112 | CLASSROOM | 0.0 | 0.00 |
| 113 | CLASSROOM | 0.0 | 0.00 |
| 114 | CLASSROOM | 0.0 | 0.00 |
| 114 | CLASSROOM | 0.0 | 0.00 |
| 115 | CLASSROOM | 0.0 | 0.00 |
| 115 | CLASSROOM | 0.0 | 0.00 |
| 117 | CLASSROOM | 0.0 | 0.00 |
| 117 | CLASSROOM | 0.0 | 0.00 |
| 118 | CLASSROOM | 0.0 | 0.00 |
| 119 | CLASSROOM | 0.0 | 0.00 |
| 120 | CLASSROOM | 0.0 | 0.00 |

| | | | |
|-------------|-----------|-------|-------|
| Hallway | HALLWAY | 0.0 | 0.00 |
| 121 | CLASSROOM | 0.0 | 0.00 |
| 122 | CLASSROOM | 0.0 | 0.00 |
| 124 | CLASSROOM | 0.0 | 0.00 |
| 124 | CLASSROOM | 32.0 | 2.13 |
| HOME MAKING | N/A | 0.0 | 0.00 |
| HOME MAKING | NA | 0.0 | 0.00 |
| 129 | CLASSROOM | 0.0 | 0.00 |
| Hallway | HALLWAY | 0.0 | 0.00 |
| 130 | CLASSROOM | 0.0 | 0.00 |
| 131 | CLASSROOM | 0.0 | 0.00 |
| 133 | CLASSROOM | 130.0 | 8.67 |
| 135 | CLASSROOM | 0.0 | 0.00 |
| 136 | CLASSROOM | 156.0 | 10.40 |