

SCHOOL DISTRICT OF PHILADELPHIA



Asbestos Hazard Emergency Response Act “AHERA”

THREE-YEAR RE-INSPECTION 2015-2016 and ASBESTOS MANAGEMENT PLAN for the

Frankford High School

ULCS# 7010

Building # B701001-1

5000 Oxford Avenue

**Philadelphia, Pennsylvania
19124**

Year Built: 1914

March 2016

Conducted by:

Accredited Environmental Technologies, Incorporated
Batta Environmental Associates, Incorporated
Criterion Laboratories, Incorporated
Environmental Testing Consultants, LLC
G & C Environmental Services, Incorporated
KEM Partners, Incorporated
Synertech, Inc.
TTI Environmental, Inc.
USA Environmental Management, Inc.
The Vertex Companies, Inc.

Management Plan Prepared by:

Criterion Labs, Inc and Synertech Inc.

This report must remain in the Main Office as mandated by the US EPA AHERA Regulations.

AHERA THREE-YEAR REINSPECTION VOLUME IX

Table of Contents

Transmittal Letter

Executive Summary

- I. Summary list of Confirmed Asbestos Containing Building Materials
- II. Summary list of Assumed Asbestos Contain Building Materials
- III. Summary list of Non-Asbestos Containing Building Materials
- IV. Summary list of Non Suspect Asbestos Containing Building Materials
- V. Summary List of Auditorium DATA for this location
- VI. Summary list of Attic and/or Crawlspace DATA for this location
- VII. Summary list of Pipe Chase/Pipe Shaft DATA for this location

Section I Report of Re-Inspection

- A. Introduction
- B. Three-Year Re-inspection IX Overview
- C. Post- Management Plan Activities and Changes
 - C.1 - Sampling and Analysis
 - C.2 - New Floor Tile Sampling
 - C.3 - Abatement Activity
 - C.4 - Periodic (Six-Month) Surveillance (Damaged Materials)

Section II Re-Inspection Data

- A. Introduction
- B. Re-Inspection Key Definitions
- C. Room by Room Location Log Report

Section III Certificates

- A. Management Planner/Building Inspector Certificates

Section IV	Cross Reference Table	Page 1-8
	Asbestos Management Program	Page 9-19

SCHOOL DISTRICT OF PHILADELPHIA
EDUCATIONAL CENTER
440 NORTH BROAD STREET
PHILADELPHIA, PENNSYLVANIA 19130

OFFICE OF ENVIRONMENTAL MANAGEMENT AND SERVICES

PHONE (215)-400-4750

January 2016

TO: All Principals
All Building Administrators

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: AHERA Three (3) Year Re-inspection IX report

In order to comply with the provisions of the Asbestos Hazard Emergency Response Act (AHERA) the attached report is submitted to you. The law requires that this report be kept in the Main/Principal's office. It cannot be removed from these locations. *If the school (program) is relocated to a different building, these environmental documents are to be safely retained for the next school/building occupants.* All asbestos reports must be available to the public and Federal EPA upon request.



Fran Burns
Chief Operation Officer

Francine Locke, M.S., Director
Office of Environmental Management
and Services

Executive Summary

This Asbestos Hazard Emergency Response Act (AHERA) Three-Year Re-inspection “Volume # IX” Management Plan at this location, has been completed and the report of re-inspection submitted to the School District of Philadelphia. The re-inspections in all School District of Philadelphia buildings of 2015-2016 were conducted and completed between October 5th, 2015 through March 30th, 2016 as a joint project by Accredited Environmental Technologies, Inc., Batta Environmental Associates, Inc., Criterion Laboratories, Inc., Environmental Testing Consultants, LLC, G & C Environmental Services, Inc., KEM Partners, Inc., Synertech, Inc., TTI Environmental, Inc., USA Environmental Management, Inc. and The Vertex Companies, Inc.

In general, the School District of Philadelphia Office of Environmental Management and Services conducts Environmental Impact Evaluations and provides Asbestos Inspection Reports prior to any renovation, demolition and/or maintenance activities. The AHERA report must be reviewed prior to any renovation, demolition and/or maintenance activities in order to avoid the unknowing disturbance to Asbestos Containing Building Materials identified within this location. In addition, prior to work activities above all drop ceilings this report should be reviewed to avoid potential disturbances to Asbestos Containing Materials. Refer to Section IV of the Cross Reference Table, for additional Asbestos Management Program information. Contact the Office of Environmental Management and Services to have an Environmental Impact Evaluation conducted prior to any renovation, demolition and/or maintenance activities within this facility.

The information contained in this report was obtained from the original Asbestos Management Plan for the school, from update reports on changes and activities since the completion of the 1st Management Plan for each location and from all prior inspections performed and documented in Volume # I through Volume VIII (dated respectively 1992, 1995, 1998, 2001, 2004, 2007, 2010 or 2013) (if applicable) - and by this Three-Year Re-inspection of this school. The re-inspection report/Management Plan of 2015-2016 were reviewed and prepared collectively by Management Planner Megan Vala, Mary Anne Lerro of Criterion Laboratories, Inc. and/or Monique Causley, of Synertech Inc.

The 2015-2016 inspection process included the addition of a comprehensive Room by Room Inventory of all Thermal (T), Surfacing (S) and Miscellaneous (M) Materials specific to each room of this facility. Inspections of each room's thermal, ceilings, walls, floors and miscellaneous items regardless of Asbestos Content are categorized on the Room by Room Location Log Report for this location. Rooms or areas of the facility that were not accessible at the time of the inspection are marked with an "X". The Room by Room Location Log Report is found in Section II C of this Management Plan.

All Presumed or Suspect Asbestos Containing Building Materials (ACBMs), listed in the following summary charts are categorized as Confirmed, Assumed, Non-Asbestos, and/or Non-Suspect (ACBMs) were identified in the original Management Plan, or in the Volume I through Volume VIII AHERA Three-Year Re-inspection reports, and were re-inspected as part of this project.

As mandated by the U S EPA AHERA regulations, periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Please feel free to contact the School District of Philadelphia's Office of Environmental Management and Services (OEMS) regarding any comments, questions, or concerns regarding this report or any Environmental related topic. OEMS staff can be reached at (215) 400 4750, via fax at (215) 400 4751 or via e-mail at flocke@philasd.org and/or gfunod@philasd.org.

Additional information can be found on our website. Here is the link to the OEMS website.
<http://webgui.phila.k12.pa.us/offices/e/environmental>

I. Summary list of Confirmed Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. *These materials have been sampled and Laboratory Analysis has CONFIRMED the presence of Asbestos. Contact OEMS prior to the disturbance of any of the following materials.*

Confirmed Asbestos Containing Building Materials for this location

Floor Tile VAT 9" x 9"	Pipe Fitting Insulation	Pipe Insulation > 6 inch
Pipe Insulation 2-6 inch	Tank Insulation	Transite
Transite Electrical Panel	Transite Stalls	Transite Wall

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

II. Summary list of Assumed Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. These materials have not been sampled and should not be disturbed until verification of Asbestos Content. Contact OEMS for assessment and sampling prior to the disturbance of these materials.

Assumed Asbestos Containing Building Materials for this location

Acoustical Plaster Walls	Blackboard Glue Dots	Brick Boiler
Fire Doors	Floor Tile VAT 12" x 12"	Linoleum
Pipe Insulation > 6 inch	Radiator Insulation	Sectional Boiler
Sink Undercoat Mastic	Transite	Transite Cove Base
Transite Electrical Panel	Transite Fume Hood	Transite Sills
Transite Stalls	Transite Table Top	Transite Wall
Vibration Damper Cloth	Vinyl Stair Treads	

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

III. Summary list of Non-Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. *These materials have been sampled and Laboratory Analysis has indicated NO Asbestos present or NO ASBESTOS DETECTED (NAD).*

Non- Asbestos Containing Building Materials for this location

Ceiling Tile 1' x 1'	Ceiling Tile 2' x 2'	Ceiling Tile 2' x 4'
Plaster Ceiling	Plaster Floor	Plaster Walls
Sheetrock Wall		

* *Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

** *Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

IV. Summary list of Non-Suspect Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. These materials are not typically known to contain Asbestos.

Non-Suspect Asbestos Containing Building Materials for this location

Brick Floor	Brick Wall	Carpet
Ceiling Tile 1' x 1'	Cement Board Walls	Ceramic Tile Floors
Compacted Gravel Floor	Concrete Block Wall	Concrete Ceiling
Concrete Floor	Fiberglass Duct Insulation	Fiberglass Pipe Fitting Insulation
Fiberglass Pipe Insulation	Fiberglass Tank Insulation	Fire Doors
Folding Partition Wall	Horse Hair Pipe Insulation	Marble Floor
Metal Ceiling	Metal Floor	Metal Walls
Plywood Panels	Plywood Walls	Sheetrock Wall
Terra Cotta Walls	Terrazzo Floor	Vinyl Vibration Damper Cloth
Wood Catwalks	Wood Floor	Wood Panel Walls

* *Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

** *Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

V. Summary list of Auditorium DATA for this location

These charts are to be used for a quick reference of the Auditorium DATA within this facility. Sampling of the Auditorium Ceilings throughout the District is more difficult because of the various ceiling heights. As sampling occurs this information is updated on a case by case basis for each specific location and facility.

This is a list of known materials for this location's Auditorium

Auditorium		
Auditorium	Wood Floor	Non Suspect ACM
Auditorium	Plaster Walls	NAD
Auditorium	Plaster Ceiling	NAD
Auditorium	Pipe Insulation 2-6 inch	Confirmed
Auditorium	Pipe Fitting Insulation	Confirmed
Auditorium	Radiator Insulation	Assumed
Auditorium Stage	Wood Floor	Non Suspect ACM
Auditorium Stage	Plaster Walls	NAD
Auditorium Stage	Plaster Ceiling	NAD
Auditorium Balcony	Floor Tile VAT 9" x 9"	Confirmed
Auditorium Balcony	Concrete Floor	Non Suspect ACM
Auditorium Balcony	Plaster Walls	NAD
Auditorium Balcony	Plaster Ceiling	NAD
Auditorium Balcony	Pipe Insulation 2-6 inch	Confirmed
Auditorium Balcony	Pipe Fitting Insulation	Confirmed
Auditorium Balcony	Radiator Insulation	Assumed

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

VI. Summary list of Attic and/or Crawlspace DATA for this location

These charts are to be used for a quick reference regarding the Attics and/or Crawlspaces inspection DATA within this facility. Contact OEMS prior to entering any attic or crawlspace within this facility and refer to the below chart and legend for Category Rank determination. The Data relative to these spaces is updated as conditions change regarding Abatement or Renovation activity on a case by case basis for each specific location and facility. In general, Crawlspaces are below the basement or 1st floor and Attics are above the floor space.

Category Rank Legend

"A" - No Asbestos Containing Materials - Sample Results indicate NO ACM on pipes, fittings, elbows, or equipment located within this functional space, and NO VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"B" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space, HOWEVER, NO VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"C" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space, and LOCALIZED VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"D" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space and DISTRIBUTED VISIBLE DEBRIS or SIGNIFICANT DAMAGE observed at time of this inspection.
"E" - No Bulk Sample Results Available SUSPECT ACM OBSERVED. Contact OEMS immediately for additional instructions.

Attic/Crawlspace	Access Area	Floor Surface	Category Rank	Comments
Oakland Street Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
Wakeling Street Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
North Oxford Street Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
South Oxford Street Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
Harrison Street Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
3 rd Floor Gymnasium Attic	Unknown	Plaster Floor/ Wood Catwalks	"B"	ACPI and ACPFI
Crawl Space behind Auditorium	Unknown	Unknown	"A"	

VII. Summary list of Pipe Chase/Pipe Shaft DATA for this location

These charts are to be used for a quick reference regarding the information known about the Pipe Chases and/or Pipe Shafts inspection DATA within this facility. Contact OEMS prior to performing renovation activities any Pipe Chase and/or Pipe Shaft within this facility and refer to the below chart and legend for Asbestos Content of various materials identified within each space. The Data relative to these spaces is updated as conditions change regarding Inspection, Abatement and/or Renovation activity on a case by case basis for each specific location and facility. In general, Pipe Chases are horizontal spaces and Pipe Shafts are vertical spaces.

Pipe Chases and Pipe Shafts need to be assessed.

Section I

Report of Re-Inspection

A. Introduction

B. Three-Year Re-Inspection IX Overview

C. Post-Management Plan Activities and Changes

C.1 Sampling and Analysis

C.2 New Floor Tile Sampling

C.3 Abatement Activity

C.4 Periodic Six-Month Surveillance (Damaged Materials)

Section I - A

Report of Re-inspection

Introduction

The Three-Year Re-inspection IX was performed to fulfill the requirements of 40 CFR Part 763 - the Asbestos Hazard Emergency Response Act (AHERA). As required by AHERA, each Local Education Agency (LEA) must re-inspect all known confirmed or assumed Asbestos Containing Building Material (ACBM) located in the LEA's facilities. This re-inspection is intended to update the original Asbestos Management Plan for the LEA's facilities.

Multiple Building Inspectors of several firms performed the 2015/2016 re-inspection. The re-inspection report/Management Plan of 2015-2016 were reviewed and prepared collectively by Management Planner Megan Vala, Mary Anne Lerro of Criterion Laboratories, Inc. and Monique Causley, of Synertech Inc.

All of the certificates can be found in Section III.

During the re-inspection of each School District of Philadelphia facility, all of the Management Plans for that facility were reviewed. Information from the conclusions section of that report is included in this report. Additionally, information on activities such as abatements, cleanings, sampling and inspections, which have taken place since the completion of the original Management Plan, were reviewed during the re-inspection. Information on those activities is included in this report.

As mandated by the U S EPA AHERA regulations, all future periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Section I - B

Three-Year Re-inspection IX Overview

Each homogeneous area of Asbestos Containing Building Material (ACBM) listed in the original Management Plan or in the 1992, 1995, 1998, 2001, etc., Three-Year Re-inspection reports were inspected for the AHERA Three-Year Re-inspection Volume IX, and the information for that material verified. Any changes to a homogeneous area listed in the updates to the Management Plans were verified. Any area of suspected ACBM found in the course of the re-inspection, and not listed in the Management Plan or updates, were either assumed to contain asbestos or sampled and analyzed to determine their asbestos content. Any such new areas either assumed to contain asbestos or determined through analysis to contain asbestos were included in the report of the Three-Year Re-inspection. The results of the AHERA Three-Year Re-inspection IX are tabulated in the Room by Room log reports located in *Section II-C* of this report.

As previously noted, all future periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Section I – C.1

Post Management Plan Activities/Changes

Information on activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following: *Sampling and Analysis, New Tile Installation, Abatement Activity and Periodic Six-Month Surveillance Data.*

Sampling and Analysis

In the event Sampling occurs, data will be listed here.

Section I – C.2

Information on the installation of new floor tiles/renovation activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following:

New Floor Tile Sampling

In the event that new tile is installed, the material must be tested prior to installation.

Section I – C.3

Information on the Asbestos Abatement and renovation activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following:

Abatement Activity

Floor	Room Type	Location	Material	Color	Removed or Encapsulated	Quantity
1 st	Cafeteria	Cafeteria C	Floor Tile 9" x 9"	Brown	Removed	6 SF
Basement	Mechanical Room	Electrical Room next to Boiler Room	Pipe Insulation 2-6 inch		Removed	6 LF
Basement	Mechanical Room	Auditorium Fan Room – Between Electrical Room and Cafeteria B	Pipe Insulation 2-6 inch		Removed	30 LF
4 th	Hallway	North Hallway from Classroom 400 to Stairwell 4	Pipe Insulation > 6 inch		Encapsulated	4 LF
4 th	Hallway	Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Fitting Insulation		Encapsulated	3 EA
4 th	Hallway	South Hallway from Classroom 400 to Stairwell 1	Pipe Insulation > 6 inch		Encapsulated	8 LF
4 th	Stairs	Stairwell in South Hallway to Weight Rm. and Rooftop	Pipe Insulation > 6 inch		Encapsulated	<1 LF
4 th	Hallway	South Hallway from Classroom 400 to Stairwell 1	Pipe Insulation 2-6 inch		Encapsulated	<1 LF
4 th	Mechanical Room	Tank Rm. in Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Fitting Insulation		Encapsulated	<1 EA
4 th	Mechanical Room	Tank Rm. in Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Insulation > 6 inch		Encapsulated	6 LF
4 th	Hallway	Fan Rm. in SW Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation > 6 inch		Removed	3 LF
4 th	Administrative Office	Office next to Stairwell 1	Pipe Insulation > 6 inch		Encapsulated	4 LF
4 th	Hallway	Foyer to West Hallway next to Stairwell 3	Pipe Insulation > 6 inch		Encapsulated	1 LF
4 th	Classroom	Spiral Staircase inside of Classroom 400	Pipe Insulation > 6 inch		Encapsulated	2 LF
4 th	Classroom	Spiral Staircase inside of Classroom 400	Pipe Fitting Insulation		Encapsulated	<1 EA
4 th	Hallway	West Hallway from Stairwell 2 to Stairwell 3	Pipe Insulation > 6 inch		Encapsulated	<1 LF
4 th	Hallway	SW Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation > 6 inch		Encapsulated	3 LF

Abatement Activity (continued)

Floor	Room Type	Location	Material	Color	Removed or Encapsulated	Quantity
4 th	Mechanical Room	Tank Rm. in SW Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation > 6 inch		Encapsulated	2 LF
4 th	Mechanical Room	Tank Rm. in SW Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation > 6 inch		Encapsulated	2 LF
4 th	Administrative Office	North End Office by Stairwell 4	Pipe Insulation > 6 inch		Encapsulated	1 LF
4 th	Administrative Office	Office in SW Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation > 6 inch		Encapsulated	<1 LF
3 rd	Classroom	Classroom 319	Pipe Insulation > 6 inch		Encapsulated	1 LF
3 rd	Classroom	Classroom 320	Pipe Insulation > 6 inch		Encapsulated	2 LF
3 rd	Classroom	Classroom 316	Pipe Insulation > 6 inch		Encapsulated	2 LF
3 rd	Hallway	Hallway outside of Classrooms 302-307	Pipe Insulation > 6 inch		Encapsulated	1 LF
3 rd	Restrooms, Staff - Female	Women's Staff Restroom across from Classroom 303	Pipe Insulation > 6 inch		Encapsulated	12 LF
3 rd	Restrooms, Staff - Female	Women's Staff Restroom across from Classroom 303	Pipe Fitting Insulation		Encapsulated	1 EA
3 rd	Teacher Lounge/Dining	Teacher's Lounge beside Classroom 311	Pipe Fitting Insulation		Encapsulated	2 EA
3 rd	Classroom	Music Classroom across from Gymnasium	Pipe Insulation > 6 inch		Encapsulated	2 LF
3 rd	Gymnasium	3rd Floor Gymnasium	Pipe Insulation > 6 inch		Encapsulated	1 LF
3 rd	Student Restrooms - Male/Female (Classroom)	Women's Student Restroom behind Gymnasium	Pipe Insulation > 6 inch		Encapsulated	6 LF
3 rd	Administrative Office	Office next to Stairwell 3	Pipe Insulation > 6 inch		Encapsulated	10 LF
3 rd	Weight Room	Large Weight Rm. above 3rd Floor Gymnasium	Pipe Insulation > 6 inch		Encapsulated	3 LF
2 nd	Classroom	Classroom 202	Pipe Insulation > 6 inch		Encapsulated	2 LF
2 nd	Classroom	Classroom 203	Pipe Insulation > 6 inch		Encapsulated	1 LF
2 nd	Student Restrooms - Male/Female (Classroom)	Women's Student Restroom across from classroom 204	Pipe Insulation > 6 inch		Encapsulated	<1 LF
2 nd	Student Restrooms - Male/Female (Classroom)	Women's Student Restroom across from classroom 204	Pipe Fitting Insulation		Encapsulated	2 EA

Abatement Activity (continued)

Floor	Room Type	Location	Material	Color	Removed or Encapsulated	Quantity
2 nd	Restrooms, Staff - Female	Women's Staff Restroom across from Classroom 203	Pipe Insulation > 6 inch		Encapsulated	4 LF
2 nd	Restrooms, Staff - Female	Women's Staff Restroom across from Classroom 203	Pipe Fitting Insulation		Encapsulated	1 EA
2 nd	Classroom	Classroom 206	Pipe Insulation > 6 inch		Encapsulated	1 LF
2 nd	Classroom	Teen Courtroom next to Classroom 206	Pipe Insulation > 6 inch		Encapsulated	2 LF
2 nd	Administrative Office	Office next to Teen Courtroom	Pipe Insulation > 6 inch		Encapsulated	1 LF
1 st	Building Engineer's Office	Building Engineers Office	Pipe Insulation > 6 inch		Encapsulated	2 LF
1 st	Auditorium	Auditorium	Pipe Insulation > 6 inch		Encapsulated	2 LF
2 nd	Classroom	Classroom 211	Pipe Insulation > 6 inch		Encapsulated	4 LF
2 nd	Classroom	Classroom 216	Pipe Insulation > 6 inch		Encapsulated	2 LF
2 nd	Classroom	Classroom 217	Pipe Insulation > 6 inch		Encapsulated	3 LF
2 nd	Classroom	Classroom 220	Pipe Insulation > 6 inch		Encapsulated	4 LF
2 nd	Hallway	Hallway outside Classroom 219-220	Pipe Insulation > 6 inch		Encapsulated	2 LF
2 nd	Hallway	Hallway outside Classroom 219-220	Pipe Insulation > 6 inch		Encapsulated	3 LF
Basement	Restrooms, Staff - Female	Women's Staff Restroom inside Gallery Kitchen beside Cafeteria B Serving Line	Pipe Insulation > 6 inch		Encapsulated	2 LF
Basement	Restrooms, Staff - Male	Men's Staff Restroom inside Gallery Kitchen beside Cafeteria B Serving Line	Pipe Insulation > 6 inch		Removed	150 LF
Basement	Restrooms, Staff - Male	Men's Staff Restroom inside Gallery Kitchen beside Cafeteria B Serving Line	Pipe Insulation > 6 inch		Removed	15 LF
Basement	Hallway	Narrow Hallway behind Auditorium Stage	Pipe Insulation > 6 inch		Encapsulated	2 LF
Basement	Storage	West End Storage Rm. behind Auditorium behind Restricted Area	Pipe Insulation > 6 inch		Encapsulated	10 LF
2 nd	Hallway	Hallway outside of Classroom 210-214	Pipe Insulation > 6 inch		Encapsulated	3 LF
2 nd	Classroom	Classroom 210	Pipe Insulation > 6 inch		Removed	5 LF
2 nd	Classroom	Classroom 210	Pipe Insulation > 6 inch		Removed	1 LF
2 nd	Classroom	Classroom 210	Pipe Insulation > 6 inch		Removed	20 LF

Section I – C.4

Information on the AHERA inspection that noted damage to various Building Materials at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Work orders are created for Corrective Action responses and tracked for completion. Updates to the Management Plan include the following:

Periodic (Six-Month) Surveillance (Damaged Materials)

<i>Date</i>	<i>Element</i>	<i>Floor</i>	<i>On Site Room Name</i>	<i>Material</i>	<i>Amount of Material</i>	<i>Amount of Damage</i>
7/11/2016	A	BS	North Fan Room across from Stairwell 4	Pipe Insulation 2-6 inch	220 LF	15 LF
7/11/2016	A	BS	Long Hallway to Gymnasium	Pipe Insulation 2-6 inch	250 LF	1 LF
7/11/2016	A	BS	Women's Staff Restroom next to Cafeteria C	Pipe Fitting Insulation	10 EA	1 EA
7/11/2016	A	BS	Women's Student Restroom next to Cafeteria C	Pipe Insulation 2-6 inch	65 LF	2 LF
7/11/2016	A	BS	North Hallway outside Rooms 23 -27	Pipe Insulation 2-6 inch	611 LF	5 LF
7/11/2016	A	BS	North Hallway outside Rooms 23 -27	Pipe Fitting Insulation	122 EA	3 EA
7/11/2016	A	BS	North Hallway at Entrance to Cafeteria C	Pipe Insulation 2-6 inch	100 LF	3 LF
7/11/2016	A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	Pipe Insulation 2-6 inch	9 LF	2 LF
7/11/2016	A	BS	Cafeteria A	Pipe Insulation 2-6 inch	44 LF	1 LF
7/11/2016	A	BS	South Hallway outside Stairwell 2 to Classroom 005	Pipe Insulation 2-6 inch	831 LF	9 LF
7/11/2016	A	BS	South Hallway outside Stairwell 2 to Classroom 005	Pipe Fitting Insulation	163 EA	2 EA
7/11/2016	A	BS	South Hallway outside Stairwell 2 to Classroom 005	Pipe Insulation > 6 inch	8 LF	1 LF
7/11/2016	A	BS	Classroom 007 Right Storage Room	Pipe Insulation 2-6 inch	55 LF	2 LF
7/11/2016	A	BS	Water Main/Storage Room	Pipe Insulation 2-6 inch	110 LF	8 LF
7/11/2016	A	BS	Men's Student Restroom across from Classroom 004	Pipe Insulation 2-6 inch	40 LF	3 LF
7/11/2016	A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	Pipe Insulation 2-6 inch	250 LF	6 LF
7/11/2016	A	BS	Building Engineer's Office	Floor Tile VAT 12" x 12"	150 SF	1 SF
7/11/2016	A	BS	Building Engineer's Office	Pipe Insulation 2-6 inch	80 LF	2 LF
7/11/2016	A	1	Classroom 103	Floor Tile VAT 12" x 12"	600 SF	1 SG
7/11/2016	A	1	Classroom 103	Pipe Insulation 2-6 inch	48 LF	4 LF
7/11/2016	A	1	Classroom 104	Floor Tile VAT 12" x 12"	300 SF	1 SF
7/11/2016	A	1	Classroom 104	Floor Tile VAT 12" x 12"	300 SF	1 SF

Periodic (Six-Month) Surveillance (Damaged Materials) continued

<i>Date</i>	<i>Element</i>	<i>Floor</i>	<i>On Site Room Name</i>	<i>Material</i>	<i>Amount of Material</i>	<i>Amount of Damage</i>
7/11/2016	A	1	Classroom 106	Pipe Insulation 2-6 inch	48 LF	1 LF
7/11/2016	A	1	Classroom 107	Floor Tile VAT 12" x 12"	700 SF	1 SF
7/11/2016	A	1	Hallway outside Classrooms 102 - 108	Pipe Insulation 2-6 inch	152 LF	3 LF
7/11/2016	A	1	Hallway outside Classrooms 106 - 107	Pipe Insulation 2-6 inch	30 LF	1 LF
7/11/2016	A	1	Women's Staff Restroom across from Classroom 103	Pipe Fitting Insulation	18 EA	1 EA
7/11/2016	A	1	Hallway outside Classrooms 113 - 115	Pipe Insulation 2-6 inch	105 LF	4 LF
7/11/2016	A	1	Office next to Former Main Entrance Vestibule	Pipe Insulation 2-6 inch	36 LF	1 LF
7/11/2016	A	1	Hallway outside Classrooms 117 - 121	Pipe Fitting Insulation	31 EA	2 EA
7/11/2016	A	1	Art Classroom 118	Floor Tile VAT 9" x 9"	1200 SF	300 SF
7/11/2016	A	1	Art Classroom 118	Pipe Insulation 2-6 inch	96 LF	2 LF
7/11/2016	A	1	Storage Room between Art Classrooms 117 & 118	Floor Tile VAT 9" x 9"	200 SF	300 SF
7/11/2016	A	1	Classroom 119	Pipe Insulation 2-6 inch	24 LF	2 LF
7/11/2016	A	1	Custodial Closet across from Art Classroom 118	Pipe Insulation 2-6 inch	38 LF	3 LF
7/11/2016	A	1	Auditorium	Pipe Insulation 2-6 inch	116 LF	2 LF
7/11/2016	A	1	Narrow Hallway behind Auditorium Stage	Pipe Insulation 2-6 inch	28 LF	2 LF
7/11/2016	A	1	West End Storage Room behind Auditorium - Restricted Area	Pipe Insulation 2-6 inch	38 LF	10 LF
7/11/2016	A	2	Auditorium Balcony	Floor Tile VAT 9" x 9"	480 SF	2 SF
7/11/2016	A	2	Classroom 202	Pipe Insulation 2-6 inch	40 LF	2 LF
7/11/2016	A	2	Classroom 203	Pipe Insulation 2-6 inch	48 LF	1 LF
7/11/2016	A	2	Women's Student Restroom across from Classroom 204	Pipe Insulation 2-6 inch	45 LF	2 LF
7/11/2016	A	2	Women's Student Restroom across from Classroom 204	Pipe Fitting Insulation	10 EA	1 EA
7/11/2016	A	2	Women's Staff Restroom across from Classroom 203	Pipe Insulation 2-6 inch	34 LF	4 LF
7/11/2016	A	2	Women's Staff Restroom across from Classroom 203	Pipe Fitting Insulation	8 EA	2 EA
7/11/2016	A	2	Classroom 206	Pipe Insulation 2-6 inch	48 LF	1 LF
7/11/2016	A	2	Teen Courtroom next to Classroom 206	Pipe Insulation 2-6 inch	48 LF	2 LF
7/11/2016	A	2	Office next to Teen Courtroom	Pipe Insulation 2-6 inch	24 LF	1 LF
7/11/2016	A	2	Office next to Stairwell 4	Pipe Insulation 2-6 inch	12 LF	1 LF
7/11/2016	A	2	Classroom 211	Pipe Insulation 2-6 inch	44 LF	4 LF
7/11/2016	A	2	Hallway outside Classrooms 210 -214	Pipe Insulation 2-6 inch	212 LF	3 LF
7/11/2016	A	2	Hallway outside Classrooms 219 - 220	Pipe Insulation 2-6 inch	37 LF	2 LF
7/11/2016	A	2	Hallway outside Classrooms 216 -220	Pipe Insulation 2-6 inch	165 LF	3 LF
7/11/2016	A	2	Classroom 216	Pipe Insulation 2-6 inch	72 LF	2 LF

Periodic (Six-Month) Surveillance (Damaged Materials) continued

<i>Date</i>	<i>Element</i>	<i>Floor</i>	<i>On Site Room Name</i>	<i>Material</i>	<i>Amount of Material</i>	<i>Amount of Damage</i>
7/11/2016	A	2	Classroom 217	Pipe Insulation 2-6 inch	48 LF	3 LF
7/11/2016	A	2	Classroom 220	Pipe Insulation 2-6 inch	45 LF	4 LF
7/11/2016	A	3	3rd Floor Gymnasium	Pipe Insulation 2-6 inch	84 LF	1 LF
7/11/2016	A	3	Women's Student Restroom behind 3rd Floor Gymnasium	Pipe Insulation 2-6 inch	104 LF	6 LF
7/11/2016	A	3	Narrow Hallway behind 3rd Floor Gymnasium	Floor Tile VAT 9" x 9"	80 SF	3 SF
7/11/2016	A	3	Office next to Stairwell 3	Pipe Insulation 2-6 inch	10 LF	10 LF
7/11/2016	A	3	Hallway outside Classrooms 302 - 307	Pipe Insulation 2-6 inch	23 LF	1 LF
7/11/2016	A	3	Women's Student Restroom across from Classroom 304	Pipe Insulation 2-6 inch	12 LF	12 LF
7/11/2016	A	3	Women's Staff Restroom across from Classroom 303	Pipe Insulation 2-6 inch	40 LF	1 LF
7/11/2016	A	3	Teacher's Lounge next to Classroom 311	Pipe Fitting Insulation	12 EA	3 EA
7/11/2016	A	3	Music Classroom across from Gymnasium	Pipe Insulation 2-6 inch	12 LF	2 LF
7/11/2016	A	3	Classroom 316	Pipe Insulation 2-6 inch	12 LF	2 LF
7/11/2016	A	3	Classroom 320	Pipe Insulation 2-6 inch	12 LF	2 LF
7/11/2016	A	3	Classroom 319	Pipe Insulation 2-6 inch	24 LF	1 LF
7/11/2016	A	4	North Spiral Staircase in Classroom 400	Pipe Insulation 2-6 inch	25 LF	2 LF
7/11/2016	A	4	North Spiral Staircase in Classroom 400	Pipe Fitting Insulation	2 EA	1 EA
7/11/2016	A	4	North Hallway from Classroom 400 to Stairwell 4	Pipe Insulation > 6 inch	100 LF	8 LF
7/11/2016	A	4	North End Office next to Stairwell 4	Pipe Insulation 2-6 inch	25 LF	1 LF
7/11/2016	A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Insulation 2-6 inch	108 LF	5 LF
7/11/2016	A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Insulation 2-6 inch	38 LF	6 LF
7/11/2016	A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	Pipe Fitting Insulation	15 EA	1 EA
7/11/2016	A	4	Foyer to West Hallway next to Stairwell 3	Pipe Fitting Insulation	5 EA	2 EA
7/11/2016	A	4	West Hallway from Stairwell 2 to Stairwell 3	Pipe Fitting Insulation	3 EA	1 EA
7/11/2016	A	4	Former Kitchen between Stairwells 2 and 3	Pipe Insulation 2-6 inch	20 LF	1 LF
7/11/2016	A	4	Southwest Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation 2-6 inch	100 LF	3 LF
7/11/2016	A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation 2-6 inch	33 LF	2 LF
7/11/2016	A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2	Pipe Fitting Insulation	10 EA	4 EA
7/11/2016	A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation 2-6 inch	3 LF	3 LF

Periodic (Six-Month) Surveillance (Damaged Materials) continued

<i>Date</i>	<i>Element</i>	<i>Floor</i>	<i>On Site Room Name</i>	<i>Material</i>	<i>Amount of Material</i>	<i>Amount of Damage</i>
7/11/2016	A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	Pipe Insulation 2-6 inch	14 LF	1 LF
7/11/2016	A	4	Office next to Stairwell 1	Pipe Insulation 2-6 inch	22 LF	4 LF
7/11/2016	A	4	South Hallway from Classroom 400 to Stairwell 1	Pipe Insulation > 6 inch	100 LF	8 LF
7/11/2016	A	4	South Hallway from Classroom 400 to Stairwell 1	Pipe Fitting Insulation	30 EA	1 EA
7/11/2016	A	4	Stairwell in South Hallway to Weight Room and Rooftop	Pipe Insulation 2-6 inch	7 LF	1 LF
7/11/2016	A	4	Larger Weight Room above 3rd Floor Gym	Pipe Insulation 2-6 inch	6 LF	3 LF
7/11/2016	B	BS	Restroom inside 1st Floor Gymnasium	Pipe Insulation 2-6 inch	100 LF	1 LF
7/11/2016	B	BS	Office next to Women's Locker Room	Pipe Insulation 2-6 inch	340 LF	1 LF
7/11/2016	D	GD	Women's Locker Room	Pipe Insulation 2-6 inch	340 LF	1 LF
7/11/2016	D	GD	Main Hallway to Main (A) Building	Floor Tile VAT 12" x 12"	450 SF	6 SF
7/11/2016	D	GD	Main Hallway to Main (A) Building	Floor Tile VAT 9" x 9"	450 SF	6 SF
7/11/2016	D	1	Principal's Office	Floor Tile VAT 9" x 9"	650 SF	3 SF
7/11/2016	D	3	IT MDF/Storage Room	Floor Tile VAT 9" x 9"	50 SF	5 SF

Section II

Re-Inspection Data

A. Introduction

B. Re-Inspection Key Definitions

C. Room by Room Location Log Report

Section II - A

Re-inspection Data

Introduction

The following information documents the Three-Year Re-inspection IX of the subject school/facility. The Homogeneous Area Reports were produced using the building inspector's field data on the facility. The key to the Homogeneous Area Report is outlined in the following pages of this report.

Section II - B
(page 1 of 4)

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE YEAR RE-INSPECTION IX**

ITEM	DEFINITION
ULCS#	Individual identification number assigned to each school within the School District of Philadelphia.
HOMOGENEOUS AREA ID#	Identification number assigned to each homogeneous area in a school/facility. Each section of the homogeneous area ID is significant. 1010/01/01/01 A B C D A. Is the ULCS# for the school. B. Designates the specific building/building area within the school. C. Designates the floor or level within the building/building area. D. Designates the homogeneous material within that floor or level. Note: Item D may be a number or a letter.
SYSTEM AFFECTED	Corresponds to the AHERA system for classifying materials. T : Thermal System S : Surfacing System M : Miscellaneous
ITEM AFFECTED	Is a description of the homogeneous material.
ORIGINAL INSPECTION DATA	This section contains the information found in the original Management Plan (1988-1989).
AMOUNT OF MATERIAL/ UNIT	Quantity of material, and measuring unit. Units include: Square Feet (SF) Each (EA) Linear Feet (LF) Cubic Feet (CF).

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

ITEM	DEFINITION
CND Condition	Corresponds to AHERA condition rating for materials. 0 : No Damage 1 : Damage 2 : Significant Damage
DP Damage Potential	Corresponds to the AHERA material assessment system. 1 : Potential for Damage 2 : Potential for Significant Damage
ASMD Assumed Asbestos	This means that a material was not sampled for asbestos content during the original Management Plan inspection.
RA Response Action	This corresponds to the AHERA system of response action rating for materials. 1 : Establish O&M Program 2 : Repair and Establish O&M Program 3 : Enclose 4 : Encapsulate 5 : Remove 6 : Partial Removal and Establish O&M Program
CHANGES	This section describes changes to the homogeneous material in the twenty-four years since the original AHERA inspection. The abbreviations are defined below. RMVD : Removed ENCL : Enclosed ENCP : Encapsulated DMGD : Damaged SMPLD : Sampled MTRL : Material RPRD : Repaired N/L : None Located RPLCD : Replaced

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE-YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

ITEM	DEFINITION												
THREE YEAR RE-INSPECTION	<p>This section contains the information obtained from the Three-Year Re-inspection IX. With three exceptions, the information categories are identical in format and meaning to those found in the original inspection data section. The three exceptions are defined below.</p>												
DMGD AMT Amount Damaged	<p>This section gives the quantity of damaged material in a homogeneous area. The quantity is shown in the same format as the amount of material/unit section.</p>												
NF Newly Friable	<p>This section identifies materials in the original Management Plan which have since become friable.</p>												
RA Response Action	<p>This rating is based on the AHERA regulations, and is comparable to the RA rating found in the "Original Inspection Data" section. The following table details the response actions.</p> <table><tr><td>1.</td><td>Establish O&M Program</td></tr><tr><td>2.</td><td>Repair and Establish O&M Program</td></tr><tr><td>3.</td><td>Enclose</td></tr><tr><td>4.</td><td>Encapsulate</td></tr><tr><td>5.</td><td>Remove</td></tr><tr><td>6.</td><td>Partial Removal and Establish O&M Program</td></tr></table> <p>a. High Priority Response The homogeneous material has been scheduled for abatement or other response action.</p> <p>b. Medium Priority Response The homogeneous material will be scheduled for abatement or other response action as soon as the high priority responses have been addressed.</p> <p>c. Low Priority Response The homogeneous material will be scheduled for abatement or other response action as soon as the medium priority responses have been addressed.</p> <p>d. On-Going Response/Operations and Maintenance The homogeneous material does not require abatement or other response action at present, and should be included in the facility's on-going operations and maintenance program.</p>	1.	Establish O&M Program	2.	Repair and Establish O&M Program	3.	Enclose	4.	Encapsulate	5.	Remove	6.	Partial Removal and Establish O&M Program
1.	Establish O&M Program												
2.	Repair and Establish O&M Program												
3.	Enclose												
4.	Encapsulate												
5.	Remove												
6.	Partial Removal and Establish O&M Program												

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE-YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

The information presented in the changes section has been compiled from a variety of sources, including the Re-inspection and the following:

- * Quality Control/Quality Assurance Reports of asbestos abatement projects, prepared by consultants to the School District.
- * Permit and Notification Forms for asbestos abatement projects.
- * Periodic Surveillance Forms
- * Operations and Maintenance activities performed by School District personnel.
- * Verbal information from School District personnel.
- * Reports of sampling and analysis of suspected materials by both School District personnel and outside consultants.

**ROOM BY
ROOM
LOCATION LOG
REPORT**

This section gives information, including damage amount and location, for a specific homogeneous material on a room-by-room basis and follows the Re-inspection form.

NOTE: The disparate nature of the above sources of information prohibits the verification of much information within the scope of the AHERA Three-Year Re-inspection. Discrepancies and omissions may exist in this information, and therefore is included on an "as is" basis. The inspectors for the Three-Year Re-inspection IX evaluated homogeneous areas based on the materials current condition and location, as evidenced during the inspector's site visit.

Section II - C

Room by Room Location Log Report

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location.

NOTE:

*Contact OEMS prior to the disturbance of any of the materials that are listed as **Confirmed and/or Assumed**.*

The quantities listed for (NAD) non-asbestos containing materials and/or Non-Suspect Materials are only estimated and were not measured for the purpose of this report. Field verification of quantities for renovation purposes would be necessary.

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	BS	North Fan Room across from Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
A	BS	North Fan Room across from Stairwell 4	N/A	Brick Wall		Non Suspect ACM	2700	SF	0					N/A	N/A	N/A
A	BS	North Fan Room across from Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
A	BS	North Fan Room across from Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	220	LF	15	LF		Open Ends, Open Seams and Damaged Lagging		1	Yes	2/C
A	BS	North Fan Room across from Stairwell 4	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	30	EA	0					1	No	1/D
A	BS	North Fan Room across from Stairwell 4	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	250	LF	0					N/A	N/A	N/A
A	BS	North Fan Room across from Stairwell 4	T	Pipe Insulation > 6 inch	7010/01/08/07	Confirmed	15	LF	0					1	No	1/D
A	BS	North Fan Room across from Stairwell 4	T	Tank Insulation	7010/01/08/25	Confirmed	250	SF	0					1	No	1/D
A	BS	North Fan Room across from Stairwell 4	M	Transite Electrical Panel	7010/01/08/SYN/BB/2350	Confirmed	40	SF	0			2 Panels - 20 SF Each		1	No	1/D
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	M	Transite Cove Base	7010/01/08/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	N/A	Brick Wall		Non Suspect ACM	480	SF	0					N/A	N/A	N/A
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	59	LF	0					1	No	1/D
A	BS	Room 27 - Teacher's Lounge across from Stairwell 4	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	4	EA	0					1	No	1/D
A	BS	Exercise Room next to Hallway Entrances to Gymnasium	N/A	Ceramic Tile Floors		Non Suspect ACM	800	SF	0					N/A	N/A	N/A
A	BS	Exercise Room next to Hallway Entrances to Gymnasium	N/A	Plaster Walls		NAD	2400	SF	0					N/A	N/A	N/A
A	BS	Exercise Room next to Hallway Entrances to Gymnasium	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A
A	BS	Exercise Room next to Hallway Entrances to Gymnasium	M	Blackboard Glue Dots	7010/01/08/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D
A	BS	Exercise Room next to Hallway Entrances to Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0					N/A	N/A	N/A
A	BS	Restroom inside Exercise Room next to Hallway Entrances to Gymnasium	N/A	Ceramic Tile Floors		Non Suspect ACM	112	SF	0					N/A	N/A	N/A
A	BS	Restroom inside Exercise Room next to Hallway Entrances to Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	336	SF	0					N/A	N/A	N/A
A	BS	Restroom inside Exercise Room next to Hallway Entrances to Gymnasium	N/A	Ceiling Tile 1' x 1'		NAD	112	SF	0					N/A	N/A	N/A
A	BS	Long Hallway to Gymnasium	N/A	Concrete Floor		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
A	BS	Long Hallway to Gymnasium	N/A	Plaster Walls		NAD	1200	SF	0					N/A	N/A	N/A
A	BS	Long Hallway to Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
A	BS	Long Hallway to Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	250	LF	1	LF		Damaged Lagging		1	Yes	2/A
A	BS	Long Hallway to Gymnasium	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	25	EA	0					1	No	1/D
A	BS	Long Hallway to Gymnasium	M	Transite Sills	7010/01/08/SYN/BB/2300	Assumed	3	SF	0					1	No	1/D
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Ceramic Tile Floors		Non Suspect ACM	650	SF	0					N/A	N/A	N/A
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Plaster Walls		NAD	1950	SF	0					N/A	N/A	N/A
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Ceiling Tile 2' x 4'		NAD	650	SF	0					N/A	N/A	N/A
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	M	Blackboard Glue Dots	7010/01/08/SYN/BB/2600	Assumed	40	SF	0					1	No	1/D
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	62	LF	0			Additional Quantity above ACT		1	No	1/D
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	10	EA	0			Additional Quantity above ACT		1	No	1/D
A	BS	Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	M	Sink Undercoat Mastic	7010/01/08/SYN/BB/2602	Assumed	12	SF	0			2 Sinks		1	No	1/D
A	BS	Front Storage Closet in Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Ceramic Tile Floors		Non Suspect ACM	36	SF	0					N/A	N/A	N/A
A	BS	Front Storage Closet in Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Plaster Walls		NAD	120	SF	0					N/A	N/A	N/A
A	BS	Front Storage Closet in Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	36	SF	0					N/A	N/A	N/A
A	BS	Rear Storage Closet in Room 25 - Teacher's Lounge next to Long Hallway to Gymnasium	x	x		x	x	x	x	x		No Access		x	x	x
A	BS	Supply Room 24	N/A	Concrete Floor		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Supply Room 24	M	Transite Cove Base	7010/01/08/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	Supply Room 24	N/A	Plaster Walls		NAD	480	SF	0					N/A	N/A	N/A
A	BS	Supply Room 24	N/A	Concrete Ceiling		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Supply Room 24	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	100	LF	0					1	No	1/D
A	BS	Supply Room 24	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	32	EA	0					1	No	1/D
A	BS	Supply Room 24	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
A	BS	Rear Storage Room inside Supply Room 24	N/A	Concrete Floor		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Rear Storage Room inside Supply Room 24	M	Transite Cove Base	7010/01/08/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	Rear Storage Room inside Supply Room 24	N/A	Plaster Walls		NAD	480	SF	0					N/A	N/A	N/A
A	BS	Rear Storage Room inside Supply Room 24	N/A	Concrete Ceiling		Non Suspect ACM	160	SF	0					N/A	N/A	N/A
A	BS	Rear Storage Room inside Supply Room 24	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	50	LF	0					1	No	1/D
A	BS	Rear Storage Room inside Supply Room 24	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	9	EA	0					1	No	1/D
A	BS	Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728				
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	BS	Stairwell 4	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 4	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room 23	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	850	SF	0		Tan			1	No	1/D
A	BS	Kitchen Storage Room 23	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	100	LF	0					1	No	1/D
A	BS	Kitchen Storage Room 23	N/A	Brick Wall		Non Suspect ACM	1275	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room 23	N/A	Plaster Walls		NAD	1275	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room 23	N/A	Ceiling Tile 1' x 1'		NAD	850	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room 23	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	12	LF	0					1	No	1/D
A	BS	Kitchen Storage Room 23	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	1	EA	0					1	No	1/D
A	BS	Women's Staff Restroom next to Cafeteria C	N/A	Ceramic Tile Floors		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom next to Cafeteria C	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	32	LF	0					1	No	1/D
A	BS	Women's Staff Restroom next to Cafeteria C	N/A	Brick Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom next to Cafeteria C	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom next to Cafeteria C	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	36	LF	0					1	No	1/D
A	BS	Women's Staff Restroom next to Cafeteria C	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	10	EA	1	EA		Damaged Fitting		1	Yes	2/A
A	BS	Women's Staff Restroom next to Cafeteria C	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0					N/A	N/A	N/A
A	BS	Women's Student Restroom next to Cafeteria C	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Women's Student Restroom next to Cafeteria C	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	56	LF	0					1	No	1/D
A	BS	Women's Student Restroom next to Cafeteria C	N/A	Brick Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Women's Student Restroom next to Cafeteria C	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Women's Student Restroom next to Cafeteria C	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	65	LF	2	LF		Damaged Lagging in Corner		1	Yes	2/A
A	BS	Women's Student Restroom next to Cafeteria C	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	12	EA	0					1	No	1/D
A	BS	Women's Student Restroom next to Cafeteria C	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	80	LF	0					N/A	N/A	N/A
A	BS	x	x	x		x	x	x	x	x	x	No Access - Need on site room name		x	x	x
A	BS	Storage Room behind Elevator	N/A	Concrete Floor		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
A	BS	Storage Room behind Elevator	N/A	Brick Wall		Non Suspect ACM	180	SF	0					N/A	N/A	N/A
A	BS	Storage Room behind Elevator	N/A	Concrete Ceiling		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
A	BS	North Hallway outside Rooms 23 -27	N/A	Concrete Floor		Non Suspect ACM	800	SF	0					N/A	N/A	N/A
A	BS	North Hallway outside Rooms 23 -27	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	160	LF	0					1	No	1/D
A	BS	North Hallway outside Rooms 23 -27	N/A	Brick Wall		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	North Hallway outside Rooms 23 -27	N/A	Concrete Ceiling		Non Suspect ACM	800	SF	0					N/A	N/A	N/A
A	BS	North Hallway outside Rooms 23 -27	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	611	LF	5	LF		Open Ends		1	Yes	2/A
A	BS	North Hallway outside Rooms 23 -27	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	122	EA	3	EA		Damaged Fittings		1	Yes	2/A
A	BS	North Hallway outside Rooms 23 -27	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0					N/A	N/A	N/A
A	BS	North Hallway outside Rooms 23 -27	M	Transite Electrical Panel	7010/01/0B/SYN/BB/2350	Confirmed	20	SF	0			1 Panel - 20 SF		1	No	1/D
A	BS	North Hallway at Entrance to Cafeteria C	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	North Hallway at Entrance to Cafeteria C	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	North Hallway at Entrance to Cafeteria C	N/A	Brick Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
A	BS	North Hallway at Entrance to Cafeteria C	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	North Hallway at Entrance to Cafeteria C	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	100	LF	3	LF		Open Seams		1	Yes	2/A
A	BS	North Hallway at Entrance to Cafeteria C	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	10	EA	0					1	No	1/D
A	BS	North Hallway at Entrance to Cafeteria C	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	60	LF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room next to Elevator	N/A	Ceramic Tile Floors		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room next to Elevator	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	36	LF	0					1	No	1/D
A	BS	Kitchen Storage Room next to Elevator	N/A	Brick Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room next to Elevator	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Kitchen Storage Room next to Elevator	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	22	EA	0					1	No	1/D
A	BS	Kitchen Storage Room next to Elevator	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	120	LF	0					N/A	N/A	N/A
A	BS	Elevator across from Kitchen	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	40	SF	0		Green			1	No	1/D
A	BS	Elevator across from Kitchen	N/A	Metal Walls		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	BS	Elevator across from Kitchen	N/A	Metal Ceiling		Non Suspect ACM	40	SF	0					N/A	N/A	N/A
A	BS	Main Kitchen	N/A	Ceramic Tile Floors		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
A	BS	Main Kitchen	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	110	LF	0					1	No	1/D
A	BS	Main Kitchen	N/A	Brick Wall		Non Suspect ACM	2700	SF	0					N/A	N/A	N/A
A	BS	Main Kitchen	N/A	Concrete Ceiling		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
A	BS	Main Kitchen	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	20	LF	0					1	No	1/D
A	BS	Main Kitchen	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	12	EA	0					1	No	1/D
A	BS	Main Kitchen	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0					N/A	N/A	N/A
A	BS	Main Kitchen	M	Transite	7010/01/0B/SYN/BB/2305	Confirmed	300	SF	0					1	No	1/D
A	BS	Kitchen Office	N/A	Ceramic Tile Floors		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Kitchen Office	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D
A	BS	Kitchen Office	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Kitchen Office	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Kitchen Office	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	160	LF	0					1	No	1/D
A	BS	Kitchen Office	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	20	EA	0					1	No	1/D
A	BS	Kitchen Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Ceramic Tile Floors		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	120	LF	0					1	No	1/D

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016				
												Building Inspector: Bernard J Bryson				
												Number: ACC-0125-6-031				
												Management Planner: Megan Vala				
												Number: 740728				
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	40	LF	0					1	No	1/D
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	25	EA	0					1	No	1/D
A	BS	Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0					N/A	N/A	N/A
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Ceramic Tile Floors		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	30	LF	0					1	No	1/D
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	180	SF	0					N/A	N/A	N/A
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	3	EA	0					1	No	1/D
A	BS	Domestic Water Heater Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Ceramic Tile Floors		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	46	LF	0					1	No	1/D
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	9	LF	2	LF		Open Ends		1	Yes	2/A
A	BS	Women's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	18	LF	0					N/A	N/A	N/A
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Ceramic Tile Floors		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	36	LF	0					1	No	1/D
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	4	EA	0					1	No	1/D
A	BS	Women's Staff Locker Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
A	BS	Food Storage Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Floor		Non Suspect ACM	625	SF	0					N/A	N/A	N/A
A	BS	Food Storage Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	90	LF	0					1	No	1/D
A	BS	Food Storage Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	1875	SF	0					N/A	N/A	N/A
A	BS	Food Storage Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	625	SF	0					N/A	N/A	N/A
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Floor		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	36	LF	0					1	No	1/D
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	6	EA	0					1	No	1/D
A	BS	Storage Room next to Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	35	LF	0					N/A	N/A	N/A
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report									Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	46	LF	0					1	No	1/D		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	150	LF	0					1	No	1/D		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	30	EA	0					1	No	1/D		
A	BS	Men's Staff Restroom inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Stalls	7010/01/0B/04	Assumed	50	SF	0			Stalls are Painted; May be Granite		1	No	1/D		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Ceramic Tile Floors		Non Suspect ACM	50	SF	0					N/A	N/A	N/A		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	25	LF	0					1	No	1/D		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0					N/A	N/A	N/A		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	2	EA	0					1	No	1/D		
A	BS	Warming Oven Room inside Long Gallery Kitchen next to Cafeteria B Serving Line	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	5	LF	0					N/A	N/A	N/A		
A	BS	Cafeteria A	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	1800	SF	0		Grey			1	No	1/D		
A	BS	Cafeteria A	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	160	LF	0					1	No	1/D		
A	BS	Cafeteria A	N/A	Brick Wall		Non Suspect ACM	5400	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria A	N/A	Ceiling Tile 1' x 1'		NAD	1800	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria A	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	44	LF	1	LF		Open End		1	Yes	2/A		
A	BS	Cafeteria A	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	7	EA	0					1	No	1/D		
A	BS	Cafeteria A	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	50	LF	0					N/A	N/A	N/A		
A	BS	Cafeteria B	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	2400	SF	0		Multi			1	No	1/D		
A	BS	Cafeteria B	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	200	LF	0					1	No	1/D		
A	BS	Cafeteria B	N/A	Brick Wall		Non Suspect ACM	7200	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria B	N/A	Ceiling Tile 1' x 1'		NAD	2400	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria B Serving Line	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	800	SF	0		Tan			1	No	1/D		
A	BS	Cafeteria B Serving Line	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D		
A	BS	Cafeteria B Serving Line	N/A	Brick Wall		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria B Serving Line	N/A	Ceiling Tile 1' x 1'		NAD	800	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria C	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	2600	SF	0		Multi			1	No	1/D		
A	BS	Cafeteria C	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	210	LF	0					1	No	1/D		
A	BS	Cafeteria C	N/A	Brick Wall		Non Suspect ACM	7800	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria C	N/A	Ceiling Tile 1' x 1'		NAD	2600	SF	0					N/A	N/A	N/A		
A	BS	Cafeteria C	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	1	EA	0					1	No	1/D		
A	BS	Cafeteria C	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	4	LF	0					N/A	N/A	N/A		
A	BS	Former School Store	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	900	SF	0		Multi			1	No	1/D		
A	BS	Former School Store	N/A	Plaster Walls		NAD	2700	SF	0					N/A	N/A	N/A		
A	BS	Former School Store	N/A	Sheetrock Wall		Non Suspect ACM	200	SF	0					N/A	N/A	N/A		
A	BS	Former School Store	N/A	Ceiling Tile 2' x 4'		NAD	900	SF	0					N/A	N/A	N/A		
A	BS	Former School Store	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	120	LF	0					1	No	1/D		
A	BS	Former School Store	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	18	EA	0					1	No	1/D		
A	BS	Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	BS	Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	BS	Stairwell 1	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A		
A	BS	Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	BS	South Hallway at Entrance to Cafeteria A	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A		
A	BS	South Hallway at Entrance to Cafeteria A	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D		
A	BS	South Hallway at Entrance to Cafeteria A	N/A	Brick Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A		
A	BS	South Hallway at Entrance to Cafeteria A	N/A	Sheetrock Wall		Non Suspect ACM	200	SF	0					N/A	N/A	N/A		
A	BS	South Hallway at Entrance to Cafeteria A	M	Transite Wall	7010/01/0B/SYN/BB/2380	Assumed	30	SF	0			Upper Wall Panels along Former School Store		1	No	1/D		
A	BS	South Hallway at Entrance to Cafeteria A	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A		
A	BS	South Hallway at Entrance to Cafeteria A	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	95	LF	0	LF				1	No	1/D		
A	BS	South Hallway at Entrance to Cafeteria A	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	35	EA	0					1	No	1/D		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	N/A	Concrete Floor		Non Suspect ACM	1500	SF	0					N/A	N/A	N/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	240	LF	0					1	No	1/D		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	N/A	Brick Wall		Non Suspect ACM	4500	SF	0					N/A	N/A	N/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	N/A	Concrete Ceiling		Non Suspect ACM	1500	SF	0					N/A	N/A	N/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	831	LF	9	LF		Open Ends, Open Seams and Damaged Lagging		1	Yes	2/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	163	EA	2	EA		Damaged Fittings		1	Yes	2/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	225	LF	0					N/A	N/A	N/A		
A	BS	South Hallway outside Stairwell 2 to Classroom 005	T	Pipe Insulation > 6 inch	7010/01/0B/07	Confirmed	8	LF	1	LF		Open End Outside of Water Main/Storage Room		1	Yes	2/A		
A	BS	Southeast Hallway outside Classroom 007	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A		

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)			
A	BS	Southeast Hallway outside Classroom 007	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D			
A	BS	Southeast Hallway outside Classroom 007	N/A	Brick Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway outside Classroom 007	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway outside Classroom 007	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	60	LF	0					1	No	1/D			
A	BS	Southeast Hallway outside Classroom 007	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	11	EA	0					1	No	1/D			
A	BS	Southeast Hallway outside Classroom 007	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	35	LF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway Foyer outside Classroom 007	N/A	Concrete Floor		Non Suspect ACM	80	SF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway Foyer outside Classroom 007	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	20	LF	0					1	No	1/D			
A	BS	Southeast Hallway Foyer outside Classroom 007	N/A	Brick Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway Foyer outside Classroom 007	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0					N/A	N/A	N/A			
A	BS	Southeast Hallway Foyer outside Classroom 007	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	7	LF	0					1	No	1/D			
A	BS	Southeast Hallway Foyer outside Classroom 007	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	11	EA	0					1	No	1/D			
A	BS	Gas Main/Storage Room next to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	250	SF	0			Gas Smell - B.E. reported a leak		N/A	N/A	N/A			
A	BS	Gas Main/Storage Room next to Stairwell 1	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	100	SF	0		Blue			1	No	1/D			
A	BS	Gas Main/Storage Room next to Stairwell 1	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	70	LF	0					1	No	1/D			
A	BS	Gas Main/Storage Room next to Stairwell 1	N/A	Brick Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A			
A	BS	Gas Main/Storage Room next to Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	BS	Gas Main/Storage Room next to Stairwell 1	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	26	LF	0					1	No	1/D			
A	BS	Gas Main/Storage Room next to Stairwell 1	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	15	EA	0					1	No	1/D			
A	BS	School Police Camera Room	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	150	SF	0		Blue			1	No	1/D			
A	BS	School Police Camera Room	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D			
A	BS	School Police Camera Room	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A			
A	BS	School Police Camera Room	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A			
A	BS	School Police Camera Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	54	LF	0					1	No	1/D			
A	BS	School Police Camera Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	18	EA	0					1	No	1/D			
A	BS	School Police Camera Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	60	LF	0					N/A	N/A	N/A			
A	BS	School Police Holding Room	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	65	SF	0		Blue			1	No	1/D			
A	BS	School Police Holding Room	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	30	LF	0					1	No	1/D			
A	BS	School Police Holding Room	N/A	Brick Wall		Non Suspect ACM	195	SF	0					N/A	N/A	N/A			
A	BS	School Police Holding Room	N/A	Concrete Ceiling		Non Suspect ACM	65	SF	0					N/A	N/A	N/A			
A	BS	School Police Office	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	150	SF	0		Tan			1	No	1/D			
A	BS	School Police Office	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A			
A	BS	School Police Office	N/A	Ceiling Tile 2' x 2'		NAD	150	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	1100	SF	0		Grey			1	No	1/D			
A	BS	Classroom 007	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	150	LF	0					1	No	1/D			
A	BS	Classroom 007	N/A	Brick Wall		Non Suspect ACM	1650	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007	N/A	Plaster Walls		NAD	1650	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007	N/A	Ceiling Tile 2' x 4'		NAD	1100	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	44	LF	0					1	No	1/D			
A	BS	Classroom 007	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	5	EA	0					1	No	1/D			
A	BS	Classroom 007 Left Storage Room	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	170	SF	0		Tan			1	No	1/D			
A	BS	Classroom 007 Left Storage Room	N/A	Brick Wall		Non Suspect ACM	510	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007 Left Storage Room	N/A	Concrete Ceiling		Non Suspect ACM	170	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007 Right Storage Room	N/A	Concrete Floor		Non Suspect ACM	170	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007 Right Storage Room	N/A	Brick Wall		Non Suspect ACM	510	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007 Right Storage Room	N/A	Concrete Ceiling		Non Suspect ACM	170	SF	0					N/A	N/A	N/A			
A	BS	Classroom 007 Right Storage Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	55	LF	2	LF		Damaged Lagging and Open Seam		1	Yes	2/A			
A	BS	Classroom 007 Right Storage Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	12	EA	0					1	No	1/D			
A	BS	Classroom 005	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A			
A	BS	Classroom 005	N/A	Brick Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A			
A	BS	Classroom 005	N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A			
A	BS	Classroom 005	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A			
A	BS	Classroom 005	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
A	BS	Classroom 005	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	50	LF	0					N/A	N/A	N/A			
A	BS	Classroom 004	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	900	SF	0		Tan			1	No	1/D			
A	BS	Classroom 004	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	120	LF	0					1	No	1/D			
A	BS	Classroom 004	N/A	Brick Wall		Non Suspect ACM	1350	SF	0					N/A	N/A	N/A			
A	BS	Classroom 004	N/A	Plaster Walls		NAD	1350	SF	0					N/A	N/A	N/A			
A	BS	Classroom 004	N/A	Sheetrock Wall		Non Suspect ACM	340	SF	0					N/A	N/A	N/A			
A	BS	Classroom 004	N/A	Ceiling Tile 2' x 4'		NAD	900	SF	0					N/A	N/A	N/A			
A	BS	Classroom 004	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
A	BS	Classroom 004	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0					N/A	N/A	N/A			
A	BS	Administrative Office Space next to Classroom 004	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	900	SF	0		Tan			1	No	1/D			
A	BS	Administrative Office Space next to Classroom 004	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	120	LF	0					1	No	1/D			
A	BS	Administrative Office Space next to Classroom 004	N/A	Brick Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A			
A	BS	Administrative Office Space next to Classroom 004	N/A	Sheetrock Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A			
A	BS	Administrative Office Space next to Classroom 004	N/A	Ceiling Tile 2' x 4'		NAD	900	SF	0					N/A	N/A	N/A			
A	BS	Administrative Office Space next to Classroom 004	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	25	SF	0					1	No	1/D			
A	BS	Administrative Office Space next to Classroom 004	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	25	LF	0					N/A	N/A	N/A			
A	BS	Sex Education Office	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	300	SF	0		Tan			1	No	1/D			
A	BS	Sex Education Office	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	40	LF	0					1	No	1/D			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	BS	Sex Education Office	N/A	Brick Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Sex Education Office	N/A	Sheetrock Wall		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	Sex Education Office	N/A	Ceiling Tile 2' x 4'		NAD	300	SF	0					N/A	N/A	N/A
A	BS	Sex Education Office	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	25	SF	0					1	No	1/D
A	BS	Sex Education Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0					N/A	N/A	N/A
A	BS	Foyer to Sex Education Office	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	65	SF	0		Tan			1	No	1/D
A	BS	Foyer to Sex Education Office	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	8	LF	0					1	No	1/D
A	BS	Foyer to Sex Education Office	N/A	Brick Wall		Non Suspect ACM	65	SF	0					N/A	N/A	N/A
A	BS	Foyer to Sex Education Office	N/A	Sheetrock Wall		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	BS	Foyer to Sex Education Office	N/A	Ceiling Tile 2' x 4'		NAD	65	SF	0					N/A	N/A	N/A
A	BS	Foyer to Sex Education Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0					N/A	N/A	N/A
A	BS	Sex Education Office Storage Room	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	115	SF	0		Tan			1	No	1/D
A	BS	Sex Education Office Storage Room	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	40	LF	0					1	No	1/D
A	BS	Sex Education Office Storage Room	N/A	Brick Wall		Non Suspect ACM	345	SF	0					N/A	N/A	N/A
A	BS	Sex Education Office Storage Room	N/A	Ceiling Tile 2' x 4'		NAD	115	SF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	11	LF	0					N/A	N/A	N/A
A	BS	Stairwell 2	N/A	Cement Board Walls		Non Suspect ACM	65	SF	0			Newer Type Material		N/A	N/A	N/A
A	BS	Water Main/Storage Room	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Water Main/Storage Room	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	Water Main/Storage Room	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Water Main/Storage Room	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Water Main/Storage Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	110	LF	8		LF	Open Ends and Open Seams		1	Yes	2/C
A	BS	Water Main/Storage Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	18	EA	0					1	No	1/D
A	BS	Water Main/Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0					N/A	N/A	N/A
A	BS	Men's Student Restroom across from Classroom 004	N/A	Ceramic Tile Floors		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	Men's Student Restroom across from Classroom 004	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
A	BS	Men's Student Restroom across from Classroom 004	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	Men's Student Restroom across from Classroom 004	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	40	LF	3		LF	Open Ends		1	Yes	2/A
A	BS	Men's Student Restroom across from Classroom 004	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	20	EA	0					1	No	1/D
A	BS	Men's Student Restroom across from Classroom 004	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	150	LF	0					N/A	N/A	N/A
A	BS	Storage Room across from Former School Store	N/A	Concrete Floor		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Former School Store	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	80	LF	0					1	No	1/D
A	BS	Storage Room across from Former School Store	N/A	Brick Wall		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Former School Store	N/A	Sheetrock Wall		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Former School Store	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
A	BS	South Fan Room across from Sexual Education Office	N/A	Concrete Floor		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A
A	BS	South Fan Room across from Sexual Education Office	N/A	Brick Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
A	BS	South Fan Room across from Sexual Education Office	N/A	Concrete Ceiling		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A
A	BS	South Fan Room across from Sexual Education Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	400	LF	0					N/A	N/A	N/A
A	BS	South Fan Room across from Sexual Education Office	N/A	Fiberglass Duct Insulation		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	100	LF	0					1	No	1/D
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	N/A	Brick Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	250	LF	6		LF	Open Ends		1	Yes	2/C
A	BS	Narrow Hallway between Auditorium Fan Room and Electric Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	25	EA	0					1	No	1/D
A	BS	Auditorium Fan Room/Cleaners Lounge	N/A	Concrete Floor		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	Auditorium Fan Room/Cleaners Lounge	N/A	Brick Wall		Non Suspect ACM	7200	SF	0					N/A	N/A	N/A
A	BS	Auditorium Fan Room/Cleaners Lounge	N/A	Sheetrock Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Auditorium Fan Room/Cleaners Lounge	N/A	Concrete Ceiling		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	Auditorium Fan Room/Cleaners Lounge	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	220	LF	0					1	No	1/D
A	BS	Auditorium Fan Room/Cleaners Lounge	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	50	EA	0					1	No	1/D

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728					
E l e m e n t	F l o o r	On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	BS	Auditorium Fan Room/Cleaners Lounge		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	250	LF	0					N/A	N/A	N/A
A	BS	Main Electric Room		N/A	Concrete Floor		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	Main Electric Room		M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	80	LF	0					1	No	1/D
A	BS	Main Electric Room		N/A	Terra Cotta Walls		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	Main Electric Room		N/A	Concrete Ceiling		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
A	BS	Main Electric Room		T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	224	LF	0					1	No	1/D
A	BS	Main Electric Room		T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	60	EA	0					1	No	1/D
A	BS	Main Electric Room		T	Pipe Insulation > 6 inch	7010/01/0B/07	Confirmed	65	LF	0					1	No	1/D
A	BS	Main Electric Room		M	Fire Doors	7010/01/0B/SYN/BB/1635	Assumed	1	EA	0			Metal Fire Door between Main Electric Room and Small Electric Room		1	No	1/D
A	BS	Small Electric Room inside Main Electric Room		N/A	Concrete Floor		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Small Electric Room inside Main Electric Room		N/A	Brick Wall		Non Suspect ACM	1350	SF	0					N/A	N/A	N/A
A	BS	Small Electric Room inside Main Electric Room		N/A	Concrete Ceiling		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Small Electric Room inside Main Electric Room		N/A	Vinyl Vibration Damper Cloth		Non Suspect ACM	4	SF	0					N/A	N/A	N/A
A	BS	Small Electric Room inside Main Electric Room		M	Transite Electrical Panel	7010/01/0B/SYN/BB/2350	Assumed	100	SF	0			Old High Voltage Capacitors		1	No	1/D
A	BS	Storage Room across from Stairwell 3		N/A	Concrete Floor		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Stairwell 3		M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D
A	BS	Storage Room across from Stairwell 3		N/A	Brick Wall		Non Suspect ACM	1350	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
A	BS	Storage Room across from Stairwell 3		M	Transite Electrical Panel	7010/01/0B/SYN/BB/2350	Confirmed	40	SF	0			2 Panels - 20 SF Each		1	No	1/D
A	BS	Storage Room across from Stairwell 3		T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	65	LF	0					1	No	1/D
A	BS	Storage Room across from Stairwell 3		T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	10	EA	0					1	No	1/D
A	BS	Storage Room across from Stairwell 3		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0					N/A	N/A	N/A
A	BS	Stairwell 3		N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Stairwell 3		N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 3		N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	BS	Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Stairwell 3		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0					N/A	N/A	N/A
A	BS	Hallway outside of Stairwell 3		N/A	Concrete Floor		Non Suspect ACM	480	SF	0					N/A	N/A	N/A
A	BS	Hallway outside of Stairwell 3		M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	80	LF	0					1	No	1/D
A	BS	Hallway outside of Stairwell 3		N/A	Brick Wall		Non Suspect ACM	1440	SF	0					N/A	N/A	N/A
A	BS	Hallway outside of Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	480	SF	0					N/A	N/A	N/A
A	BS	Hallway outside of Stairwell 3		T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	110	LF	0					1	No	1/D
A	BS	Hallway outside of Stairwell 3		T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	36	EA	0					1	No	1/D
A	BS	Hallway outside of Stairwell 3		T	Pipe Insulation > 6 inch	7010/01/0B/07	Confirmed	30	LF	0					1	No	1/D
A	BS	Hallway outside of Stairwell 3		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	120	LF	0					N/A	N/A	N/A
A	BS	Building Engineer's Office		M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	150	SF	1	SF	Green			1	Yes	5/B
A	BS	Building Engineer's Office		M	Transite Cove Base	7010/01/0B/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	BS	Building Engineer's Office		N/A	Brick Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
A	BS	Building Engineer's Office		N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	BS	Building Engineer's Office		T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	80	LF	2	LF		Damaged Lagging and Open Seam		1	Yes	2/A
A	BS	Building Engineer's Office		T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	15	EA	0					1	No	1/D
A	BS	Building Engineer's Office		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	2	LF	0					N/A	N/A	N/A
A	BS	Building Engineer's Office		M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	12	SF	0					1	No	1/D
A	BS	Boiler Room		N/A	Concrete Floor		Non Suspect ACM	2000	SF	0					N/A	N/A	N/A
A	BS	Boiler Room		N/A	Brick Wall		Non Suspect ACM	8000	SF	0					N/A	N/A	N/A
A	BS	Boiler Room		N/A	Concrete Ceiling		Non Suspect ACM	2000	SF	0					N/A	N/A	N/A
A	BS	Boiler Room		T	Sectional Boiler	7010/01/0B/SYN/BB/1620	Assumed	4	EA	0					1	No	1/D
A	BS	Boiler Room		M	Brick Boiler	7010/01/0B/SYN/BB/1610	Assumed	2	EA	0					1	No	1/D
A	BS	Boiler Room		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	500	LF	0					N/A	N/A	N/A
A	BS	Boiler Room		N/A	Fiberglass Tank Insulation		Non Suspect ACM	200	SF	0			2 Tanks - 100 SF Each		N/A	N/A	N/A
A	BS	Boiler Room		M	Fire Doors	7010/01/0B/SYN/BB/1635	Assumed	1	EA	0			Large Metal Fire Door between Boiler Room and Upper Hallway		1	No	1/D
A	BS	Upper Hallway behind Boiler Room		N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Upper Hallway behind Boiler Room		N/A	Brick Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
A	BS	Upper Hallway behind Boiler Room		N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	BS	Upper Hallway behind Boiler Room		M	Fire Doors	7010/01/0B/SYN/BB/1635	Assumed	1	EA	0			Large Metal Fire Door between Upper Hallway and Emergency Generator Room		1	No	1/D
A	BS	Emergency Generator Room behind Boiler Room		N/A	Brick Floor		Non Suspect ACM	200	SF	0			No Generator Flue Insulation		N/A	N/A	N/A
A	BS	Emergency Generator Room behind Boiler Room		N/A	Brick Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Emergency Generator Room behind Boiler Room		N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Grounds-keeping Storage Room behind Boiler Room		N/A	Brick Floor		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Grounds-keeping Storage Room behind Boiler Room		N/A	Brick Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	BS	Grounds-keeping Storage Room behind Boiler Room		N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	BS	Spiral Staircase next to Grounds-keeping Storage Room behind Boiler Room		N/A	Brick Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	BS	Spiral Staircase next to Grounds-keeping Storage Room behind Boiler Room		N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A
A	BS	Spiral Staircase next to Grounds-keeping Storage Room behind Boiler Room		N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	BS	Spiral Staircase in Northeast Corner of Boiler Room		N/A	Brick Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728							
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
A	BS	Spiral Staircase in Northeast Corner of Boiler Room	N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A				
A	BS	Spiral Staircase in Northeast Corner of Boiler Room	N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A				
A	BS	Spiral Staircase in Southeast Corner of Boiler Room	N/A	Brick Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A				
A	BS	Spiral Staircase in Southeast Corner of Boiler Room	N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A				
A	BS	Spiral Staircase in Southeast Corner of Boiler Room	N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A				
A	1	Office next to Stairwell 3	N/A	Wood Floor		Non Suspect ACM	200	SF	0	x	x			N/A	N/A	N/A				
A	1	Office next to Stairwell 3	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Office next to Stairwell 3	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A				
A	1	Office next to Stairwell 3	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	12	LF	0			Additional Quantity above ACTs		1	No	1/D				
A	1	Stairwell 3	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Stairwell 3	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A				
A	1	Stairwell 3	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A				
A	1	Stairwell 3	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Stairwell 3	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	23	LF	0			Basement - 1st Floor Landing		N/A	N/A	N/A				
A	1	Classroom 102	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 102	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A				
A	1	Classroom 102	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 102	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	48	LF	0					1	No	1/D				
A	1	Classroom 102	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	3	LF	0					N/A	N/A	N/A				
A	1	Classroom 102	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D				
A	1	Classroom 103	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	600	SF	1	SF	Blue			1	Yes	5/B				
A	1	Classroom 103	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A				
A	1	Classroom 103	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 103	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	48	LF	4	LF		Open Seams		1	Yes	2/A				
A	1	Classroom 103	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D				
A	1	Classroom 103	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0			All comprised of wood and cloth		N/A	N/A	N/A				
A	1	Classroom 104	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	300	SF	1	SF	Blue			1	Yes	5/B				
A	1	Classroom 104	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	300	SF	1	SF	White			1	Yes	5/B				
A	1	Classroom 104	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	36	LF	0					1	No	1/D				
A	1	Classroom 104	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D				
A	1	Classroom 104	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Classroom 104	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	40	LF	0					1	No	1/D				
A	1	Classroom 104	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D				
A	1	Classroom 106	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 106	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Classroom 106	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 106	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	48	LF	1	LF		Open Seam in Corner		1	Yes	2/A				
A	1	Classroom 106	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	200	SF	0					1	No	1/D				
A	1	Classroom 107	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	700	SF	1	SF	Tan			1	Yes	5/B				
A	1	Classroom 107	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Classroom 107	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 107	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D				
A	1	Classroom 108	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 108	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Classroom 108	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 108	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	48	LF	0					1	No	1/D				
A	1	Classroom 108	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D				
A	1	IT MDF/Storage Room next to Classroom 108	N/A	Wood Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	IT MDF/Storage Room next to Classroom 108	N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A				
A	1	IT MDF/Storage Room next to Classroom 108	N/A	Ceiling Tile 2' x 4'		NAD	300	SF	0					N/A	N/A	N/A				
A	1	IT MDF/Storage Room next to Classroom 108	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D				
A	1	Storage Room next to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	72	SF	0					N/A	N/A	N/A				
A	1	Storage Room next to Stairwell 4	N/A	Brick Wall		Non Suspect ACM	144	SF	0					N/A	N/A	N/A				
A	1	Storage Room next to Stairwell 4	N/A	Sheetrock Wall		Non Suspect ACM	72	SF	0					N/A	N/A	N/A				
A	1	Storage Room next to Stairwell 4	N/A	Plaster Ceiling		NAD	72	SF	0					N/A	N/A	N/A				
A	1	Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Stairwell 4	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A				
A	1	Stairwell 4	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A				
A	1	Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Stairwell 4	N/A	Plywood Panels		Non Suspect ACM	50	SF	0			Below Windows on Basement - 1st Floor Landing		N/A	N/A	N/A				
A	1	Hallway outside Classrooms 102 - 108	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 102 - 108	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D				
A	1	Hallway outside Classrooms 102 - 108	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 102 - 108	N/A	Plaster Ceiling		NAD	1250	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 102 - 108	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	152	LF	3	LF		Open Seams		1	Yes	2/A				
A	1	Hallway outside Classrooms 102 - 108	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	34	EA	0					1	No	1/D				

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914										AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report					Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
A	1	Hallway outside Classrooms 102 - 108	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	7	LF	7	LF				N/A	N/A	N/A				
A	1	Hallway outside Classrooms 106 - 107	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 106 - 107	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D				
A	1	Hallway outside Classrooms 106 - 107	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 106 - 107	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 106 - 107	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	30	LF	1	LF		Open Seam		1	Yes	2/A				
A	1	Hallway outside Classrooms 106 - 107	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	5	EA	0					1	No	1/D				
A	1	Women's Student Restroom across from Classroom 104	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0					N/A	N/A	N/A				
A	1	Women's Student Restroom across from Classroom 104	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D				
A	1	Women's Student Restroom across from Classroom 104	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A				
A	1	Women's Student Restroom across from Classroom 104	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A				
A	1	Women's Student Restroom across from Classroom 104	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	20	LF	0					1	No	1/D				
A	1	Custodial Closet across from Classroom 104	x	x		x	x	x	x	x		No Access		x	x	x				
A	1	Women's Staff Restroom across from Classroom 103	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0	x	x			N/A	N/A	N/A				
A	1	Women's Staff Restroom across from Classroom 103	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D				
A	1	Women's Staff Restroom across from Classroom 103	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A				
A	1	Women's Staff Restroom across from Classroom 103	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A				
A	1	Women's Staff Restroom across from Classroom 103	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	80	LF	0					1	No	1/D				
A	1	Women's Staff Restroom across from Classroom 103	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	18	EA	1	EA				1	Yes	5/A				
A	1	Classroom 110	N/A	Wood Floor		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A				
A	1	Classroom 110	N/A	Plaster Walls		NAD	3000	SF	0					N/A	N/A	N/A				
A	1	Classroom 110	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A				
A	1	Classroom 110	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D				
A	1	Classroom 110	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	200	SF	0					1	No	1/D				
A	1	Classroom 110	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0					N/A	N/A	N/A				
A	1	Classroom 111	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 111	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Classroom 111	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Classroom 111	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	12	LF	0					1	No	1/D				
A	1	Classroom 111	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D				
A	1	Classroom 111	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 110 - 111	N/A	Concrete Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 110 - 111	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	140	LF	0					1	No	1/D				
A	1	Hallway outside Classrooms 110 - 111	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 110 - 111	N/A	Plaster Ceiling		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 110 - 111	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	95	LF	0					1	No	1/D				
A	1	Hallway outside Classrooms 110 - 111	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	18	EA	0					1	No	1/D				
A	1	Grand Hallway outside of Auditorium	N/A	Marble Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Grand Hallway outside of Auditorium	N/A	Terrazo Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Grand Hallway outside of Auditorium	N/A	Plaster Walls		NAD	1800	SF	0			Decorative Plaster Moldings		N/A	N/A	N/A				
A	1	Grand Hallway outside of Auditorium	N/A	Plaster Ceiling		NAD	600	SF	0			Decorative Plaster Moldings		N/A	N/A	N/A				
A	1	Hallway outside Classrooms 113 - 115	N/A	Concrete Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 113 - 115	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	140	LF	0					1	No	1/D				
A	1	Hallway outside Classrooms 113 - 115	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 113 - 115	N/A	Plaster Ceiling		NAD	700	SF	0					N/A	N/A	N/A				
A	1	Hallway outside Classrooms 113 - 115	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	105	LF	4	LF		Open Seams		1	Yes	2/A				
A	1	Hallway outside Classrooms 113 - 115	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	24	EA	0					1	No	1/D				
A	1	Former Main Entrance Vestibule/Stairs	N/A	Marble Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
A	1	Former Main Entrance Vestibule/Stairs	N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A				
A	1	Former Main Entrance Vestibule/Stairs	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A				
A	1	Office next to Former Main Entrance Vestibule	N/A	Wood Floor		Non Suspect ACM	200	SF	0					N/A	N/A	N/A				
A	1	Office next to Former Main Entrance Vestibule	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A				
A	1	Office next to Former Main Entrance Vestibule	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A				
A	1	Office next to Former Main Entrance Vestibule	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	36	LF	1	LF		Open Seam		1	Yes	2/A				
A	1	Copy Room next to Former Main Entrance Vestibule	N/A	Wood Floor		Non Suspect ACM	400	SF	0					N/A	N/A	N/A				
A	1	Copy Room next to Former Main Entrance Vestibule	N/A	Plaster Walls		NAD	1200	SF	0					N/A	N/A	N/A				
A	1	Copy Room next to Former Main Entrance Vestibule	N/A	Ceiling Tile 2' x 4'		NAD	400	SF	0					N/A	N/A	N/A				
A	1	Copy Room next to Former Main Entrance Vestibule	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	32	SF	0					1	No	1/D				
A	1	Men's Staff Restroom next to Former Main Entrance Vestibule	N/A	Wood Floor		Non Suspect ACM	200	SF	0					N/A	N/A	N/A				

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report									Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728				
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	1	Men's Staff Restroom next to Former Main Entrance Vestibule	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A
A	1	Men's Staff Restroom next to Former Main Entrance Vestibule	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
A	1	Men's Staff Restroom next to Former Main Entrance Vestibule	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D
A	1	Men's Staff Lounge next to Former Main Entrance Vestibule	N/A	Wood Floor		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
A	1	Men's Staff Lounge next to Former Main Entrance Vestibule	N/A	Plaster Walls		NAD	1200	SF	0					N/A	N/A	N/A
A	1	Men's Staff Lounge next to Former Main Entrance Vestibule	N/A	Ceiling Tile 2' x 4'		NAD	400	SF	0					N/A	N/A	N/A
A	1	Classroom 113	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A
A	1	Classroom 113	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A
A	1	Classroom 113	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A
A	1	Classroom 113	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D
A	1	Classroom 113	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D
A	1	Office between Classrooms 113 and 115	N/A	Wood Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	1	Office between Classrooms 113 and 115	N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A
A	1	Office between Classrooms 113 and 115	N/A	Ceiling Tile 2' x 4'		NAD	300	SF	0					N/A	N/A	N/A
A	1	Office between Classrooms 113 and 115	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	40	SF	0					1	No	1/D
A	1	Classroom 115	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A
A	1	Classroom 115	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A
A	1	Classroom 115	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A
A	1	Classroom 115	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D
A	1	Classroom 115	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	210	SF	0					1	No	1/D
A	1	Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	1	Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	1	Stairwell 1	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	1	Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	1	Custodial Closet next to Stairwell 1	N/A	Metal Floor		Non Suspect ACM	16	SF	0					N/A	N/A	N/A
A	1	Custodial Closet next to Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
A	1	Custodial Closet next to Stairwell 1	N/A	Metal Ceiling		Non Suspect ACM	16	SF	0					N/A	N/A	N/A
A	1	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x
A	1	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x
A	1	Storage Room next to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	72	SF	0					N/A	N/A	N/A
A	1	Storage Room next to Stairwell 1	N/A	Brick Wall		Non Suspect ACM	144	SF	0					N/A	N/A	N/A
A	1	Storage Room next to Stairwell 1	N/A	Sheetrock Wall		Non Suspect ACM	72	SF	0					N/A	N/A	N/A
A	1	Storage Room next to Stairwell 1	N/A	Plaster Ceiling		NAD	72	SF	0					N/A	N/A	N/A
A	1	Hallway from A Building to D Building Addition	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	240	SF	0		Tan			1	No	1/D
A	1	Hallway from A Building to D Building Addition	N/A	Concrete Block Wall		Non Suspect ACM	720	SF	0					N/A	N/A	N/A
A	1	Hallway from A Building to D Building Addition	N/A	Ceiling Tile 2' x 4'		NAD	240	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 117 - 121	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 117 - 121	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D
A	1	Hallway outside Classrooms 117 - 121	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 117 - 121	N/A	Plaster Ceiling		NAD	1250	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 117 - 121	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	139	LF	0					1	No	1/D
A	1	Hallway outside Classrooms 117 - 121	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	31	EA	2	EA		Open Ends outside Auditorium		1	Yes	2/A
A	1	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x
A	1	Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	1	Stairwell 2	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	1	Stairwell 2	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	1	Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	1	Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0			Basement - 1st Floor Landing		N/A	N/A	N/A
A	1	Art Classroom 117	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	600	SF	0		Tan			1	No	1/D
A	1	Art Classroom 117	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	100	LF	0					1	No	1/D
A	1	Art Classroom 117	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A
A	1	Art Classroom 117	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
A	1	Art Classroom 117	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	0					1	No	1/D
A	1	Art Classroom 117	M	Transite	7010/01/01/SYN/BB/2305	Assumed	100	SF	0			Appear to be Soap Stone		1	No	1/D
A	1	Art Classroom 118	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	1200	SF	300	SF	Tan	Tiles are Loose/Lifting		2	Yes	5/A
A	1	Art Classroom 118	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	150	LF	0					1	No	1/D
A	1	Art Classroom 118	N/A	Plaster Walls		NAD	3600	SF	0					N/A	N/A	N/A
A	1	Art Classroom 118	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
A	1	Art Classroom 118	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	96	LF	2	LF		Torn Lagging		1	Yes	2/A
A	1	Art Classroom 118	M	Transite Table Top	7010/01/01/SYN/BB/2330	Assumed	8	SF	0			Table Top		1	No	1/D
A	1	Storage Room between Art Classrooms 117 & 118	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	300	SF	Tan			1	Yes	5/B
A	1	Storage Room between Art Classrooms 117 & 118	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	1	Storage Room between Art Classrooms 117 & 118	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A
A	1	Storage Room between Art Classrooms 117 & 118	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
A	1	Art Classroom 118 Storage Room	x	x		x	x	x	x	x	x	No Access		x	x	x

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016			
													Building Inspector: Bernard J Bryson			
													Number: ACC-0125-6-031			
													Management Planner: Megan Vala			
													Number: 740728			
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	1	Classroom 119	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	1	Classroom 119	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A
A	1	Classroom 119	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
A	1	Classroom 119	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	24	LF	2	LF		Open Seams		1	Yes	2/A
A	1	Classroom 119	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	60	SF	0					1	No	1/D
A	1	Classroom 119	M	Transite Wall	7010/01/08/SYN/BB/2380	Assumed	24	SF	0			Lower Wall Panel		1	No	1/D
A	1	Hallway outside Classrooms 120 - 121	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 120 - 121	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D
A	1	Hallway outside Classrooms 120 - 121	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 120 - 121	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
A	1	Hallway outside Classrooms 120 - 121	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	37	LF	0					1	No	1/D
A	1	Hallway outside Classrooms 120 - 121	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	8	EA	0					1	No	1/D
A	1	Computer Classroom 120	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
A	1	Computer Classroom 120	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A
A	1	Computer Classroom 120	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
A	1	Computer Classroom 120	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D
A	1	Classroom 121	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A
A	1	Classroom 121	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A
A	1	Classroom 121	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A
A	1	Classroom 121	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	41	LF	0					1	No	1/D
A	1	Classroom 121	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	110	SF	0					1	No	1/D
A	1	Custodial Closet across from Art Classroom 118	N/A	Concrete Floor		Non Suspect ACM	12	SF	0					N/A	N/A	N/A
A	1	Custodial Closet across from Art Classroom 118	N/A	Plaster Walls		NAD	100	SF	0					N/A	N/A	N/A
A	1	Custodial Closet across from Art Classroom 118	N/A	Plaster Ceiling		NAD	12	SF	0					N/A	N/A	N/A
A	1	Custodial Closet across from Art Classroom 118	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	38	LF	3	LF		Open End and Damaged Lagging		1	Yes	2/A
A	1	Custodial Closet across from Art Classroom 118	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	3	EA	0					1	No	1/D
A	1	Custodial Closet across from Art Classroom 118	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	17	LF	0					N/A	N/A	N/A
A	1	Men's Student Restroom across from Art Classroom 118	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	1	Men's Student Restroom across from Art Classroom 118	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D
A	1	Men's Student Restroom across from Art Classroom 118	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A
A	1	Men's Student Restroom across from Art Classroom 118	N/A	Plaster Ceiling		NAD	200	SF	0					N/A	N/A	N/A
A	1	Men's Student Restroom across from Art Classroom 118	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	8	LF	0					1	No	1/D
A	1	Men's Student Restroom across from Art Classroom 118	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	35	LF	0					N/A	N/A	N/A
A	1	Auditorium	N/A	Wood Floor		Non Suspect ACM	4800	SF	0					N/A	N/A	N/A
A	1	Auditorium	N/A	Plaster Walls		NAD	14400	SF	0					N/A	N/A	N/A
A	1	Auditorium	N/A	Plaster Ceiling		NAD	4800	SF	0					N/A	N/A	N/A
A	1	Auditorium	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	116	LF	2	LF		Open Ends		1	Yes	2/A
A	1	Auditorium	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	2	EA	0					1	No	1/D
A	1	Auditorium	T	Radiator Insulation	7010/01/01/SYN/BB/1600	Assumed	480	SF	0			Radiators are Connected, Full Length on Each Side		1	No	1/D
A	1	Auditorium Stage	N/A	Wood Floor		Non Suspect ACM	900	SF	0			Stage Light Wiring is Newer - No Cloth Wire Wrap		N/A	N/A	N/A
A	1	Auditorium Stage	N/A	Plaster Walls		NAD	2700	SF	0					N/A	N/A	N/A
A	1	Auditorium Stage	N/A	Plaster Ceiling		NAD	900	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Left)	N/A	Wood Floor		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Left)	N/A	Plaster Walls		NAD	240	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Left)	N/A	Plaster Ceiling		NAD	80	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Left)	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	38	LF	0					1	No	1/D
A	1	Side Stage Storage Room (Stage Left)	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	8	EA	0					1	No	1/D
A	1	Side Stage Restroom (Stage Left)	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	25	SF	0		Tan			1	No	1/D
A	1	Side Stage Restroom (Stage Left)	N/A	Plaster Walls		NAD	100	SF	0					N/A	N/A	N/A
A	1	Side Stage Restroom (Stage Left)	N/A	Ceiling Tile 2' x 4'		NAD	25	SF	0					N/A	N/A	N/A
A	1	Side Stage Electric Room (Stage Left)	N/A	Wood Floor		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
A	1	Side Stage Electric Room (Stage Left)	N/A	Plaster Walls		NAD	150	SF	0					N/A	N/A	N/A
A	1	Side Stage Electric Room (Stage Left)	N/A	Plaster Ceiling		NAD	50	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Right)	N/A	Wood Floor		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Right)	N/A	Plaster Walls		NAD	240	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Right)	N/A	Plaster Ceiling		NAD	80	SF	0					N/A	N/A	N/A
A	1	Side Stage Storage Room (Stage Right)	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	21	LF	0					1	No	1/D
A	1	Side Stage Storage Room (Stage Right)	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	6	EA	0					1	No	1/D
A	1	Side Stage Restroom (Stage Right)	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	25	SF	0		Tan			1	No	1/D
A	1	Side Stage Restroom (Stage Right)	N/A	Plaster Walls		NAD	100	SF	0					N/A	N/A	N/A
A	1	Side Stage Restroom (Stage Right)	N/A	Ceiling Tile 2' x 4'		NAD	25	SF	0					N/A	N/A	N/A
A	1	Side Stage Restroom (Stage Right)	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	45	LF	0			Behind Walls and above ACTs (limited visibility)		1	No	1/D
A	1	Side Stage Restroom (Stage Right)	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	8	EA	0			Behind Walls and above ACTs (limited visibility)		1	No	1/D
A	1	Side Stage Restroom (Stage Right)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	15	LF	0					N/A	N/A	N/A
A	1	Narrow Hallway behind Auditorium Stage	N/A	Wood Floor		Non Suspect ACM	100	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	1	Narrow Hallway behind Auditorium Stage	N/A	Plaster Walls		NAD	300	SF	0					N/A	N/A	N/A
A	1	Narrow Hallway behind Auditorium Stage	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
A	1	Narrow Hallway behind Auditorium Stage	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	28	LF	2	LF		Open Ends		1	Yes	2/A
A	1	Hallway behind Auditorium - Restricted Area	N/A	Concrete Floor		Non Suspect ACM	750	SF	0			Includes H15		N/A	N/A	N/A
A	1	Hallway behind Auditorium - Restricted Area	M	Transite Cove Base	7010/01/01/SYN/BB/2320	Assumed	150	LF	0					1	No	1/D
A	1	Hallway behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	2250	SF	0					N/A	N/A	N/A
A	1	Hallway behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	750	SF	0					N/A	N/A	N/A
A	1	Hallway behind Auditorium - Restricted Area	M	Transite Wall	7010/01/08/SYN/BB/2380	Confirmed	120	SF	0			Walls Surrounding Organ Fan		1	No	1/D
A	1	Unfinished Crawlspace behind Auditorium - Restricted Area	N/A	Compacted Gravel Floor		Non Suspect ACM	140	SF	0				"A"	N/A	N/A	N/A
A	1	West End Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	1	West End Spiral Staircase behind Auditorium - Restricted Area	N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A
A	1	West End Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	1	West End Storage Room behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
A	1	West End Storage Room behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A
A	1	West End Storage Room behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
A	1	West End Storage Room behind Auditorium - Restricted Area	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	38	LF	10	LF		Open Ends		1	Yes	2/A
A	1	West End Storage Room behind Auditorium - Restricted Area	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	4	EA	0					1	No	1/D
A	1	Northwest Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	1	Northwest Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A
A	1	Northwest Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	450	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	150	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room Closet behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	15	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room Closet behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	100	SF	0					N/A	N/A	N/A
A	1	Rear Right Storage Room Closet behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	15	SF	0					N/A	N/A	N/A
A	1	Restroom behind Auditorium - Restricted Area	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
A	1	Restroom behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	450	SF	0					N/A	N/A	N/A
A	1	Restroom behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	150	SF	0					N/A	N/A	N/A
A	1	Restroom behind Auditorium - Restricted Area	M	Transite Stalls	7010/01/01/SYN/BB/2310	Assumed	100	SF	0			Around Shower and Toilet Stall Partition - Painted; May be Marble		1	No	1/D
A	1	Storage Room next to Restroom behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	1	Storage Room next to Restroom behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	360	SF	0					N/A	N/A	N/A
A	1	Storage Room next to Restroom behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	120	SF	0					N/A	N/A	N/A
A	1	Middle Storage Room behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	1	Middle Storage Room behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	360	SF	0					N/A	N/A	N/A
A	1	Middle Storage Room behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	120	SF	0					N/A	N/A	N/A
A	1	First Storage Room behind Auditorium - Restricted Area	N/A	Wood Floor		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	1	First Storage Room behind Auditorium - Restricted Area	N/A	Plaster Walls		NAD	360	SF	0					N/A	N/A	N/A
A	1	First Storage Room behind Auditorium - Restricted Area	N/A	Plaster Ceiling		NAD	120	SF	0					N/A	N/A	N/A
A	1	Northeast Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A
A	1	Northeast Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Brick Wall		Non Suspect ACM	210	SF	0					N/A	N/A	N/A
A	1	Northeast Corner Spiral Staircase behind Auditorium - Restricted Area	N/A	Concrete Ceiling		Non Suspect ACM	70	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914				AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report							Reinspection Date: March 21-25, 2016				Attic Crawl Space Ranking				Damage Potential (DP)				Newly Friable (NF)				Response Action (RA)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
															Building Inspector: Bernard J Bryson																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
															Number: ACC-0125-6-031																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
															Management Planner: Megan Vala																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
															Number: 740728																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report									Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)		
A	2	Women's Student Restroom across from Classroom 204	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A		
A	2	Women's Student Restroom across from Classroom 204	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A		
A	2	Women's Student Restroom across from Classroom 204	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	45	LF	2	LF		Open End and Open Seam		1	Yes	2/A		
A	2	Women's Student Restroom across from Classroom 204	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	10	EA	1	EA				1	Yes	5/A		
A	2	Women's Student Restroom across from Classroom 204	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	60	LF	0					N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 204	N/A	Concrete Floor		Non Suspect ACM	12	SF	0					N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 204	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	10	LF	0					1	No	1/D		
A	2	Custodial Closet across from Classroom 204	N/A	Plaster Walls		NAD	80	SF	0					N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 204	N/A	Plaster Ceiling		NAD	12	SF	0					N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 204	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	72	LF	0					1	No	1/D		
A	2	Custodial Closet across from Classroom 204	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	4	EA	0					1	No	1/D		
A	2	Women's Staff Restroom across from Classroom 203	N/A	Ceramic Tile Floors		Non Suspect ACM	80	SF	0					N/A	N/A	N/A		
A	2	Women's Staff Restroom across from Classroom 203	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	36	LF	0					1	No	1/D		
A	2	Women's Staff Restroom across from Classroom 203	N/A	Plaster Walls		NAD	240	SF	0					N/A	N/A	N/A		
A	2	Women's Staff Restroom across from Classroom 203	N/A	Plaster Ceiling		NAD	80	SF	0					N/A	N/A	N/A		
A	2	Women's Staff Restroom across from Classroom 203	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	34	LF	4	LF		Open End and Open Seam		1	Yes	2/A		
A	2	Women's Staff Restroom across from Classroom 203	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	8	EA	2	EA				1	Yes	5/A		
A	2	Women's Staff Restroom across from Classroom 203	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	44	LF	0					N/A	N/A	N/A		
A	2	Classroom 206	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A		
A	2	Classroom 206	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A		
A	2	Classroom 206	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A		
A	2	Classroom 206	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	200	SF	0					1	No	1/D		
A	2	Classroom 206	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	48	LF	1	LF		Open Seam		1	Yes	2/A		
A	2	Teen Courtroom next to Classroom 206	N/A	Wood Floor		Non Suspect ACM	800	SF	0					N/A	N/A	N/A		
A	2	Teen Courtroom next to Classroom 206	N/A	Carpet		Non Suspect ACM	800	SF	0					N/A	N/A	N/A		
A	2	Teen Courtroom next to Classroom 206	N/A	Plaster Walls		NAD	2400	SF	0					N/A	N/A	N/A		
A	2	Teen Courtroom next to Classroom 206	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A		
A	2	Teen Courtroom next to Classroom 206	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	200	SF	0					1	No	1/D		
A	2	Teen Courtroom next to Classroom 206	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	48	LF	2	LF		Open Seams		1	Yes	2/A		
A	2	Office next to Teen Courtroom	N/A	Wood Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	2	Office next to Teen Courtroom	N/A	Plaster Walls		NAD	1500	SF	0					N/A	N/A	N/A		
A	2	Office next to Teen Courtroom	N/A	Ceiling Tile 2' x 4'		NAD	500	SF	0					N/A	N/A	N/A		
A	2	Office next to Teen Courtroom	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	24	LF	1	LF		Open Seam		1	Yes	2/A		
A	2	Office next to Stairwell 4	N/A	Wood Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	2	Office next to Stairwell 4	N/A	Plaster Walls		NAD	1500	SF	0					N/A	N/A	N/A		
A	2	Office next to Stairwell 4	N/A	Ceiling Tile 2' x 4'		NAD	500	SF	0					N/A	N/A	N/A		
A	2	Office next to Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	12	LF	1	LF				1	Yes	2/A		
A	2	Office next to Stairwell 4	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0					N/A	N/A	N/A		
A	2	Office next to Stairwell 4	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	25	SF	0					1	No	1/D		
A	2	Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	2	Stairwell 4	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	2	Stairwell 4	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A		
A	2	Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	2	Classroom 210	N/A	Wood Floor		Non Suspect ACM	850	SF	0					N/A	N/A	N/A		
A	2	Classroom 210	N/A	Plaster Walls		NAD	2550	SF	0					N/A	N/A	N/A		
A	2	Classroom 210	N/A	Ceiling Tile 2' x 4'		NAD	850	SF	0					N/A	N/A	N/A		
A	2	Classroom 210	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	200	SF	0					1	No	1/D		
A	2	Classroom 210	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	36	LF	0					1	No	1/D		
A	2	Classroom 211	N/A	Wood Floor		Non Suspect ACM	850	SF	0					N/A	N/A	N/A		
A	2	Classroom 211	N/A	Plaster Walls		NAD	2550	SF	0					N/A	N/A	N/A		
A	2	Classroom 211	N/A	Ceiling Tile 2' x 4'		NAD	850	SF	0					N/A	N/A	N/A		
A	2	Classroom 211	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	90	SF	0					1	No	1/D		
A	2	Classroom 211	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	44	LF	4	LF		Open Seams		1	Yes	2/A		
A	2	Computer Classroom 212	N/A	Wood Floor		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A		
A	2	Computer Classroom 212	N/A	Plaster Walls		NAD	3000	SF	0					N/A	N/A	N/A		
A	2	Computer Classroom 212	N/A	Plaster Ceiling		NAD	1000	SF	0					N/A	N/A	N/A		
A	2	Computer Classroom 212	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	50	LF	0					1	No	1/D		
A	2	Computer Classroom 212	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	8	LF	0					1	No	1/D		
A	2	Classroom 213	N/A	Wood Floor		Non Suspect ACM	850	SF	0					N/A	N/A	N/A		
A	2	Classroom 213	N/A	Plaster Walls		NAD	2550	SF	0					N/A	N/A	N/A		

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)			
A	2	Classroom 213	N/A	Ceiling Tile 2' x 4'		NAD	850	SF	0					N/A	N/A	N/A			
A	2	Classroom 213	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D			
A	2	Classroom 213	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	24	LF	0					1	No	1/D			
A	2	Classroom 213	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0			All comprised of wood and cloth		N/A	N/A	N/A			
A	2	Classroom 214	N/A	Wood Floor		Non Suspect ACM	850	SF	0					N/A	N/A	N/A			
A	2	Classroom 214	N/A	Plaster Walls		NAD	2550	SF	0					N/A	N/A	N/A			
A	2	Classroom 214	N/A	Ceiling Tile 2' x 4'		NAD	850	SF	0					N/A	N/A	N/A			
A	2	Classroom 214	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	240	SF	0					1	No	1/D			
A	2	Classroom 214	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	24	LF	0					1	No	1/D			
A	2	Classroom 214	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	2	Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	2	Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A			
A	2	Stairwell 1	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A			
A	2	Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	2	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x			
A	2	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x			
A	2	Office next to Stairwell 1	N/A	Wood Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 1	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 1	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 1	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	46	LF	0					1	No	1/D			
A	2	Office next to Stairwell 1	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	10	LF	0					1	No	1/D			
A	2	Storage Room next to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	72	SF	0					N/A	N/A	N/A			
A	2	Storage Room next to Stairwell 1	N/A	Brick Wall		Non Suspect ACM	144	SF	0					N/A	N/A	N/A			
A	2	Storage Room next to Stairwell 1	N/A	Sheetrock Wall		NAD	72	SF	0					N/A	N/A	N/A			
A	2	Storage Room next to Stairwell 1	N/A	Plaster Ceiling		NAD	72	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 210-214	N/A	Concrete Floor		Non Suspect ACM	2000	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 210-214	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	400	LF	0					1	No	1/D			
A	2	Hallway outside Classrooms 210-214	N/A	Plaster Walls		NAD	6000	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 210-214	N/A	Plaster Ceiling		NAD	2000	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 210-214	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	212	LF	3	LF		Open Seams and Puncture		1	Yes	2/A			
A	2	Hallway outside Classrooms 210-214	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	46	EA	0					1	No	1/D			
A	2	Hallway outside Classrooms 219-220	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 219-220	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D			
A	2	Hallway outside Classrooms 219-220	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 219-220	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 219-220	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	37	LF	2	LF		Open Seams		1	Yes	2/A			
A	2	Hallway outside Classrooms 219-220	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	7	EA	0					1	No	1/D			
A	2	Hallway outside Classrooms 216-220	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 216-220	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D			
A	2	Hallway outside Classrooms 216-220	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 216-220	N/A	Plaster Ceiling		NAD	1250	SF	0					N/A	N/A	N/A			
A	2	Hallway outside Classrooms 216-220	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	165	LF	3	LF		Open Seams		1	Yes	2/A			
A	2	Hallway outside Classrooms 216-220	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	34	EA	0					1	No	1/D			
A	2	Office next to Stairwell 2	N/A	Wood Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 2	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 2	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0					N/A	N/A	N/A			
A	2	Office next to Stairwell 2	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	14	LF	0					1	No	1/D			
A	2	Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	2	Stairwell 2	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A			
A	2	Stairwell 2	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A			
A	2	Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	2	Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0			1st - 2nd Floor Landing		N/A	N/A	N/A			
A	2	Classroom 216	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1400	SF	0		Tan			1	No	1/D			
A	2	Classroom 216	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	200	LF	0					1	No	1/D			
A	2	Classroom 216	N/A	Brick Wall		Non Suspect ACM	2100	SF	0					N/A	N/A	N/A			
A	2	Classroom 216	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A			
A	2	Classroom 216	N/A	Ceiling Tile 2' x 4'		NAD	1400	SF	0					N/A	N/A	N/A			
A	2	Classroom 216	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	72	LF	2	LF		Open Seams		1	Yes	2/A			
A	2	Classroom 217	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	550	SF	0		Tan			1	No	1/D			
A	2	Classroom 217	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	250	SF	0		Tan			1	No	1/D			
A	2	Classroom 217	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	100	LF	0					1	No	1/D			
A	2	Classroom 217	N/A	Brick Wall		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A			
A	2	Classroom 217	N/A	Plaster Walls		NAD	1200	SF	0					N/A	N/A	N/A			
A	2	Classroom 217	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A			
A	2	Classroom 217	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	48	LF	3	LF		Open Seams		1	Yes	2/A			
A	2	Classroom 217	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	150	SF	0					1	No	1/D			
A	2	Classroom 218	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A			
A	2	Classroom 218	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A			
A	2	Classroom 218	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A			
A	2	Classroom 218	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	24	LF	0					1	No	1/D			
A	2	Classroom 218	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016							
												Building Inspector: Bernard J Bryson							
												Number: ACC-0125-6-031							
												Management Planner: Megan Vala							
Number: 740728																			
E l e m e n t	F l o o r	On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)		
A	2	Classroom 219	N/A	Wood Floor		Non Suspect ACM	700	SF	0						N/A	N/A	N/A		
A	2	Classroom 219	N/A	Plaster Walls		NAD	1850	SF	0						N/A	N/A	N/A		
A	2	Classroom 219	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0						N/A	N/A	N/A		
A	2	Classroom 219	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0						N/A	N/A	N/A		
A	2	Classroom 219	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	48	LF	0						1	No	1/D		
A	2	Classroom 219	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	180	SF	0						1	No	1/D		
A	2	Classroom 220	N/A	Wood Floor		Non Suspect ACM	700	SF	0						N/A	N/A	N/A		
A	2	Classroom 220	N/A	Plaster Walls		NAD	1850	SF	0						N/A	N/A	N/A		
A	2	Classroom 220	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0						N/A	N/A	N/A		
A	2	Classroom 220	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0						N/A	N/A	N/A		
A	2	Classroom 220	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	45	LF	4	LF			Open Ends and Failing Wettable Lag Cloth		1	Yes	2/A		
A	2	Classroom 220	M	Blackboard Glue Dots	7010/01/02/SYN/BB/2600	Assumed	180	SF	0						1	No	1/D		
A	2	Hallway from A Building to D Building Addition	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	240	SF	0			Tan			1	No	1/D		
A	2	Hallway from A Building to D Building Addition	N/A	Concrete Block Wall		Non Suspect ACM	720	SF	0						N/A	N/A	N/A		
A	2	Hallway from A Building to D Building Addition	N/A	Ceiling Tile 2' x 4'		NAD	240	SF	0						N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 217	N/A	Concrete Floor		Non Suspect ACM	12	SF	0						N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 217	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	10	LF	0						1	No	1/D		
A	2	Custodial Closet across from Classroom 217	N/A	Plaster Walls		NAD	80	SF	0						N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 217	N/A	Plaster Ceiling		NAD	12	SF	0						N/A	N/A	N/A		
A	2	Custodial Closet across from Classroom 217	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	85	LF	0						1	No	1/D		
A	2	Custodial Closet across from Classroom 217	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	5	EA	0						1	No	1/D		
A	2	Custodial Closet across from Classroom 217	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	14	LF	0						N/A	N/A	N/A		
A	2	Men's Staff Restroom across from Classroom 213	N/A	Ceramic Tile Floors		Non Suspect ACM	80	SF	0						N/A	N/A	N/A		
A	2	Men's Staff Restroom across from Classroom 213	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	36	LF	0						1	No	1/D		
A	2	Men's Staff Restroom across from Classroom 213	N/A	Plaster Walls		NAD	240	SF	0						N/A	N/A	N/A		
A	2	Men's Staff Restroom across from Classroom 213	N/A	Plaster Ceiling		NAD	80	SF	0						N/A	N/A	N/A		
A	2	Men's Staff Restroom across from Classroom 213	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	40	LF	0						1	No	1/D		
A	2	Men's Staff Restroom across from Classroom 213	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	23	EA	0						1	No	1/D		
A	2	Men's Staff Restroom across from Classroom 213	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	47	LF	0						N/A	N/A	N/A		
A	2	Men's Student Restroom across from Classroom 216	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0						N/A	N/A	N/A		
A	2	Men's Student Restroom across from Classroom 216	M	Transite Cove Base	7010/01/02/SYN/BB/2320	Assumed	60	LF	0						1	No	1/D		
A	2	Men's Student Restroom across from Classroom 216	N/A	Plaster Walls		NAD	600	SF	0						N/A	N/A	N/A		
A	2	Men's Student Restroom across from Classroom 216	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0						N/A	N/A	N/A		
A	2	Men's Student Restroom across from Classroom 216	T	Pipe Insulation 2-6 inch	7010/01/02/41	Confirmed	30	LF	0						1	No	1/D		
A	2	Men's Student Restroom across from Classroom 216	T	Pipe Fitting Insulation	7010/01/02/48	Confirmed	6	EA	0						1	No	1/D		
A	2	Men's Student Restroom across from Classroom 216	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium	N/A	Wood Floor		Non Suspect ACM	4800	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium	N/A	Brick Wall		Non Suspect ACM	7200	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium	N/A	Plaster Walls		NAD	7200	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium	N/A	Plaster Ceiling		NAD	4800	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	84	LF	1	LF			Open Seam; Vertical Risers		1	Yes	2/A		
A	3	3rd Floor Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	110	LF	0				Horizontal Lines Below Metal Jacketing in Rear		1	No	1/D		
A	3	3rd Floor Gymnasium	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	15	EA	0						1	No	1/D		
A	3	3rd Floor Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	14	LF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium Front Storage Room	N/A	Concrete Floor		Non Suspect ACM	250	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium Front Storage Room	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	36	LF	0						1	No	1/D		
A	3	3rd Floor Gymnasium Front Storage Room	N/A	Brick Wall		Non Suspect ACM	375	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium Front Storage Room	N/A	Plaster Walls		NAD	375	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium Front Storage Room	N/A	Plaster Ceiling		NAD	250	SF	0						N/A	N/A	N/A		
A	3	3rd Floor Gymnasium Front Storage Room	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	2	EA	0						1	No	1/D		
A	3	3rd Floor Gymnasium Front Storage Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0						N/A	N/A	N/A		
A	3	Narrow Hallway in front of 3rd Floor Gymnasium	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	600	SF	0			Tan			1	No	1/D		
A	3	Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0						N/A	N/A	N/A		
A	3	Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Plaster Walls		NAD	900	SF	0						N/A	N/A	N/A		
A	3	Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Plaster Ceiling		NAD	600	SF	0						N/A	N/A	N/A		
A	3	Storage Closet inside Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	40	SF	0						N/A	N/A	N/A		
A	3	Storage Closet inside Narrow Hallway in front of 3rd Floor Gymnasium	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	28	LF	0						1	No	1/D		
A	3	Storage Closet inside Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Brick Wall		Non Suspect ACM	60	SF	0						N/A	N/A	N/A		
A	3	Storage Closet inside Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Plaster Walls		NAD	60	SF	0						N/A	N/A	N/A		
A	3	Storage Closet inside Narrow Hallway in front of 3rd Floor Gymnasium	N/A	Plaster Ceiling		NAD	40	SF	0						N/A	N/A	N/A		

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016		Attic Crawl Space Ranking				Damage Potential (DP)		Newly Friable (NF)		Response Action (RA)																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
												Building Inspector: Bernard J Bryson																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
												Number: ACC-0125-6-031																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
												Management Planner: Megan Vala																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
												Number: 740728																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728					
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)		
A	3	Classroom 304	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D		
A	3	Classroom 304	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	20	SF	0			Black Window Sills		1	No	1/D		
A	3	Classroom 305	M	Floor Tile VAT 12" x 12"	7010/01/03/TT	Assumed	600	SF	0		Brown			1	No	1/D		
A	3	Classroom 305	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A		
A	3	Classroom 305	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A		
A	3	Classroom 305	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	20	LF	0			Risers; Below Metal Jackets		1	No	1/D		
A	3	Classroom 305	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D		
A	3	Classroom 305	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	20	SF	0			Black Window Sills		1	No	1/D		
A	3	Hallway outside Classrooms 306 - 307	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 306 - 307	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D		
A	3	Hallway outside Classrooms 306 - 307	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 306 - 307	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 306 - 307	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0					1	No	1/D		
A	3	Hallway outside Classrooms 302 - 307	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 302 - 307	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D		
A	3	Hallway outside Classrooms 302 - 307	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 302 - 307	N/A	Plaster Ceiling		NAD	1250	SF	0					N/A	N/A	N/A		
A	3	Hallway outside Classrooms 302 - 307	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	23	LF	1	LF		Open Seam beside wheel chair lift		1	Yes	2/A		
A	3	Hallway outside Classrooms 302 - 307	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	1	EA	0					1	No	1/D		
A	3	Classroom 306	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A		
A	3	Classroom 306	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A		
A	3	Classroom 306	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A		
A	3	Classroom 306	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0					1	No	1/D		
A	3	Classroom 306	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D		
A	3	Classroom 307	N/A	Wood Floor		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A		
A	3	Classroom 307	N/A	Plaster Walls		NAD	3000	SF	0					N/A	N/A	N/A		
A	3	Classroom 307	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A		
A	3	Classroom 307	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0					1	No	1/D		
A	3	Classroom 307	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D		
A	3	Classroom 308	N/A	Wood Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	3	Classroom 308	N/A	Plaster Walls		NAD	1500	SF	0					N/A	N/A	N/A		
A	3	Classroom 308	N/A	Ceiling Tile 2' x 4'		NAD	500	SF	0					N/A	N/A	N/A		
A	3	Classroom 308	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0					1	No	1/D		
A	3	Classroom 308	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D		
A	3	Storage Room next to Classroom 308	N/A	Wood Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Classroom 308	N/A	Plaster Walls		NAD	1500	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Classroom 308	N/A	Ceiling Tile 2' x 4'		NAD	500	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Classroom 308	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0					1	No	1/D		
A	3	Storage Room next to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	72	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Stairwell 4	N/A	Brick Wall		Non Suspect ACM	144	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Stairwell 4	N/A	Sheetrock Wall		Non Suspect ACM	72	SF	0					N/A	N/A	N/A		
A	3	Storage Room next to Stairwell 4	N/A	Plaster Ceiling		NAD	72	SF	0					N/A	N/A	N/A		
A	3	Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	3	Stairwell 4	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A		
A	3	Stairwell 4	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A		
A	3	Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A		
A	3	Women's Student Restroom across from Classroom 304	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0					N/A	N/A	N/A		
A	3	Women's Student Restroom across from Classroom 304	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D		
A	3	Women's Student Restroom across from Classroom 304	N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A		
A	3	Women's Student Restroom across from Classroom 304	N/A	Plaster Ceiling		NAD	200	SF	0					N/A	N/A	N/A		
A	3	Women's Student Restroom across from Classroom 304	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	12	LF		Frayed Entire Height		1	Yes	5/A		
A	3	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x		
A	3	Women's Staff Restroom across from Classroom 303	N/A	Ceramic Tile Floors		Non Suspect ACM	80	SF	0					N/A	N/A	N/A		
A	3	Women's Staff Restroom across from Classroom 303	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	36	LF	0					1	No	1/D		
A	3	Women's Staff Restroom across from Classroom 303	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0					N/A	N/A	N/A		
A	3	Women's Staff Restroom across from Classroom 303	N/A	Plaster Walls		NAD	120	SF	0					N/A	N/A	N/A		
A	3	Women's Staff Restroom across from Classroom 303	N/A	Plaster Ceiling		NAD	80	SF	0					N/A	N/A	N/A		
A	3	Women's Staff Restroom across from Classroom 303	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	40	LF	1	LF		Damaged Lagging		1	Yes	2/A		
A	3	Women's Staff Restroom across from Classroom 303	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	8	EA	0					1	No	1/D		
A	3	Classroom 310	N/A	Wood Floor		Non Suspect ACM	800	SF	0					N/A	N/A	N/A		

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016									
																Building Inspector: Bernard J Bryson									
																					Number: ACC-0125-6-031				
																					Management Planner: Megan Vala				
					Number: 740728																				
On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)						
A	3	Classroom 310	N/A	Plaster Walls		NAD	2400	SF	0								N/A	N/A	N/A						
A	3	Classroom 310	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 310	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0								1	No	1/D						
A	3	Classroom 310	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	180	SF	0								1	No	1/D						
A	3	Classroom 311	N/A	Wood Floor		Non Suspect ACM	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 311	N/A	Plaster Walls		NAD	2400	SF	0								N/A	N/A	N/A						
A	3	Classroom 311	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 311	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0								1	No	1/D						
A	3	Classroom 311	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0								1	No	1/D						
A	3	Entrance Foyer to Teacher's Lounge next to Classroom 311	N/A	Wood Floor		Non Suspect ACM	170	SF	0								N/A	N/A	N/A						
A	3	Entrance Foyer to Teacher's Lounge next to Classroom 311	N/A	Plaster Walls		NAD	510	SF	0								N/A	N/A	N/A						
A	3	Entrance Foyer to Teacher's Lounge next to Classroom 311	N/A	Ceiling Tile 2' x 4'		NAD	170	SF	0								N/A	N/A	N/A						
A	3	Teacher's Lounge next to Classroom 311	N/A	Wood Floor		Non Suspect ACM	250	SF	0								N/A	N/A	N/A						
A	3	Teacher's Lounge next to Classroom 311	N/A	Plaster Walls		NAD	750	SF	0								N/A	N/A	N/A						
A	3	Teacher's Lounge next to Classroom 311	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0								N/A	N/A	N/A						
A	3	Teacher's Lounge next to Classroom 311	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	35	LF	0								1	No	1/D						
A	3	Teacher's Lounge next to Classroom 311	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	12	EA	3	EA				Damaged Fittings		1	Yes	2/A							
A	3	Teacher's Lounge next to Classroom 311	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	8	SF	0					Black Window Sills		1	No	1/D							
A	3	Music Classroom across from Gymnasium	N/A	Wood Floor		Non Suspect ACM	170	SF	0								N/A	N/A	N/A						
A	3	Music Classroom across from Gymnasium	N/A	Plaster Walls		NAD	510	SF	0								N/A	N/A	N/A						
A	3	Music Classroom across from Gymnasium	N/A	Ceiling Tile 2' x 4'		NAD	170	SF	0								N/A	N/A	N/A						
A	3	Music Classroom across from Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	2	LF				Open Ends		1	Yes	2/A							
A	3	Music Classroom across from Gymnasium	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	1	EA	0								1	No	1/D						
A	3	Music Classroom across from Gymnasium	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	15	SF	0					Black Window Sills		1	No	1/D							
A	3	Music Classroom across from Gymnasium	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	90	SF	0								1	No	1/D						
A	3	Entrance Foyer to Dean's Office next to Classroom 315	N/A	Wood Floor		Non Suspect ACM	170	SF	0								N/A	N/A	N/A						
A	3	Entrance Foyer to Dean's Office next to Classroom 315	N/A	Plaster Walls		NAD	510	SF	0								N/A	N/A	N/A						
A	3	Entrance Foyer to Dean's Office next to Classroom 315	N/A	Ceiling Tile 2' x 4'		NAD	170	SF	0								N/A	N/A	N/A						
A	3	Dean's Office next to Classroom 315	N/A	Wood Floor		Non Suspect ACM	250	SF	0								N/A	N/A	N/A						
A	3	Dean's Office next to Classroom 315	N/A	Plaster Walls		NAD	750	SF	0								N/A	N/A	N/A						
A	3	Dean's Office next to Classroom 315	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0								N/A	N/A	N/A						
A	3	Dean's Office next to Classroom 315	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0								1	No	1/D						
A	3	Dean's Office next to Classroom 315	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	8	SF	0					Black Window Sills		1	No	1/D							
A	3	Classroom 315	N/A	Wood Floor		Non Suspect ACM	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 315	N/A	Plaster Walls		NAD	2400	SF	0								N/A	N/A	N/A						
A	3	Classroom 315	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 315	T	Pipe Insulation > 6 inch	7010/01/03/SYN/BB/1110	Assumed	12	LF	0								1	No	1/D						
A	3	Classroom 315	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0								1	No	1/D						
A	3	Classroom 316	N/A	Wood Floor		Non Suspect ACM	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 316	N/A	Plaster Walls		NAD	2400	SF	0								N/A	N/A	N/A						
A	3	Classroom 316	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0								N/A	N/A	N/A						
A	3	Classroom 316	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	2	LF				Puncture and Duct Tape Patch		1	Yes	2/A							
A	3	Classroom 316	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0								1	No	1/D						
A	3	Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	300	SF	0								N/A	N/A	N/A						
A	3	Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0								N/A	N/A	N/A						
A	3	Stairwell 1	N/A	Plaster Walls		NAD	500	SF	0								N/A	N/A	N/A						
A	3	Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0								N/A	N/A	N/A						
A	3	Storage Room across from Classroom 323	x	x		x	x	x	x	x	x	x	x	No Access		x	x	x	x						
A	3	x	x	x		x	x	x	x	x	x	x	x	Need on site room name		x	x	x	x						
A	3	Custodial Closet next to Stairwell 1	N/A	Metal Floor		Non Suspect ACM	16	SF	0								N/A	N/A	N/A						
A	3	Custodial Closet next to Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0								N/A	N/A	N/A						
A	3	Custodial Closet next to Stairwell 1	N/A	Metal Ceiling		Non Suspect ACM	16	SF	0								N/A	N/A	N/A						
A	3	Storage Room next to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	72	SF	0								N/A	N/A	N/A						
A	3	Storage Room next to Stairwell 1	N/A	Brick Wall		Non Suspect ACM	144	SF	0								N/A	N/A	N/A						
A	3	Storage Room next to Stairwell 1	N/A	Sheetrock Wall		Non Suspect ACM	72	SF	0								N/A	N/A	N/A						
A	3	Storage Room next to Stairwell 1	N/A	Plaster Ceiling		NAD	72	SF	0								N/A	N/A	N/A						
A	3	Hallway outside Classrooms 310 - 316	N/A	Concrete Floor		Non Suspect ACM	2000	SF	0								N/A	N/A	N/A						
A	3	Hallway outside Classrooms 310 - 316	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	400	LF	0								1	No	1/D						
A	3	Hallway outside Classrooms 310 - 316	N/A	Plaster Walls		NAD	6000	SF	0								N/A	N/A	N/A						
A	3	Hallway outside Classrooms 310 - 316	N/A	Plaster Ceiling		NAD	2000	SF	0								N/A	N/A	N/A						
A	3	Hallway outside Classrooms 310 - 316	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	217	LF	0								1	No	1/D						
A	3	Hallway outside Classrooms 310 - 316	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	48	EA	0								1	No	1/D						
A	3	Hallway outside Classrooms 310 - 316	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	25	SF	0								1	No	1/D						
A	3	Men's Staff Restroom across from Classroom 315	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0								N/A	N/A	N/A						
A	3	Men's Staff Restroom across from Classroom 315	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	60	LF	0								1	No	1/D						

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)			
A	3	Men's Staff Restroom across from Classroom 315	N/A	Brick Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	3	Men's Staff Restroom across from Classroom 315	N/A	Plaster Walls		NAD	300	SF	0					N/A	N/A	N/A			
A	3	Men's Staff Restroom across from Classroom 315	N/A	Plaster Ceiling		NAD	200	SF	0					N/A	N/A	N/A			
A	3	Men's Staff Restroom across from Classroom 315	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	30	LF	0					1	No	1/D			
A	3	Men's Staff Restroom across from Classroom 315	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	2	EA	0					1	No	1/D			
A	3	Men's Staff Restroom across from Classroom 315	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0			beneath sink		N/A	N/A	N/A			
A	3	Men's Staff Restroom across from Classroom 315	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	7	EA	0			beneath sink		N/A	N/A	N/A			
A	3	Hallway outside Classrooms 322 - 323	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 322 - 323	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D			
A	3	Hallway outside Classrooms 322 - 323	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 322 - 323	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 322 - 323	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0					1	No	1/D			
A	3	Hallway outside Classrooms 318 - 323	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 318 - 323	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D			
A	3	Hallway outside Classrooms 318 - 323	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 318 - 323	N/A	Plaster Ceiling		NAD	1250	SF	0					N/A	N/A	N/A			
A	3	Hallway outside Classrooms 318 - 323	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	64	LF	0					1	No	1/D			
A	3	Hallway outside Classrooms 318 - 323	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	10	EA	0					1	No	1/D			
A	3	Hallway outside Classrooms 318 - 323	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	5	LF	0					N/A	N/A	N/A			
A	3	Classroom 322	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A			
A	3	Classroom 322	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A			
A	3	Classroom 322	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A			
A	3	Classroom 322	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0					1	No	1/D			
A	3	Classroom 322	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D			
A	3	Classroom 323	N/A	Wood Floor		Non Suspect ACM	700	SF	0					N/A	N/A	N/A			
A	3	Classroom 323	N/A	Plaster Walls		NAD	2100	SF	0					N/A	N/A	N/A			
A	3	Classroom 323	N/A	Ceiling Tile 2' x 4'		NAD	700	SF	0					N/A	N/A	N/A			
A	3	Classroom 323	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	0					1	No	1/D			
A	3	Classroom 323	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D			
A	3	Classroom 321	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A			
A	3	Classroom 321	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A			
A	3	Classroom 321	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A			
A	3	Classroom 321	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0					1	No	1/D			
A	3	Classroom 321	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D			
A	3	Classroom 320	N/A	Wood Floor		Non Suspect ACM	800	SF	0					N/A	N/A	N/A			
A	3	Classroom 320	N/A	Plaster Walls		NAD	2400	SF	0					N/A	N/A	N/A			
A	3	Classroom 320	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0			All comprised of wood and cloth		N/A	N/A	N/A			
A	3	Classroom 320	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A			
A	3	Classroom 320	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	2	LF		Puncture and Broken Metal Band		1	Yes	2/A			
A	3	Classroom 320	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D			
A	3	Classroom 319	N/A	Wood Floor		Non Suspect ACM	800	SF	0					N/A	N/A	N/A			
A	3	Classroom 319	N/A	Plaster Walls		NAD	2400	SF	0					N/A	N/A	N/A			
A	3	Classroom 319	N/A	Folding Partition Wall		Non Suspect ACM	250	SF	0			All comprised of wood and cloth		N/A	N/A	N/A			
A	3	Classroom 319	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A			
A	3	Classroom 319	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	24	LF	1	LF		Open Seam		1	Yes	2/A			
A	3	Classroom 319	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	180	SF	0					1	No	1/D			
A	3	Classroom 318	N/A	Wood Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A			
A	3	Classroom 318	N/A	Plaster Walls		NAD	1800	SF	0					N/A	N/A	N/A			
A	3	Classroom 318	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A			
A	3	Classroom 318	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	12	LF	0					1	No	1/D			
A	3	Classroom 318	M	Blackboard Glue Dots	7010/01/03/SYN/BB/2600	Assumed	220	SF	0					1	No	1/D			
A	3	Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	3	Stairwell 2	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A			
A	3	Stairwell 2	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A			
A	3	Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	3	Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	5	LF	0					N/A	N/A	N/A			
A	3	Office next to Stairwell 2	M	Linoleum	7010/01/03/CC	Assumed	150	SF	0		Brown	2nd - 3rd Floor Landing - Labeled Steam Old Burlap Backing Type		1	No	1/D			
A	3	Office next to Stairwell 2	N/A	Plaster Walls		NAD	450	SF	0					N/A	N/A	N/A			
A	3	Office next to Stairwell 2	N/A	Ceiling Tile 2' x 4'		NAD	150	SF	0					N/A	N/A	N/A			
A	3	Office next to Stairwell 2	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	6	LF	0					1	No	1/D			
A	3	Office next to Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	2	LF	0					N/A	N/A	N/A			
A	3	Office next to Stairwell 2	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	3	EA	0					N/A	N/A	N/A			
A	3	Men's Student Restroom across from Classroom 320	N/A	Ceramic Tile Floors		Non Suspect ACM	200	SF	0					N/A	N/A	N/A			
A	3	Men's Student Restroom across from Classroom 320	M	Transite Cove Base	7010/01/03/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D			
A	3	Men's Student Restroom across from Classroom 320	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A			
A	3	Men's Student Restroom across from Classroom 320	N/A	Plaster Ceiling		NAD	200	SF	0					N/A	N/A	N/A			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)			
A	3	Men's Student Restroom across from Classroom 320	T	Pipe Insulation 2-6 inch	7010/01/03/54	Confirmed	15	LF	0					1	No	1/D			
A	3	Men's Student Restroom across from Classroom 320	T	Pipe Fitting Insulation	7010/01/03/60	Confirmed	4	EA	0					1	No	1/D			
A	4	Classroom 400	N/A	Wood Floor		Non Suspect ACM	600	SF	0				Active Steam Leak - No ACM affected at this time - There is an Attic above this Room; Entrance to Attic is unknown	N/A	N/A	N/A			
A	4	Classroom 400	M	Linoleum	7010/01/04/FF	Assumed	1000	SF	0		Brown	Old Burlap Backing Type		1	No	1/D			
A	4	Classroom 400	N/A	Plaster Walls		NAD	4800	SF	0					N/A	N/A	N/A			
A	4	Classroom 400	N/A	Wood Panel Walls		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A			
A	4	Classroom 400	N/A	Plaster Ceiling		NAD	1600	SF	0					N/A	N/A	N/A			
A	4	Classroom 400	N/A	Ceiling Tile 1' x 1'		Non Suspect ACM	4000	SF	0			1' x 1' Fiberglass Tiles Glued to Upper Walls and Ceiling		N/A	N/A	N/A			
A	4	Classroom 400	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	6	LF	0					1	No	1/D			
A	4	Classroom 400	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	3	LF	2					N/A	N/A	N/A			
A	4	Classroom 400	M	Transite Sills	7010/01/04/SYN/BB/2300	Assumed	16	SF	0			Black Window Sills		1	No	1/D			
A	4	South Spiral Staircase in Classroom 400	N/A	Wood Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A			
A	4	South Spiral Staircase in Classroom 400	N/A	Plaster Walls		NAD	210	SF	0					N/A	N/A	N/A			
A	4	South Spiral Staircase in Classroom 400	N/A	Plaster Ceiling		NAD	70	SF	0					N/A	N/A	N/A			
A	4	South Spiral Staircase in Classroom 400	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	14	LF	0					1	No	1/D			
A	4	South Spiral Staircase in Classroom 400	M	Transite Sills	7010/01/04/SYN/BB/2300	Assumed	6	SF	0			Black Window Sills		1	No	1/D			
A	4	North Spiral Staircase in Classroom 400	N/A	Wood Floor		Non Suspect ACM	70	SF	0					N/A	N/A	N/A			
A	4	North Spiral Staircase in Classroom 400	N/A	Plaster Walls		NAD	210	SF	0					N/A	N/A	N/A			
A	4	North Spiral Staircase in Classroom 400	N/A	Plaster Ceiling		NAD	70	SF	0					N/A	N/A	N/A			
A	4	North Spiral Staircase in Classroom 400	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	25	LF	2	LF		Open Ends		1	Yes	2/A			
A	4	North Spiral Staircase in Classroom 400	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	2	EA	1	EA		Open End		1	Yes	2/A			
A	4	North Spiral Staircase in Classroom 400	M	Transite Sills	7010/01/04/SYN/BB/2300	Assumed	6	SF	0			Black Window Sills		1	No	1/D			
A	4	Storage Room in Classroom 400	N/A	Wood Floor		Non Suspect ACM	100	SF	0					N/A	N/A	N/A			
A	4	Storage Room in Classroom 400	N/A	Plaster Walls		NAD	300	SF	0					N/A	N/A	N/A			
A	4	Storage Room in Classroom 400	N/A	Plaster Ceiling		NAD	100	SF	0					N/A	N/A	N/A			
A	4	North Hallway from Classroom 400 to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A			
A	4	North Hallway from Classroom 400 to Stairwell 4	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	200	LF	0					1	No	1/D			
A	4	North Hallway from Classroom 400 to Stairwell 4	N/A	Plaster Walls		NAD	3000	SF	0					N/A	N/A	N/A			
A	4	North Hallway from Classroom 400 to Stairwell 4	N/A	Plaster Ceiling		NAD	1000	SF	0					N/A	N/A	N/A			
A	4	North Hallway from Classroom 400 to Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	45	LF	0					1	No	1/D			
A	4	North Hallway from Classroom 400 to Stairwell 4	T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	100	LF	8	EA		Open Hangers		1	Yes	2/A			
A	4	North Hallway from Classroom 400 to Stairwell 4	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	35	EA	0					1	No	1/D			
A	4	North Hallway from Classroom 400 to Stairwell 4	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	5	LF	0					N/A	N/A	N/A			
A	4	Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	4	Stairwell 4	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A			
A	4	Stairwell 4	N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A			
A	4	Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room across from Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room across from Stairwell 4	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	50	LF	0					1	No	1/D			
A	4	North End Storage Room across from Stairwell 4	N/A	Plaster Walls		NAD	450	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room across from Stairwell 4	N/A	Plaster Ceiling		NAD	150	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room across from Stairwell 4	T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	6	LF	0					1	No	1/D			
A	4	North End Storage Room across from Stairwell 4	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	2	EA	0					1	No	1/D			
A	4	North End Office next to Stairwell 4	N/A	Wood Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
A	4	North End Office next to Stairwell 4	N/A	Plaster Walls		NAD	750	SF	0					N/A	N/A	N/A			
A	4	North End Office next to Stairwell 4	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A			
A	4	North End Office next to Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	25	LF	1	LF		Open Seam		1	Yes	2/A			
A	4	North End Office next to Stairwell 4	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	3	EA	0					1	No	1/D			
A	4	North End Storage Room next to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	72	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room next to Stairwell 4	N/A	Plaster Walls		NAD	216	SF	0					N/A	N/A	N/A			
A	4	North End Storage Room next to Stairwell 4	N/A	Plaster Ceiling		NAD	72	SF	0					N/A	N/A	N/A			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Ceiling Tile 2' x 4'		NAD	1250	SF	0					N/A	N/A	N/A			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	108	LF	5	EA		Open Hangers		1	Yes	2/A			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	6	LF	0					1	No	1/D			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	15	EA	0					1	No	1/D			
A	4	Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0			Below Metal Jacketing		N/A	N/A	N/A			
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A			
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	38	LF	6	EA		Open Ends		1	Yes	2/C			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report						Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728							
E l e m e n t	F l o o r	On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	15	EA	1	EA				1	Yes	2/C
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4		N/A	Horse Hair Pipe Insulation		Non Suspect ACM	3	LF	0					N/A	N/A	N/A
A	4	Tank Room in Northwest Hallway from Stairwell 3 to Stairwell 4		M	Vibration Damper Cloth	7010/01/04/SYN/BB/2601	Assumed	6	SF	0					1	No	1/D
A	4	Fan Room in Northwest Hallway from Stairwell 3 to Stairwell 4		N/A	Concrete Floor		Non Suspect ACM	120	SF	0			Limited Access		N/A	N/A	N/A
A	4	Fan Room in Northwest Hallway from Stairwell 3 to Stairwell 4		S	Acoustical Plaster Walls	7010/01/04/SYN/BB/1903	Assumed	360	SF	0			These Plaster Walls are Textured and Appear Different than all other Plaster Walls throughout the Building		1	No	1/D
A	4	Fan Room in Northwest Hallway from Stairwell 3 to Stairwell 4		N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
A	4	Stairwell 3		N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Stairwell 3		N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	4	Stairwell 3		N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	4	Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Office next to Stairwell 3		M	Linoleum	7010/01/04/FF	Assumed	200	SF	0		Brown	Old Burlap Backing Type		1	No	1/D
A	4	Office next to Stairwell 3		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D
A	4	Office next to Stairwell 3		N/A	Plaster Walls		NAD	600	SF	0					N/A	N/A	N/A
A	4	Office next to Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
A	4	Office next to Stairwell 3		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	15	LF	0					1	No	1/D
A	4	Office next to Stairwell 3		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	3	EA	0					1	No	1/D
A	4	Office next to Stairwell 3		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 3		N/A	Concrete Floor		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 3		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	16	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 3		N/A	Plaster Walls		NAD	150	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 3		N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 3		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	12	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 3		T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	5	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 3		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	5	EA	2	EA		Damaged Fittings		1	Yes	2/A
A	4	West Hallway from Stairwell 2 to Stairwell 3		M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	600	SF	0		Tan			1	No	1/D
A	4	West Hallway from Stairwell 2 to Stairwell 3		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	16	LF	0					1	No	1/D
A	4	West Hallway from Stairwell 2 to Stairwell 3		N/A	Plaster Walls		NAD	150	SF	0					N/A	N/A	N/A
A	4	West Hallway from Stairwell 2 to Stairwell 3		N/A	Plaster Ceiling		NAD	50	SF	0					N/A	N/A	N/A
A	4	West Hallway from Stairwell 2 to Stairwell 3		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	2	LF	0					1	No	1/D
A	4	West Hallway from Stairwell 2 to Stairwell 3		T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	2	LF	0					1	No	1/D
A	4	West Hallway from Stairwell 2 to Stairwell 3		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	3	EA	1	EA		Damaged Fitting		1	Yes	2/A
A	4	Former Kitchen between Stairwells 2 and 3		M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	900	SF	0		Tan			1	No	1/D
A	4	Former Kitchen between Stairwells 2 and 3		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	150	LF	0					1	No	1/D
A	4	Former Kitchen between Stairwells 2 and 3		N/A	Plaster Walls		NAD	2700	SF	0					N/A	N/A	N/A
A	4	Former Kitchen between Stairwells 2 and 3		N/A	Plaster Ceiling		NAD	900	SF	0					N/A	N/A	N/A
A	4	Former Kitchen between Stairwells 2 and 3		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	20	LF	1	LF				1	Yes	2/A
A	4	Foyer to West Hallway next to Stairwell 2		N/A	Concrete Floor		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 2		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	16	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 2		N/A	Plaster Walls		NAD	150	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 2		N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
A	4	Foyer to West Hallway next to Stairwell 2		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	6	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 2		T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	6	LF	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 2		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	1	EA	0					1	No	1/D
A	4	Foyer to West Hallway next to Stairwell 2		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0					N/A	N/A	N/A
A	4	x		x	x		x	x	x	x	x	x	Need on site room name		x	x	x
A	4	Stairwell 2		N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Stairwell 2		N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
A	4	Stairwell 2		N/A	Plaster Walls		NAD	500	SF	0					N/A	N/A	N/A
A	4	Stairwell 2		N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Concrete Floor		Non Suspect ACM	1250	SF	0					N/A	N/A	N/A
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	250	LF	0					1	No	1/D
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Plaster Walls		NAD	3750	SF	0					N/A	N/A	N/A
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Ceiling Tile 2' x 4'		NAD	1250	SF	0					N/A	N/A	N/A
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	100	LF	3	EA		Open Hangers		1	Yes	2/A
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	10	LF	0					1	No	1/D
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	20	EA	0					1	No	1/D
A	4	Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	120	LF	0			100 LF Below Metal Jacketing		N/A	N/A	N/A
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Concrete Floor		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Plaster Walls		NAD	900	SF	0					N/A	N/A	N/A
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2		N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2		T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	33	LF	2	EA		Open Ends		1	Yes	2/C

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016									
																Building Inspector: Bernard J Bryson									
																					Number: ACC-0125-6-031				
																					Management Planner: Megan Vala				
					Number: 740728																				
On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)						
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	10		EA	4		EA			Damaged Fittings		1	Yes	2/C						
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Horse Hair Pipe Insulation		Non Suspect ACM	6		LF	6		LF			On Ground		N/A	N/A	N/A						
A	4	Tank Room in Southwest Hallway from Stairwell 1 to Stairwell 2	M	Vibration Damper Cloth	7010/01/04/SYN/BB/2601	Assumed	6		SF	0							1	No	1/D						
A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	120		SF	0					Limited Access		N/A	N/A	N/A						
A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	S	Acoustical Plaster Walls	7010/01/04/SYN/BB/1903	Assumed	360		SF	0					These Plaster Walls are Textured and Appear Different than all other Plaster Walls throughout the Building		1	No	1/D						
A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	120		SF	0							N/A	N/A	N/A						
A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	3		LF	3		LF			Air-Cell Lying in Corner		2	Yes	5/A						
A	4	Fan Room in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Horse Hair Pipe Insulation		Non Suspect ACM	15		LF	0							N/A	N/A	N/A						
A	4	Storage Closet next to Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	12		SF	0							N/A	N/A	N/A						
A	4	Storage Closet next to Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Plaster Walls		NAD	60		SF	0							N/A	N/A	N/A						
A	4	Storage Closet next to Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	12		SF	0							N/A	N/A	N/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Floor		Non Suspect ACM	500		SF	0							N/A	N/A	N/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Plaster Walls		NAD	1200		SF	0							N/A	N/A	N/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Sheetrock Wall		Non Suspect ACM	300		SF	0							N/A	N/A	N/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Concrete Ceiling		Non Suspect ACM	500		SF	0							N/A	N/A	N/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	14		LF	1		EA			Open End		1	Yes	2/A						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	3		EA	0							1	No	1/D						
A	4	Office in Southwest Hallway from Stairwell 1 to Stairwell 2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	4		LF	0							N/A	N/A	N/A						
A	4	Office next to Stairwell 1	N/A	Wood Floor		Non Suspect ACM	450		SF	0							N/A	N/A	N/A						
A	4	Office next to Stairwell 1	N/A	Plaster Walls		NAD	1350		SF	0							N/A	N/A	N/A						
A	4	Office next to Stairwell 1	N/A	Ceiling Tile 2' x 4'		NAD	450		SF	0							N/A	N/A	N/A						
A	4	Office next to Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	450		SF	0							N/A	N/A	N/A						
A	4	Office next to Stairwell 1	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	22		LF	4		EA			Damaged Lagging and Puncture		1	Yes	2/A						
A	4	Office next to Stairwell 1	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	3		EA	0							1	No	1/D						
A	4	South End Storage Room next to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	72		SF	0							N/A	N/A	N/A						
A	4	South End Storage Room next to Stairwell 1	N/A	Brick Wall		Non Suspect ACM	216		SF	0							N/A	N/A	N/A						
A	4	South End Storage Room next to Stairwell 1	N/A	Plaster Ceiling		NAD	72		SF	0							N/A	N/A	N/A						
A	4	Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	300		SF	0							N/A	N/A	N/A						
A	4	Stairwell 1	N/A	Concrete Block Wall		Non Suspect ACM	500		SF	0							N/A	N/A	N/A						
A	4	Stairwell 1	N/A	Plaster Walls		NAD	500		SF	0							N/A	N/A	N/A						
A	4	Stairwell 1	N/A	Concrete Ceiling		Non Suspect ACM	300		SF	0							N/A	N/A	N/A						
A	4	South Hallway from Classroom 400 to Stairwell 1	N/A	Concrete Floor		Non Suspect ACM	1000		SF	0							N/A	N/A	N/A						
A	4	South Hallway from Classroom 400 to Stairwell 1	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	200		LF	0							1	No	1/D						
A	4	South Hallway from Classroom 400 to Stairwell 1	N/A	Plaster Walls		NAD	3000		SF	0							N/A	N/A	N/A						
A	4	South Hallway from Classroom 400 to Stairwell 1	N/A	Plaster Ceiling		NAD	1000		SF	0							N/A	N/A	N/A						
A	4	South Hallway from Classroom 400 to Stairwell 1	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	45		LF	0							1	No	1/D						
A	4	South Hallway from Classroom 400 to Stairwell 1	T	Pipe Insulation > 6 inch	7010/01/04/65	Confirmed	100		LF	8		EA			Open Hangers		1	Yes	2/A						
A	4	South Hallway from Classroom 400 to Stairwell 1	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	30		EA	1		EA			Damaged Fitting		1	Yes	2/A						
A	4	Stairwell in South Hallway to Weight Room and Rooftop	N/A	Concrete Floor		Non Suspect ACM	100		SF	0							N/A	N/A	N/A						
A	4	Stairwell in South Hallway to Weight Room and Rooftop	N/A	Brick Wall		Non Suspect ACM	300		SF	0							N/A	N/A	N/A						
A	4	Stairwell in South Hallway to Weight Room and Rooftop	N/A	Plaster Ceiling		NAD	100		SF	0							N/A	N/A	N/A						
A	4	Stairwell in South Hallway to Weight Room and Rooftop	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	7		LF	1		EA			Open Seam		1	Yes	2/A						
A	4	Stairwell in South Hallway to Weight Room and Rooftop	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	2		EA	0							1	No	1/D						
A	4	Larger Weight Room above 3rd Floor Gym	M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	600		SF	0			Tan				1	No	1/D						
A	4	Larger Weight Room above 3rd Floor Gym	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	100		LF	0							1	No	1/D						
A	4	Larger Weight Room above 3rd Floor Gym	N/A	Brick Wall		Non Suspect ACM	900		SF	0							N/A	N/A	N/A						
A	4	Larger Weight Room above 3rd Floor Gym	N/A	Plaster Walls		NAD	900		SF	0							N/A	N/A	N/A						
A	4	Larger Weight Room above 3rd Floor Gym	N/A	Plaster Ceiling		NAD	600		SF	0							N/A	N/A	N/A						
A	4	Larger Weight Room above 3rd Floor Gym	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	6		LF	3		EA			Open End and Damaged Lagging		1	Yes	2/A						
A	4	Larger Weight Room above 3rd Floor Gym	M	Blackboard Glue Dots	7010/01/04/SYN/BB/2600	Assumed	120		SF	0							1	No	1/D						

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914	AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728							
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
A	4	Storage Closet inside Larger Weight Room	M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	25	SF	0					1	No	1/D				
A	4	Storage Closet inside Larger Weight Room	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	16	LF	0					1	No	1/D				
A	4	Storage Closet inside Larger Weight Room	N/A	Brick Wall		Non Suspect ACM	50	SF	0					N/A	N/A	N/A				
A	4	Storage Closet inside Larger Weight Room	N/A	Plaster Walls		NAD	50	SF	0					N/A	N/A	N/A				
A	4	Storage Closet inside Larger Weight Room	N/A	Plaster Ceiling		NAD	25	SF	0					N/A	N/A	N/A				
A	4	Smaller Weight Room above 3rd Floor Gym	M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	450	SF	0		Tan			1	No	1/D				
A	4	Smaller Weight Room above 3rd Floor Gym	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	60	LF	0					1	No	1/D				
A	4	Smaller Weight Room above 3rd Floor Gym	N/A	Brick Wall		Non Suspect ACM	675	SF	0					N/A	N/A	N/A				
A	4	Smaller Weight Room above 3rd Floor Gym	N/A	Plaster Walls		NAD	675	SF	0					N/A	N/A	N/A				
A	4	Smaller Weight Room above 3rd Floor Gym	N/A	Plaster Ceiling		NAD	450	SF	0					N/A	N/A	N/A				
A	4	Smaller Weight Room above 3rd Floor Gym	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	1	LF	0			< 1 LF at Floor - DDC for Removal		1	No	1/D				
A	4	Storage Closet inside Smaller Weight Room	M	Floor Tile VAT 9" x 9"	7010/01/04/68	Confirmed	25	SF	0		Tan			1	No	1/D				
A	4	Storage Closet inside Smaller Weight Room	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	16	LF	0					1	No	1/D				
A	4	Storage Closet inside Smaller Weight Room	N/A	Brick Wall		Non Suspect ACM	50	SF	0					N/A	N/A	N/A				
A	4	Storage Closet inside Smaller Weight Room	N/A	Plaster Walls		NAD	50	SF	0					N/A	N/A	N/A				
A	4	Storage Closet inside Smaller Weight Room	N/A	Plaster Ceiling		NAD	25	SF	0					N/A	N/A	N/A				
A	4	Stairwell from Smaller Weight Room to 3rd Floor Gym	N/A	Concrete Floor		Non Suspect ACM	60	SF	0					N/A	N/A	N/A				
A	4	Stairwell from Smaller Weight Room to 3rd Floor Gym	M	Transite Cove Base	7010/01/04/SYN/BB/2320	Assumed	30	LF	0					1	No	1/D				
A	4	Stairwell from Smaller Weight Room to 3rd Floor Gym	N/A	Brick Wall		Non Suspect ACM	180	SF	0					N/A	N/A	N/A				
A	4	Stairwell from Smaller Weight Room to 3rd Floor Gym	N/A	Plaster Ceiling		NAD	60	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	N/A	Wood Floor		Non Suspect ACM	13500	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	40500	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	N/A	Folding Partition Wall		Non Suspect ACM	1	EA	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	13500	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	32	LF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium	T	Radiator Insulation	7010/01/08/SYN/BB/1600	Assumed	350	SF	0			14 Recessed Radiators - 25 SF Each		1	No	1/D				
B	BS	Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Terrazzo Floor		Non Suspect ACM	120	SF	0					N/A	N/A	N/A				
B	BS	Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Brick Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A				
B	BS	Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0					N/A	N/A	N/A				
B	BS	Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	2	LF	0					N/A	N/A	N/A				
B	BS	Storage Closet in Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	60	SF	0					N/A	N/A	N/A				
B	BS	Storage Closet in Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	180	SF	0					N/A	N/A	N/A				
B	BS	Storage Closet in Exterior Entrance Foyer to 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	60	SF	0					N/A	N/A	N/A				
B	BS	Storage Closet in Exterior Entrance Foyer to 1st Floor Gymnasium	M	Transite Sills	7010/01/08/SYN/BB/2300	Assumed	2	SF	0			Black Window Sills		1	No	1/D				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	N/A	Concrete Floor		Non Suspect ACM	100	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	M	Transite Sills	7010/01/08/SYN/BB/2300	Assumed	2	SF	0			Black Window Sills		1	No	1/D				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	50	LF	0					1	No	1/D				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	10	EA	0					1	No	1/D				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Storage Closet next to Exterior Entrance Foyer	T	Radiator Insulation	7010/01/08/SYN/BB/1600	Assumed	20	SF	0			1 Recessed Radiator - 20 SF		1	No	1/D				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	M	Transite Sills	7010/01/08/SYN/BB/2300	Assumed	3	SF	0			Black Window Sills		1	No	1/D				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	T	Pipe Insulation 2-6 inch	7010/01/08/01	Confirmed	30	LF	0					1	No	1/D				
B	BS	1st Floor Gymnasium Office next to Exterior Entrance Foyer	T	Pipe Fitting Insulation	7010/01/08/03	Confirmed	4	EA	0					1	No	1/D				
B	BS	1st Floor Gymnasium Office next to Women's Locker Room	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A				

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914				AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report							Reinspection Date: March 21-25, 2016				
															Building Inspector: Bernard J Bryson				
															Number: ACC-0125-6-031				
															Management Planner: Megan Vala				
															Number: 740728				

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016								
												Building Inspector: Bernard J Bryson								
												Number: ACC-0125-6-031								
												Management Planner: Megan Vala								
												Number: 740728								
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
B	BS	Weight Room next to 1st Floor Gymnasium	M	Transite Stalls	7010/01/0B/04	Confirmed	150	SF			0							1	No	1/D
B	BS	Weight Room next to 1st Floor Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	114	LF			0							1	No	1/D
B	BS	Weight Room next to 1st Floor Gymnasium	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	14	EA			0							1	No	1/D
B	BS	Weight Room next to 1st Floor Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	200	LF			0							N/A	N/A	N/A
B	BS	Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	120	SF			0							N/A	N/A	N/A
B	BS	Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	360	SF			0							N/A	N/A	N/A
B	BS	Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	120	SF			0							N/A	N/A	N/A
B	BS	Storage Room between Weight Room and 1st Floor Gymnasium	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	25	LF			0							1	No	1/D
B	BS	Storage Room between Weight Room and 1st Floor Gymnasium	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	12	EA			0							1	No	1/D
B	BS	Stairwell inside Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	40	SF			0							N/A	N/A	N/A
B	BS	Stairwell inside Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	120	SF			0							N/A	N/A	N/A
B	BS	Stairwell inside Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	40	SF			0							N/A	N/A	N/A
B	BS	Sump Pump Room below Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	120	SF			0							N/A	N/A	N/A
B	BS	Sump Pump Room below Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	360	SF			0							N/A	N/A	N/A
B	BS	Sump Pump Room below Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	120	SF			0							N/A	N/A	N/A
B	BS	Sump Pump Room below Storage Room between Weight Room and 1st Floor Gymnasium	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF			0							N/A	N/A	N/A
B	BS	Hallway from 1st Floor Gymnasium to Men's Locker Room	N/A	Concrete Floor		Non Suspect ACM	60	SF			0							N/A	N/A	N/A
B	BS	Hallway from 1st Floor Gymnasium to Men's Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	180	SF			0							N/A	N/A	N/A
B	BS	Hallway from 1st Floor Gymnasium to Men's Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	60	SF			0							N/A	N/A	N/A
B	BS	Hallway from 1st Floor Gymnasium to Men's Locker Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	26	LF			0							1	No	1/D
B	BS	Hallway from 1st Floor Gymnasium to Men's Locker Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	8	EA			0							1	No	1/D
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	N/A	Concrete Floor		Non Suspect ACM	150	SF			0							N/A	N/A	N/A
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	N/A	Concrete Block Wall		Non Suspect ACM	450	SF			0							N/A	N/A	N/A
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	N/A	Concrete Ceiling		Non Suspect ACM	150	SF			0							N/A	N/A	N/A
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	2	SF			0				Black Window Sills			1	No	1/D
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	11	LF			0							N/A	N/A	N/A
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	5	EA			0							1	No	1/D
B	BS	Corner Office between 1st Floor Gymnasium and Men's Student Restroom	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	12	SF			0							1	No	1/D
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	N/A	Concrete Floor		Non Suspect ACM	150	SF			0							N/A	N/A	N/A
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	N/A	Concrete Block Wall		Non Suspect ACM	450	SF			0							N/A	N/A	N/A
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	N/A	Concrete Ceiling		Non Suspect ACM	150	SF			0							N/A	N/A	N/A
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	5	SF			0				Black Window Sills			1	No	1/D
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	16	LF			0							1	No	1/D
B	BS	Office between 1st Floor Gymnasium and Men's Staff Restroom	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	2	EA			0							1	No	1/D
B	BS	Men's Staff Restroom in Hallway outside Men's Locker Room and 1st Floor Gymnasium	N/A	Concrete Floor		Non Suspect ACM	65	SF			0							N/A	N/A	N/A
B	BS	Men's Staff Restroom in Hallway outside Men's Locker Room and 1st Floor Gymnasium	N/A	Concrete Block Wall		Non Suspect ACM	195	SF			0							N/A	N/A	N/A
B	BS	Men's Staff Restroom in Hallway outside Men's Locker Room and 1st Floor Gymnasium	N/A	Concrete Ceiling		Non Suspect ACM	65	SF			0							N/A	N/A	N/A
B	BS	Men's Staff Restroom in Hallway outside Men's Locker Room and 1st Floor Gymnasium	M	Transite Stalls	7010/01/0B/04	Confirmed	16	SF			0							1	No	1/D
B	BS	Student Restroom in Men's Locker Room	N/A	Concrete Floor		Non Suspect ACM	65	SF			0							N/A	N/A	N/A
B	BS	Student Restroom in Men's Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	195	SF			0							N/A	N/A	N/A
B	BS	Student Restroom in Men's Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	65	SF			0							N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
B	BS	Student Restroom in Men's Locker Room	M	Transite Stalls	7010/01/0B/04	Confirmed	60	SF	0					1	No	1/D
B	BS	Student Restroom in Men's Locker Room	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	8	SF	0			Black Window Sills		1	No	1/D
B	BS	Student Restroom in Men's Locker Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	62	LF	0					1	No	1/D
B	BS	Student Restroom in Men's Locker Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	14	EA	0					1	No	1/D
B	BS	Men's Locker Room	N/A	Concrete Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
B	BS	Men's Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
B	BS	Men's Locker Room	N/A	Sheetrock Wall		Non Suspect ACM	200	SF	0					N/A	N/A	N/A
B	BS	Men's Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
B	BS	Men's Locker Room	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	12	SF	0			Black Window Sills		1	No	1/D
B	BS	Men's Locker Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	260	LF	0					1	No	1/D
B	BS	Men's Locker Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	65	EA	0					1	No	1/D
B	BS	Men's Smaller Locker Room next to End Classroom	N/A	Concrete Floor		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
B	BS	Men's Smaller Locker Room next to End Classroom	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0					N/A	N/A	N/A
B	BS	Men's Smaller Locker Room next to End Classroom	N/A	Sheetrock Wall		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
B	BS	Men's Smaller Locker Room next to End Classroom	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0					N/A	N/A	N/A
B	BS	Men's Smaller Locker Room next to End Classroom	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	8	SF	0			Black Window Sills		1	No	1/D
B	BS	Men's Smaller Locker Room next to End Classroom	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	100	LF	0					1	No	1/D
B	BS	Men's Smaller Locker Room next to End Classroom	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	18	EA	0					1	No	1/D
B	BS	End Classroom next to Men's Smaller Locker Room	N/A	Concrete Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
B	BS	End Classroom next to Men's Smaller Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A
B	BS	End Classroom next to Men's Smaller Locker Room	N/A	Sheetrock Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
B	BS	End Classroom next to Men's Smaller Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
B	BS	End Classroom next to Men's Smaller Locker Room	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	18	SF	0			Black Window Sills		1	No	1/D
B	BS	End Classroom next to Men's Smaller Locker Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	120	LF	0					1	No	1/D
B	BS	End Classroom next to Men's Smaller Locker Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	30	EA	0					1	No	1/D
B	BS	End Classroom next to Men's Smaller Locker Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
B	BS	Men's Shower Room	N/A	Concrete Floor		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
B	BS	Men's Shower Room	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0					N/A	N/A	N/A
B	BS	Men's Shower Room	N/A	Concrete Ceiling		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
B	BS	Men's Shower Room	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	9	SF	0			Black Window Sills		1	No	1/D
B	BS	Men's Shower Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	190	LF	0					1	No	1/D
B	BS	Men's Shower Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	18	EA	0					1	No	1/D
B	BS	Student Restroom next to Men's Shower Room	N/A	Concrete Floor		Non Suspect ACM	65	SF	0					N/A	N/A	N/A
B	BS	Student Restroom next to Men's Shower Room	N/A	Concrete Block Wall		Non Suspect ACM	195	SF	0					N/A	N/A	N/A
B	BS	Student Restroom next to Men's Shower Room	N/A	Concrete Ceiling		Non Suspect ACM	65	SF	0					N/A	N/A	N/A
B	BS	Student Restroom next to Men's Shower Room	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	20	LF	0					1	No	1/D
B	BS	Student Restroom next to Men's Shower Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	6	EA	0					1	No	1/D
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	N/A	Concrete Floor		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	N/A	Concrete Ceiling		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	125	LF	0					1	No	1/D
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	23	EA	0					1	No	1/D
B	BS	Hallway from End Classroom next to Men's Smaller Locker Room to Main (A) Building	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	65	LF	0					N/A	N/A	N/A
B	BS	Stairwell to Upper Classroom in Hallway next to Men's Smaller Locker Room	N/A	Concrete Floor		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
B	BS	Stairwell to Upper Classroom in Hallway next to Men's Smaller Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
B	BS	Stairwell to Upper Classroom in Hallway next to Men's Smaller Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
B	1	Storage Closet in Upper Classroom next to Stairwell	x	x		x	x	x	x	x	x	No Access		x	x	x
B	1	Hallway outside Upper Classroom	N/A	Concrete Floor		Non Suspect ACM	40	SF	0					N/A	N/A	N/A
B	1	Hallway outside Upper Classroom	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
B	1	Hallway outside Upper Classroom	N/A	Concrete Ceiling		Non Suspect ACM	40	SF	0					N/A	N/A	N/A
B	1	Hallway outside Upper Classroom	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sills		1	No	1/D
B	1	Hallway outside Upper Classroom	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	6	LF	0					1	No	1/D
B	1	Hallway outside Upper Classroom	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	3	EA	0					1	No	1/D
B	1	Upper Classroom	N/A	Wood Floor		Non Suspect ACM	3000	SF	0					N/A	N/A	N/A
B	1	Upper Classroom	N/A	Concrete Block Wall		Non Suspect ACM	9000	SF	0					N/A	N/A	N/A
B	1	Upper Classroom	N/A	Folding Partition Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
B	1	Upper Classroom	N/A	Concrete Ceiling		Non Suspect ACM	3000	SF	0					N/A	N/A	N/A
B	1	Upper Classroom	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	60	SF	0			Black Window Sills		1	No	1/D
B	1	Upper Classroom	T	Radiator Insulation	7010/01/01/SYN/BB/1600	Assumed	150	SF	0			10 Recessed Radiators - 15 SF Each		1	No	1/D
B	1	Restroom inside Upper Classroom	N/A	Concrete Floor		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
B	1	Restroom inside Upper Classroom	N/A	Brick Wall		Non Suspect ACM	180	SF	0					N/A	N/A	N/A
B	1	Restroom inside Upper Classroom	N/A	Concrete Ceiling		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
B	1	Restroom inside Upper Classroom	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sills		1	No	1/D

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914										AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728				
				On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)										
B	1			Restroom inside Upper Classroom	M	Transite Stalls	7010/01/01/SYN/BB/2310	Confirmed	15	SF	0							1/D										
B	1			Restroom inside Upper Classroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0						N/A	N/A										
B	1			Storage Room next to Restroom inside Upper Classroom	N/A	Concrete Floor		Non Suspect ACM	80	SF	0						N/A	N/A										
B	1			Storage Room next to Restroom inside Upper Classroom	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0						N/A	N/A										
B	1			Storage Room next to Restroom inside Upper Classroom	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0						N/A	N/A										
B	1			Stairwell to Upper Classroom and Fan Room above Gym	N/A	Concrete Floor		Non Suspect ACM	50	SF	0						N/A	N/A										
B	1			Stairwell to Upper Classroom and Fan Room above Gym	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0						N/A	N/A										
B	1			Stairwell to Upper Classroom and Fan Room above Gym	N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0						N/A	N/A										
B	1			Fan Room above Gym	N/A	Concrete Floor		Non Suspect ACM	2000	SF	0						N/A	N/A										
B	1			Fan Room above Gym	N/A	Concrete Block Wall		Non Suspect ACM	6000	SF	0						N/A	N/A										
B	1			Fan Room above Gym	N/A	Concrete Ceiling		Non Suspect ACM	2000	SF	0						N/A	N/A										
B	1			Fan Room above Gym	T	Pipe Insulation 2-6 inch	7010/01/01/31	Confirmed	100	LF	0						1	No 1/D										
B	1			Fan Room above Gym	T	Pipe Fitting Insulation	7010/01/01/30	Confirmed	15	EA	0						1	No 1/D										
B	1			Fan Room above Gym	M	Vibration Damper Cloth	7010/01/01/38	Assumed	30	SF	0						1	No 1/D										
C	BS			Current Main Entrance Foyer	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	1400	SF	0		Blue				1	No 1/D										
C	BS			Current Main Entrance Foyer	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0						N/A	N/A										
C	BS			Current Main Entrance Foyer	N/A	Brick Wall		Non Suspect ACM	2100	SF	0						N/A	N/A										
C	BS			Current Main Entrance Foyer	N/A	Ceiling Tile 2' x 4'		NAD	400	SF	0						N/A	N/A										
C	BS			Current Main Entrance Foyer	N/A	Concrete Ceiling		Non Suspect ACM	1000	SF	0						N/A	N/A										
C	BS			Storage Closet inside Current Main Entrance Foyer	x	x		x	x	x	x		x	Sheetrock Walls		x	x	x										
C	BS			Men's Staff Restroom in Current Main Entrance Foyer	N/A	Ceramic Tile Floors		Non Suspect ACM	30	SF	0						N/A	N/A										
C	BS			Men's Staff Restroom in Current Main Entrance Foyer	N/A	Concrete Block Wall		Non Suspect ACM	100	SF	0						N/A	N/A										
C	BS			Men's Staff Restroom in Current Main Entrance Foyer	N/A	Ceiling Tile 1' x 1'		NAD	30	SF	0						N/A	N/A										
C	BS			Women's Staff Restroom in Current Main Entrance Foyer	N/A	Ceramic Tile Floors		Non Suspect ACM	50	SF	0						N/A	N/A										
C	BS			Women's Staff Restroom in Current Main Entrance Foyer	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0						N/A	N/A										
C	BS			Women's Staff Restroom in Current Main Entrance Foyer	N/A	Ceiling Tile 1' x 1'		NAD	50	SF	0						N/A	N/A										
C	BS			Classroom 028	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	1120	SF	0		Blue	8 Missing Tiles			1	No 1/D										
C	BS			Classroom 028	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0						N/A	N/A										
C	BS			Classroom 028	N/A	Metal Walls		Non Suspect ACM	350	SF	0						N/A	N/A										
C	BS			Classroom 028	N/A	Concrete Ceiling		Non Suspect ACM	1120	SF	0						N/A	N/A										
C	BS			Classroom 028	N/A	Ceiling Tile 1' x 1'		NAD	600	SF	0						N/A	N/A										
C	BS			Classroom 028	M	Blackboard Glue Dots	7010/01/0B/SYN/BB/2600	Assumed	60	SF	0						1	No 1/D										
C	BS			Classroom 028	M	Sink Undercoat Mastic	7010/01/0B/SYN/BB/2602	Assumed	8	SF	0			1 Sink			1	No 1/D										
C	BS			Classroom 029	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	1600	SF	0		Blue				1	No 1/D										
C	BS			Classroom 029	N/A	Concrete Block Wall		Non Suspect ACM	4800	SF	0						N/A	N/A										
C	BS			Classroom 029	N/A	Sheetrock Wall		Non Suspect ACM	1500	SF	0						N/A	N/A										
C	BS			Classroom 029	N/A	Concrete Ceiling		Non Suspect ACM	1600	SF	0						N/A	N/A										
C	BS			Classroom 029	N/A	Ceiling Tile 1' x 1'		NAD	800	SF	0						N/A	N/A										
C	BS			Classroom 029	N/A	Ceiling Tile 2' x 4'		NAD	350	SF	0						N/A	N/A										
C	BS			Classroom 030	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	1400	SF	0		Brown				1	No 1/D										
C	BS			Classroom 030	N/A	Concrete Block Wall		Non Suspect ACM	4200	SF	0						N/A	N/A										
C	BS			Classroom 030	N/A	Concrete Ceiling		Non Suspect ACM	1400	SF	0						N/A	N/A										
C	BS			Classroom 030	N/A	Ceiling Tile 1' x 1'		NAD	700	SF	0						N/A	N/A										
C	BS			Entrance Vestibule next to Classroom 030	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	112	SF	0		Brown				1	No 1/D										
C	BS			Entrance Vestibule next to Classroom 030	N/A	Brick Wall		Non Suspect ACM	336	SF	0						N/A	N/A										
C	BS			Entrance Vestibule next to Classroom 030	N/A	Ceiling Tile 2' x 4'		NAD	112	SF	0						N/A	N/A										
D	BS			Stairwell next to AHU/Mechanical Room	N/A	Concrete Floor		Non Suspect ACM	250	SF	0						N/A	N/A										
D	BS			Stairwell next to AHU/Mechanical Room	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0						N/A	N/A										
D	BS			Stairwell next to AHU/Mechanical Room	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	N/A	Concrete Floor		Non Suspect ACM	1700	SF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	N/A	Concrete Block Wall		Non Suspect ACM	5100	SF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	N/A	Concrete Ceiling		Non Suspect ACM	1700	SF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	100	EA	0						1	No 1/D										
D	BS			AHU/Mechanical Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	600	LF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	N/A	Fiberglass Duct Insulation		Non Suspect ACM	500	SF	0						N/A	N/A										
D	BS			AHU/Mechanical Room	N/A	Vinyl Vibration Damper Cloth		Non Suspect ACM	25	SF	0						N/A	N/A										
D	BS			Music Classroom B027 next to AHU/Mechanical Room	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	1700	SF	0		Tan				1	No 1/D										
D	BS			Music Classroom B027 next to AHU/Mechanical Room	N/A	Concrete Block Wall		Non Suspect ACM	5100	SF	0						N/A	N/A										

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016				
												Building Inspector: Bernard J Bryson				
												Number: ACC-0125-6-031				
												Management Planner: Megan Vala Number: 740728				
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	BS	Music Classroom B027 next to AHU/Mechanical Room	N/A	Ceiling Tile 2' x 4'		NAD	1700	SF	0					N/A	N/A	N/A
D	BS	Music Classroom B027 next to AHU/Mechanical Room	N/A	Ceiling Tile 1' x 1'		Non Suspect ACM	800	SF	0			1' x 1' Cellular Glass Wall Panels		N/A	N/A	N/A
D	BS	Office B026	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	180	SF	0		Tan			1	No	1/D
D	BS	Office B026	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	BS	Office B026	N/A	Ceiling Tile 2' x 4'		NAD	180	SF	0					N/A	N/A	N/A
D	BS	Storage Room B025	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	180	SF	0		Tan			1	No	1/D
D	BS	Storage Room B025	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	BS	Storage Room B025	N/A	Ceiling Tile 2' x 4'		NAD	180	SF	0					N/A	N/A	N/A
D	BS	Hallway outside Office B026	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	50	SF	0		Tan			1	No	1/D
D	BS	Hallway outside Office B026	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	50	SF	0		Tan			1	No	1/D
D	BS	Hallway outside Office B026	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	BS	Hallway outside Office B026	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	BS	Storage Room B020	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	300	SF	0		Tan			1	No	1/D
D	BS	Storage Room B020	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	BS	Storage Room B020	N/A	Ceiling Tile 2' x 4'		NAD	300	SF	0					N/A	N/A	N/A
D	BS	Practice Room B021	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	80	SF	0		Tan			1	No	1/D
D	BS	Practice Room B021	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	BS	Practice Room B021	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	BS	Practice Room B022	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	80	SF	0		Tan			1	No	1/D
D	BS	Practice Room B022	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	BS	Practice Room B022	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	BS	Practice Room B023	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	80	SF	0		Tan			1	No	1/D
D	BS	Practice Room B023	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	BS	Practice Room B023	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	BS	Practice Room B024	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	80	SF	0		Tan			1	No	1/D
D	BS	Practice Room B024	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	BS	Practice Room B024	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	BS	Office B018	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	180	SF	0		Tan			1	No	1/D
D	BS	Office B018	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	BS	Office B018	N/A	Ceiling Tile 2' x 4'		NAD	180	SF	0					N/A	N/A	N/A
D	BS	Storage Room B019	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	180	SF	0		Tan			1	No	1/D
D	BS	Storage Room B019	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	BS	Storage Room B019	N/A	Ceiling Tile 2' x 4'		NAD	180	SF	0					N/A	N/A	N/A
D	BS	Hallway outside Office B018	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	100	SF	0		Tan			1	No	1/D
D	BS	Hallway outside Office B018	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	BS	Hallway outside Office B018	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	BS	Music Classroom B017 across from Elevator	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	1700	SF	0		Tan			1	No	1/D
D	BS	Music Classroom B017 across from Elevator	N/A	Concrete Block Wall		Non Suspect ACM	5100	SF	0					N/A	N/A	N/A
D	BS	Music Classroom B017 across from Elevator	N/A	Ceiling Tile 2' x 4'		NAD	1700	SF	0					N/A	N/A	N/A
D	BS	Music Classroom B017 across from Elevator	N/A	Ceiling Tile 1' x 1'		Non Suspect ACM	800	SF	0			1' x 1' Cellular Glass Wall Panels		N/A	N/A	N/A
D	BS	Elevator Machine Room next to Elevator	N/A	Concrete Floor		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	BS	Elevator Machine Room next to Elevator	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
D	BS	Elevator Machine Room next to Elevator	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	BS	Stairwell next to Music Classroom B017	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	BS	Stairwell next to Music Classroom B017	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	BS	Stairwell next to Music Classroom B017	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0					N/A	N/A	N/A
D	BS	Stairwell next to Music Classroom B017	T	Pipe Insulation 2-6 inch	7010/01/0B/01	Confirmed	7	LF	0			Basement - Ground Floor Landing		1	No	1/D
D	BS	Stairwell next to Music Classroom B017	T	Pipe Fitting Insulation	7010/01/0B/03	Confirmed	1	EA	0			Basement - Ground Floor Landing		1	No	1/D
D	BS	Main Hallway	M	Floor Tile VAT 9" x 9"	7010/01/0B/05	Confirmed	750	SF	0		Tan			1	No	1/D
D	BS	Main Hallway	M	Floor Tile VAT 12" x 12"	7010/01/0B/VV	Assumed	750	SF	0		Tan			1	No	1/D
D	BS	Main Hallway	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF	0					N/A	N/A	N/A
D	BS	Main Hallway	N/A	Ceiling Tile 2' x 4'		NAD	1500	SF	0					N/A	N/A	N/A
D	BS	Main Hallway	M	Transite Sills	7010/01/0B/SYN/BB/2300	Assumed	2	SF	0			Fire Extinguisher Sills		1	No	1/D
D	GD	Stairwell next to Classroom 019	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	GD	Stairwell next to Classroom 019	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	120	SF	0		Tan			1	No	1/D
D	GD	Stairwell next to Classroom 019	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	GD	Stairwell next to Classroom 019	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	GD	Stairwell next to Classroom 019	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	GD	Classroom 019	M	Floor Tile VAT 9" x 9"	7010/01/0G/22	Confirmed	450	SF	0		Tan			1	No	1/D
D	GD	Classroom 019	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	GD	Classroom 019	N/A	Sheetrock Wall		Non Suspect ACM	500	SF	0					N/A	N/A	N/A
D	GD	Classroom 019	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
D	GD	Classroom 019	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	GD	Restroom inside Classroom 019	N/A	Ceramic Tile Floors		Non Suspect ACM	100	SF	0					N/A	N/A	N/A
D	GD	Restroom inside Classroom 019	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	GD	Restroom inside Classroom 019	N/A	Sheetrock Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	GD	Restroom inside Classroom 019	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	GD	Laundry Room inside Classroom 019	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	50	SF	0		Tan			1	No	1/D
D	GD	Laundry Room inside Classroom 019	N/A	Concrete Block Wall		Non Suspect ACM	75	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016									
														Building Inspector: Bernard J Bryson									
																			Number: ACC-0125-6-031				
																			Management Planner: Megan Vala				
					Number: 740728																		
On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
D	GD	Laundry Room inside Classroom 019	N/A	Sheetrock Wall		Non Suspect ACM	75		SF	0							N/A	N/A	N/A				
D	GD	Laundry Room inside Classroom 019	N/A	Ceiling Tile 2' x 4'		NAD	50		SF	0								N/A	N/A	N/A			
D	GD	Laundry Room inside Classroom 019	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	5		LF	0								N/A	N/A	N/A			
D	GD	Classroom 020	M	Floor Tile VAT 9" x 9"	7010/01/0G/22	Confirmed	1400		SF	0				Tan			1	No	1/D				
D	GD	Classroom 020	N/A	Concrete Block Wall		Non Suspect ACM	3800		SF	0								N/A	N/A	N/A			
D	GD	Classroom 020	N/A	Sheetrock Wall		Non Suspect ACM	400		SF	0								N/A	N/A	N/A			
D	GD	Classroom 020	N/A	Ceiling Tile 2' x 4'		NAD	1400		SF	0								N/A	N/A	N/A			
D	GD	Classroom 020	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	6		SF	0					Black Window Sill		1	No	1/D				
D	GD	Classroom 020	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	40		SF	0							1	No	1/D				
D	GD	Classroom 020	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6		LF	0								N/A	N/A	N/A			
D	GD	Storage Room inside Classroom 020	N/A	Ceramic Tile Floors		Non Suspect ACM	225		SF	0								N/A	N/A	N/A			
D	GD	Storage Room inside Classroom 020	N/A	Concrete Block Wall		Non Suspect ACM	675		SF	0								N/A	N/A	N/A			
D	GD	Storage Room inside Classroom 020	N/A	Ceiling Tile 2' x 4'		NAD	225		SF	0								N/A	N/A	N/A			
D	GD	Kitchen inside Classroom 020	N/A	Ceramic Tile Floors		Non Suspect ACM	225		SF	0								N/A	N/A	N/A			
D	GD	Kitchen inside Classroom 020	N/A	Concrete Block Wall		Non Suspect ACM	675		SF	0								N/A	N/A	N/A			
D	GD	Kitchen inside Classroom 020	N/A	Ceiling Tile 2' x 4'		NAD	225		SF	0								N/A	N/A	N/A			
D	GD	Kitchen inside Classroom 020	M	Sink Undercoat Mastic	7010/01/0G/SYN/BB/2602	Assumed	6		SF	0					1 Sink		1	No	1/D				
D	GD	Classroom 008	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1200		SF	0				Tan			1	No	1/D				
D	GD	Classroom 008	N/A	Concrete Block Wall		Non Suspect ACM	3600		SF	0								N/A	N/A	N/A			
D	GD	Classroom 008	N/A	Sheetrock Wall		Non Suspect ACM	350		SF	0								N/A	N/A	N/A			
D	GD	Classroom 008	N/A	Ceiling Tile 2' x 4'		NAD	1200		SF	0								N/A	N/A	N/A			
D	GD	Classroom 008	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	4		SF	0					Black Window Sill		1	No	1/D				
D	GD	Classroom 008	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	240		SF	0							1	No	1/D				
D	GD	Classroom 009	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1500		SF	0				Tan			1	No	1/D				
D	GD	Classroom 009	N/A	Concrete Block Wall		Non Suspect ACM	4500		SF	0								N/A	N/A	N/A			
D	GD	Classroom 009	N/A	Sheetrock Wall		Non Suspect ACM	350		SF	0								N/A	N/A	N/A			
D	GD	Classroom 009	N/A	Ceiling Tile 2' x 4'		NAD	1500		SF	0								N/A	N/A	N/A			
D	GD	Classroom 009	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	100		SF	0							1	No	1/D				
D	GD	Classroom 009	T	Pipe Filling Insulation	7010/01/0G/23	Confirmed	2		EA	0					Ceiling Mounted Heater		1	No	1/D				
D	GD	Classroom 009	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	4		LF	0								N/A	N/A	N/A			
D	GD	Storage Room inside Classroom 009	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	100		SF	0				Tan			1	No	1/D				
D	GD	Storage Room inside Classroom 009	N/A	Concrete Block Wall		Non Suspect ACM	300		SF	0								N/A	N/A	N/A			
D	GD	Storage Room inside Classroom 009	N/A	Ceiling Tile 2' x 4'		NAD	100		SF	0								N/A	N/A	N/A			
D	GD	Corner Storage Room inside Classroom 009	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	280		SF	0				Tan			1	No	1/D				
D	GD	Corner Storage Room inside Classroom 009	N/A	Concrete Block Wall		Non Suspect ACM	840		SF	0								N/A	N/A	N/A			
D	GD	Corner Storage Room inside Classroom 009	N/A	Ceiling Tile 2' x 4'		NAD	280		SF	0								N/A	N/A	N/A			
D	GD	Small Lecture Room inside Classroom 009	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	480		SF	0				Tan			1	No	1/D				
D	GD	Small Lecture Room inside Classroom 009	N/A	Concrete Block Wall		Non Suspect ACM	1440		SF	0								N/A	N/A	N/A			
D	GD	Small Lecture Room inside Classroom 009	N/A	Ceiling Tile 2' x 4'		NAD	480		SF	0								N/A	N/A	N/A			
D	GD	Small Lecture Room inside Classroom 009	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	80		SF	0							1	No	1/D				
D	GD	Stairwell next to Classroom 009	N/A	Concrete Floor		Non Suspect ACM	250		SF	0								N/A	N/A	N/A			
D	GD	Stairwell next to Classroom 009	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	120		SF	0				Tan			1	No	1/D				
D	GD	Stairwell next to Classroom 009	N/A	Concrete Block Wall		Non Suspect ACM	750		SF	0								N/A	N/A	N/A			
D	GD	Stairwell next to Classroom 009	N/A	Plaster Ceiling		NAD	250		SF	0								N/A	N/A	N/A			
D	GD	Stairwell next to Classroom 009	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2		SF	0					Black Window Sill		1	No	1/D				
D	GD	Stairwell next to Classroom 009	T	Pipe Fitting Insulation	7010/01/0G/23	Confirmed	5		EA	0							1	No	1/D				
D	GD	Stairwell next to Classroom 009	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6		LF	0								N/A	N/A	N/A			
D	GD	Classroom 018	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1000		SF	0				Tan			1	No	1/D				
D	GD	Classroom 018	N/A	Concrete Block Wall		Non Suspect ACM	3000		SF	0								N/A	N/A	N/A			
D	GD	Classroom 018	N/A	Sheetrock Wall		Non Suspect ACM	350		SF	0								N/A	N/A	N/A			
D	GD	Classroom 018	N/A	Ceiling Tile 2' x 4'		NAD	1000		SF	0								N/A	N/A	N/A			
D	GD	Classroom 018	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	100		SF	0							1	No	1/D				
D	GD	Classroom 018	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	4		SF	0					Black Window Sill		1	No	1/D				
D	GD	Computer Classroom 017	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1000		SF	0				Tan			1	No	1/D				
D	GD	Computer Classroom 017	N/A	Concrete Block Wall		Non Suspect ACM	3000		SF	0								N/A	N/A	N/A			
D	GD	Computer Classroom 017	N/A	Sheetrock Wall		Non Suspect ACM	350		SF	0								N/A	N/A	N/A			
D	GD	Computer Classroom 017	N/A	Ceiling Tile 2' x 4'		NAD	1000		SF	0								N/A	N/A	N/A			
D	GD	Computer Classroom 017	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	160		SF	0							1	No	1/D				
D	GD	Computer Classroom 017	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	6		SF	0					Black Window Sill		1	No	1/D				
D	GD	Office 016	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	550		SF	0							1	No	1/D				
D	GD	Office 016	N/A	Concrete Block Wall		Non Suspect ACM	1650		SF	0								N/A	N/A	N/A			
D	GD	Office 016	N/A	Sheetrock Wall		Non Suspect ACM	160		SF	0								N/A	N/A	N/A			
D	GD	Office 016	N/A	Ceiling Tile 2' x 4'		NAD	550		SF	0								N/A	N/A	N/A			
D	GD	Office 016	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2		SF	0					Black Window Sill		1	No	1/D				
D	GD	Storage Room 016A	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	550		SF	0							1	No	1/D				
D	GD	Storage Room 016A	N/A	Concrete Block Wall		Non Suspect ACM	1650		SF	0								N/A	N/A	N/A			
D	GD	Storage Room 016A	N/A	Sheetrock Wall		Non Suspect ACM	80		SF	0								N/A	N/A	N/A			
D	GD	Storage Room 016A	N/A	Ceiling Tile 2' x 4'		NAD	550		SF	0								N/A	N/A	N/A			
D	GD	Storage Room 016A	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2		SF	0					Black Window Sill		1	No	1/D				
D	GD	Storage Room 016A	M	Sink Undercoat Mastic	7010/01/0G/SYN/BB/2602	Assumed	6		SF	0					1 Sink		1	No	1/D				
D	GD	Men's Staff Restroom next to Elevator	N/A	Ceramic Tile Floors		Non Suspect ACM	150		SF	0								N/A	N/A	N/A			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

Element Floor		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016									
														Building Inspector: Bernard J Bryson									
																			Number: ACC-0125-6-031				
																			Management Planner: Megan Vala				
On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF	LF	EA	Amount of Damage	SF	LF	EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
D	GD	Men's Staff Restroom next to Elevator	N/A	Concrete Block Wall		Non Suspect ACM	450	SF		0							N/A	N/A	N/A				
D	GD	Men's Staff Restroom next to Elevator	N/A	Plaster Ceiling		NAD	150	SF		0								N/A	N/A	N/A			
D	GD	IT MDF/Storage Room next to Elevator	N/A	Concrete Floor		Non Suspect ACM	150	SF		0								N/A	N/A	N/A			
D	GD	IT MDF/Storage Room next to Elevator	N/A	Concrete Block Wall		Non Suspect ACM	450	SF		0								N/A	N/A	N/A			
D	GD	IT MDF/Storage Room next to Elevator	N/A	Ceiling Tile 2' x 4'		NAD	150	SF		0								N/A	N/A	N/A			
D	GD	IT MDF/Storage Room next to Elevator	M	Transite Table Top	7010/01/0G/SYN/BB/2330	Assumed	24	SF		0					Loose Table Top		1	No	1/D				
D	GD	Elevator	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	50	SF		0			Grey				1	No	1/D				
D	GD	Elevator	N/A	Metal Walls		Non Suspect ACM	150	SF		0							N/A	N/A	N/A				
D	GD	Elevator	N/A	Metal Ceiling		Non Suspect ACM	50	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway from Classrooms 008 - 019	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1500	SF		0			Tan				1	No	1/D				
D	GD	Main Hallway from Classrooms 008 - 019	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway from Classrooms 008 - 019	N/A	Ceiling Tile 2' x 4'		NAD	1500	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway from Classrooms 008 - 019	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2	SF		0					Fire Extinguisher Sills		1	No	1/D				
D	GD	Main Hallway from Classrooms 008 - 019	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	80	SF		0							1	No	1/D				
D	GD	Main Hallway from Classrooms 011 - 015	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1000	SF		0			Tan				1	No	1/D				
D	GD	Main Hallway from Classrooms 011 - 015	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway from Classrooms 011 - 015	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway from Classrooms 011 - 015	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	1	SF		0					Fire Extinguisher Sills		1	No	1/D				
D	GD	Stairwell next to Carpentry Classroom 010	N/A	Concrete Floor		Non Suspect ACM	250	SF		0							N/A	N/A	N/A				
D	GD	Stairwell next to Carpentry Classroom 010	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	120	SF		0			Tan				1	No	1/D				
D	GD	Stairwell next to Carpentry Classroom 010	N/A	Concrete Block Wall		Non Suspect ACM	750	SF		0							N/A	N/A	N/A				
D	GD	Stairwell next to Carpentry Classroom 010	N/A	Plaster Ceiling		NAD	250	SF		0							N/A	N/A	N/A				
D	GD	Stairwell next to Carpentry Classroom 010	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2	SF		0					Black Window Sill		1	No	1/D				
D	GD	Men's Student Restroom	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF		0							N/A	N/A	N/A				
D	GD	Men's Student Restroom	N/A	Concrete Block Wall		Non Suspect ACM	900	SF		0							N/A	N/A	N/A				
D	GD	Men's Student Restroom	N/A	Plaster Ceiling		NAD	300	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway to Main (A) Building	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	450	SF		6			Tan	9x9 tiles below			1	Yes	5/B				
D	GD	Main Hallway to Main (A) Building	M	Floor Tile VAT 9" x 9"	7010/01/0G/22	Confirmed	450	SF		6			Tan	Below 12x12s			1	Yes	5/B				
D	GD	Main Hallway to Main (A) Building	N/A	Concrete Block Wall		Non Suspect ACM	1350	SF		0							N/A	N/A	N/A				
D	GD	Main Hallway to Main (A) Building	N/A	Ceiling Tile 2' x 4'		NAD	450	SF		0							N/A	N/A	N/A				
D	GD	Machine Shop Classroom 011	N/A	Concrete Floor		Non Suspect ACM	1800	SF		0							N/A	N/A	N/A				
D	GD	Machine Shop Classroom 011	N/A	Concrete Block Wall		Non Suspect ACM	5400	SF		0							N/A	N/A	N/A				
D	GD	Machine Shop Classroom 011	N/A	Ceiling Tile 2' x 4'		NAD	1800	SF		0							N/A	N/A	N/A				
D	GD	Machine Shop Classroom 011	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	10	SF		0					Black Window Sill		1	No	1/D				
D	GD	Machine Shop Classroom 011	N/A	Sheetrock Wall		Non Suspect ACM	250	SF		0							N/A	N/A	N/A				
D	GD	Front Office 011B between Machine Shop Classroom and Carpentry Classroom	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	250	SF		0			Blue				1	No	1/D				
D	GD	Front Office 011B between Machine Shop Classroom and Carpentry Classroom	N/A	Concrete Block Wall		Non Suspect ACM	375	SF		0							N/A	N/A	N/A				
D	GD	Front Office 011B between Machine Shop Classroom and Carpentry Classroom	N/A	Sheetrock Wall		Non Suspect ACM	375	SF		0							N/A	N/A	N/A				
D	GD	Front Office 011B between Machine Shop Classroom and Carpentry Classroom	N/A	Ceiling Tile 2' x 4'		NAD	250	SF		0							N/A	N/A	N/A				
D	GD	Rear Office 011A between Machine Shop Classroom and Carpentry Classroom	N/A	Concrete Floor		Non Suspect ACM	80	SF		0							N/A	N/A	N/A				
D	GD	Rear Office 011A between Machine Shop Classroom and Carpentry Classroom	N/A	Concrete Block Wall		Non Suspect ACM	120	SF		0							N/A	N/A	N/A				
D	GD	Rear Office 011A between Machine Shop Classroom and Carpentry Classroom	N/A	Sheetrock Wall		Non Suspect ACM	120	SF		0							N/A	N/A	N/A				
D	GD	Rear Office 011A between Machine Shop Classroom and Carpentry Classroom	N/A	Ceiling Tile 2' x 4'		NAD	80	SF		0							N/A	N/A	N/A				
D	GD	Rear Office 011A between Machine Shop Classroom and Carpentry Classroom	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2	SF		0					Black Window Sill		1	No	1/D				
D	GD	Carpentry Shop Classroom 012	N/A	Concrete Floor		Non Suspect ACM	1800	SF		0							N/A	N/A	N/A				
D	GD	Carpentry Shop Classroom 012	N/A	Concrete Block Wall		Non Suspect ACM	5400	SF		0							N/A	N/A	N/A				
D	GD	Carpentry Shop Classroom 012	N/A	Ceiling Tile 2' x 4'		NAD	1800	SF		0							N/A	N/A	N/A				
D	GD	Carpentry Shop Classroom 012	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	10	SF		0					Black Window Sill		1	No	1/D				
D	GD	Carpentry Shop Classroom 012	N/A	Sheetrock Wall		Non Suspect ACM	250	SF		0							N/A	N/A	N/A				
D	GD	Carpentry Shop Classroom 012	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	50	SF		0							1	No	1/D				
D	GD	Office 013	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	350	SF		0			Tan				1	No	1/D				
D	GD	Office 013	N/A	Concrete Block Wall		Non Suspect ACM	1050	SF		0							N/A	N/A	N/A				
D	GD	Office 013	N/A	Sheetrock Wall		Non Suspect ACM	350	SF		0							N/A	N/A	N/A				
D	GD	Office 013	N/A	Ceiling Tile 2' x 4'		NAD	350	SF		0							N/A	N/A	N/A				
D	GD	Office 013	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	2	SF		0					Black Window Sill		1	No	1/D				
D	GD	Front Small Office inside Office 013	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	150	SF		0			Tan				1	No	1/D				
D	GD	Front Small Office inside Office 013	N/A	Concrete Block Wall		Non Suspect ACM	450	SF		0							N/A	N/A	N/A				
D	GD	Front Small Office inside Office 013	N/A	Ceiling Tile 2' x 4'		NAD	150	SF		0							N/A	N/A	N/A				
D	GD	Rear Small Office inside Office 013	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	150	SF		0			Tan				1	No	1/D				
D	GD	Rear Small Office inside Office 013	N/A	Concrete Block Wall		Non Suspect ACM	450	SF		0							N/A	N/A	N/A				
D	GD	Rear Small Office inside Office 013	N/A	Ceiling Tile 2' x 4'		NAD	150	SF		0							N/A	N/A	N/A				
D	GD	Classroom 014	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1000	SF		0			Tan				1	No	1/D				
D	GD	Classroom 014	N/A	Concrete Block Wall		Non Suspect ACM	1500	SF		0							N/A	N/A	N/A				

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	GD	Classroom 014	N/A	Sheetrock Wall		Non Suspect ACM	1500	SF	0					N/A	N/A	N/A
D	GD	Classroom 014	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A
D	GD	Classroom 014	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	GD	Classroom 014	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	70	SF	0					1	No	1/D
D	GD	Classroom 015	M	Floor Tile VAT 12" x 12"	7010/01/0G/WW	Assumed	1000	SF	0		Tan			1	No	1/D
D	GD	Classroom 015	N/A	Concrete Block Wall		Non Suspect ACM	2250	SF	0					N/A	N/A	N/A
D	GD	Classroom 015	N/A	Sheetrock Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	GD	Classroom 015	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A
D	GD	Classroom 015	M	Transite Sills	7010/01/0G/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	GD	Classroom 015	M	Blackboard Glue Dots	7010/01/0G/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D
D	GD	Classroom 015	M	Transite Table Top	7010/01/0G/SYN/BB/2330	Assumed	30	SF	0			Table Top/Sink		1	No	1/D
D	GD	Custodial Closet outside Classroom 015	N/A	Concrete Floor		Non Suspect ACM	12	SF	0					N/A	N/A	N/A
D	GD	Custodial Closet outside Classroom 015	N/A	Concrete Block Wall		Non Suspect ACM	60	SF	0					N/A	N/A	N/A
D	GD	Custodial Closet outside Classroom 015	N/A	Plaster Ceiling		NAD	12	SF	0					N/A	N/A	N/A
D	1	Stairwell next to Main Office	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	1	Stairwell next to Main Office	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	1	Stairwell next to Main Office	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	1	Stairwell next to Main Office	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1	Main Hallway from Main Office to IMC	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	1500	SF	0		Tan			1	No	1/D
D	1	Main Hallway from Main Office to IMC	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF	0					N/A	N/A	N/A
D	1	Main Hallway from Main Office to IMC	N/A	Ceiling Tile 2' x 4'		NAD	1500	SF	0					N/A	N/A	N/A
D	1	Main Hallway from Main Office to IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Fire Extinguisher Sills		1	No	1/D
D	1	Main Hallway to Main (A) Building	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	600	SF	0		Tan			1	No	1/D
D	1	Main Hallway to Main (A) Building	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	1	Main Hallway to Main (A) Building	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
D	1	Stairwell next to IMC	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	1	Stairwell next to IMC	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	1	Stairwell next to IMC	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	1	Stairwell next to IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1	Hallway/Foyer to IMC	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	240	SF	0		Tan			1	No	1/D
D	1	Hallway/Foyer to IMC	N/A	Concrete Block Wall		Non Suspect ACM	720	SF	0					N/A	N/A	N/A
D	1	Hallway/Foyer to IMC	N/A	Ceiling Tile 2' x 4'		NAD	240	SF	0					N/A	N/A	N/A
D	1	Main Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	1000	SF	0		Tan			1	No	1/D
D	1	Main Office	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0					N/A	N/A	N/A
D	1	Main Office	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A
D	1	Copy Room next to Main Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1	Copy Room next to Main Office	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1	Copy Room next to Main Office	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1	Office next to Assistant Principal's Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1	Office next to Assistant Principal's Office	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1	Office next to Assistant Principal's Office	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1	Office next to Assistant Principal's Office	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1	Assistant Principal's Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1	Assistant Principal's Office	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1	Assistant Principal's Office	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1	Assistant Principal's Office	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	1	Principal's Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	650	SF	3	SF	Tan			1	Yes	5/B
D	1	Principal's Office	N/A	Concrete Block Wall		Non Suspect ACM	1950	SF	0					N/A	N/A	N/A
D	1	Principal's Office	N/A	Ceiling Tile 2' x 4'		NAD	650	SF	0					N/A	N/A	N/A
D	1	Principal's Office	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D
D	1	Principal's Office Restroom	N/A	Ceramic Tile Floors		Non Suspect ACM	20	SF	0					N/A	N/A	N/A
D	1	Principal's Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0					N/A	N/A	N/A
D	1	Principal's Office Restroom	N/A	Plaster Ceiling		NAD	20	SF	0					N/A	N/A	N/A
D	1	Main Office Mail Room	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	250	SF	0		Tan			1	No	1/D
D	1	Main Office Mail Room	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	1	Main Office Mail Room	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0					N/A	N/A	N/A
D	1	Foyer to Principal's Office from Main Hallway	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	80	SF	0		Tan	1 Missing Tile		1	No	1/D
D	1	Foyer to Principal's Office from Main Hallway	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	1	Foyer to Principal's Office from Main Hallway	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	1	Women's Staff Restroom across from Main Office	N/A	Ceramic Tile Floors		Non Suspect ACM	180	SF	0					N/A	N/A	N/A
D	1	Women's Staff Restroom across from Main Office	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	1	Women's Staff Restroom across from Main Office	N/A	Plaster Ceiling		NAD	180	SF	0					N/A	N/A	N/A
D	1	Men's Staff Restroom across from Main Office	N/A	Ceramic Tile Floors		Non Suspect ACM	180	SF	0					N/A	N/A	N/A
D	1	Men's Staff Restroom across from Main Office	N/A	Concrete Block Wall		Non Suspect ACM	540	SF	0					N/A	N/A	N/A
D	1	Men's Staff Restroom across from Main Office	N/A	Plaster Ceiling		NAD	180	SF	0					N/A	N/A	N/A
D	1	Finance Office next to Main Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	120	SF	0		Tan			1	No	1/D
D	1	Finance Office next to Main Office	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	1	Finance Office next to Main Office	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	1	Finance Office next to Main Office	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	16	SF	0					1	No	1/D
D	1	Teacher's Lounge across from Health Office Suite	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	520	SF	0		Tan			1	No	1/D
D	1	Teacher's Lounge across from Health Office Suite	N/A	Concrete Block Wall		Non Suspect ACM	1560	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report					Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728							
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	1	Teacher's Lounge across from Health Office Suite	N/A	Ceiling Tile 2' x 4'		NAD	520	SF	0					N/A	N/A	N/A
D	1	Teacher's Lounge across from Health Office Suite	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	32	SF	0					1	No	1/D
D	1	Teacher's Lounge across from Health Office Suite	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	1	Hallway to Office Cluster 123 across from Elevator	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	160	SF	0		Grey			1	No	1/D
D	1	Hallway to Office Cluster 123 across from Elevator	N/A	Concrete Block Wall		Non Suspect ACM	480	SF	0					N/A	N/A	N/A
D	1	Hallway to Office Cluster 123 across from Elevator	N/A	Ceiling Tile 2' x 4'		NAD	160	SF	0					N/A	N/A	N/A
D	1	Rear Office across from Elevator	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	170	SF	0		Grey			1	No	1/D
D	1	Rear Office across from Elevator	N/A	Concrete Block Wall		Non Suspect ACM	510	SF	0					N/A	N/A	N/A
D	1	Rear Office across from Elevator	N/A	Ceiling Tile 2' x 4'		NAD	170	SF	0					N/A	N/A	N/A
D	1	Middle Office across from Elevator	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	100	SF	0		Grey			1	No	1/D
D	1	Middle Office across from Elevator	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1	Middle Office across from Elevator	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	1	Front Office across from Elevator	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	100	SF	0		Grey	2 Missing Tiles		1	No	1/D
D	1	Front Office across from Elevator	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1	Front Office across from Elevator	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	1	Classroom W124	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	1400	SF	0		Tan			1	No	1/D
D	1	Classroom W124	N/A	Concrete Block Wall		Non Suspect ACM	4200	SF	0					N/A	N/A	N/A
D	1	Classroom W124	N/A	Ceiling Tile 2' x 4'		NAD	1400	SF	0					N/A	N/A	N/A
D	1	Classroom W124	M	Blackboard Glue Dots	7010/01/01/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D
D	1	Classroom W124	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	1	Storage Room inside Classroom W124	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	150	SF	0		Tan			1	No	1/D
D	1	Storage Room inside Classroom W124	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
D	1	Storage Room inside Classroom W124	N/A	Ceiling Tile 2' x 4'		NAD	150	SF	0					N/A	N/A	N/A
D	1	Special Education Classroom 134	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	480	SF	0		Tan	Includes W127A		1	No	1/D
D	1	Special Education Classroom 134	N/A	Concrete Block Wall		Non Suspect ACM	1440	SF	0					N/A	N/A	N/A
D	1	Special Education Classroom 134	N/A	Ceiling Tile 2' x 4'		NAD	480	SF	0					N/A	N/A	N/A
D	1	Special Education Classroom 134	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1	First Left Hand Office inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	120	SF	0		Tan			1	No	1/D
D	1	First Left Hand Office inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	1	First Left Hand Office inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	1	Second Left Hand Office inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	120	SF	0		Tan			1	No	1/D
D	1	Second Left Hand Office inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	1	Second Left Hand Office inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	1	Third Left Hand Office inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	120	SF	0		Tan			1	No	1/D
D	1	Third Left Hand Office inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	1	Third Left Hand Office inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	1	Rear Left Hand Office inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	120	SF	0		Tan			1	No	1/D
D	1	Rear Left Hand Office inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	1	Rear Left Hand Office inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	1	Office next to Lounge inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	100	SF	0		Tan			1	No	1/D
D	1	Office next to Lounge inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1	Office next to Lounge inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	1	Lounge inside Special Education Classroom W127	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	100	SF	0		Tan			1	No	1/D
D	1	Lounge inside Special Education Classroom W127	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1	Lounge inside Special Education Classroom W127	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	1	Roster Office 133	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	800	SF	0		Tan			1	No	1/D
D	1	Roster Office 133	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
D	1	Roster Office 133	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A
D	1	Rear Left Office in Roster Office 133	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1	Rear Left Office in Roster Office 133	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1	Rear Left Office in Roster Office 133	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1	Rear Right Office in Roster Office 133	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1	Rear Right Office in Roster Office 133	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1	Rear Right Office in Roster Office 133	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1	Health Office	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	600	SF	0		Tan			1	No	1/D
D	1	Health Office	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	1	Health Office	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report						Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728							
E	I	F															
			On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	1		Health Office Restroom	x	x		x	x	x	x	x		No Access		x	x	x
D	1		Health Office across from Health Office Restroom	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	150	SF	0		Tan			1	No	1/D
D	1		Health Office across from Health Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
D	1		Health Office across from Health Office Restroom	N/A	Ceiling Tile 2' x 4'		NAD	150	SF	0					N/A	N/A	N/A
D	1		Health Office across from Health Office Restroom	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1		x	x	x		x	x	x	x	x		Need on site room name		x	x	x
D	1		x	x	x		x	x	x	x	x		Need on site room name		x	x	x
D	1		x	x	x		x	x	x	x	x		Need on site room name		x	x	x
D	1		IMC (Library)	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	4200	SF	0		Tan			1	No	1/D
D	1		IMC (Library)	N/A	Concrete Block Wall		Non Suspect ACM	12600	SF	0					N/A	N/A	N/A
D	1		IMC (Library)	N/A	Ceiling Tile 2' x 4'		NAD	4200	SF	0					N/A	N/A	N/A
D	1		IMC (Library)	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	16	SF	0			Black Window Sill		1	No	1/D
D	1		Stairwell inside IMC	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	1		Stairwell inside IMC	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	1		Stairwell inside IMC	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	1		Stairwell inside IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1		IMC Office next to Stairwell	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	200	SF	0		Tan			1	No	1/D
D	1		IMC Office next to Stairwell	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0					N/A	N/A	N/A
D	1		IMC Office next to Stairwell	N/A	Ceiling Tile 2' x 4'		NAD	200	SF	0					N/A	N/A	N/A
D	1		Far Rear Corner Office inside IMC	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	250	SF	0		Tan			1	No	1/D
D	1		Far Rear Corner Office inside IMC	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	1		Far Rear Corner Office inside IMC	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0					N/A	N/A	N/A
D	1		Far Rear Corner Office inside IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	1		Far Rear Corner Office inside IMC	M	Sink Undercoat Mastic	7010/01/01/SYN/BB/2602	Assumed	6	SF	0			1 Sink		1	No	1/D
D	1		Middle Office inside IMC	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	520	SF	0		Tan			1	No	1/D
D	1		Middle Office inside IMC	N/A	Concrete Block Wall		Non Suspect ACM	1560	SF	0					N/A	N/A	N/A
D	1		Middle Office inside IMC	N/A	Ceiling Tile 2' x 4'		NAD	520	SF	0					N/A	N/A	N/A
D	1		Middle Office inside IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	1		Office next to Lounge inside IMC	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	520	SF	0		Tan			1	No	1/D
D	1		Office next to Lounge inside IMC	N/A	Concrete Block Wall		Non Suspect ACM	1560	SF	0					N/A	N/A	N/A
D	1		Office next to Lounge inside IMC	N/A	Ceiling Tile 2' x 4'		NAD	520	SF	0					N/A	N/A	N/A
D	1		Office next to Lounge inside IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	1		Lounge inside IMC	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	600	SF	0		Tan	Includes W118		1	No	1/D
D	1		Lounge inside IMC	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	1		Lounge inside IMC	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
D	1		Lounge inside IMC	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	1		Lounge inside IMC	M	Sink Undercoat Mastic	7010/01/01/SYN/BB/2602	Assumed	6	SF	0			1 Sink		1	No	1/D
D	1		Office between IMC Lounge and Women's Staff Restroom	x	x		x	x	x	x	x		No Access		x	x	x
D	1		Women's Staff Restroom outside of IMC	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1		Women's Staff Restroom outside of IMC	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	1		Women's Staff Restroom outside of IMC	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A
D	1		Men's Student Restroom outside of IMC	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	1		Men's Student Restroom outside of IMC	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	1		Men's Student Restroom outside of IMC	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A
D	1		IMC Office along Hallway Wall	M	Floor Tile VAT 12" x 12"	7010/01/01/RR	Assumed	150	SF	0		Tan			1	No	1/D
D	1		IMC Office along Hallway Wall	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
D	1		IMC Office along Hallway Wall	N/A	Ceiling Tile 2' x 4'		NAD	150	SF	0					N/A	N/A	N/A
D	1		IMC Office along Hallway Wall	M	Transite Sills	7010/01/01/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D
D	1		IMC Office along Hallway Wall	M	Floor Tile VAT 9" x 9"	7010/01/01/29	Confirmed	350	SF	0		Tan			1	No	1/D
D	1		IMC Office along Hallway Wall	N/A	Concrete Block Wall		Non Suspect ACM	1050	SF	0					N/A	N/A	N/A
D	1		IMC Office along Hallway Wall	N/A	Ceiling Tile 2' x 4'		NAD	350	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W232	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W232	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W232	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W232	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	2		Main Hallway from Classrooms W223 to W232	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1500	SF	0		Tan			1	No	1/D
D	2		Main Hallway from Classrooms W223 to W232	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF	0					N/A	N/A	N/A
D	2		Main Hallway from Classrooms W223 to W232	N/A	Ceiling Tile 2' x 4'		NAD	1500	SF	0					N/A	N/A	N/A
D	2		Main Hallway from Classrooms W223 to W232	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Fire Extinguisher Sills		1	No	1/D
D	2		Main Hallway to Main (A) Building	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	300	SF	0		Tan			1	No	1/D
D	2		Main Hallway to Main (A) Building	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	200	SF	0		Tan	Ramp		1	No	1/D
D	2		Main Hallway to Main (A) Building	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	2		Main Hallway to Main (A) Building	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W223	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W223	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W223	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	2		Stairwell next to Classroom W223	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	2		Main Hallway from Classrooms 224 - 228	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1000	SF	0		Tan			1	No	1/D
D	2		Main Hallway from Classrooms 224 - 228	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0					N/A	N/A	N/A
D	2		Main Hallway from Classrooms 224 - 228	N/A	Ceiling Tile 2' x 4'		NAD	1000	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728						
Element	Floor	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)			
D	2	Main Hallway from Classrooms 224 - 228	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	1	SF	0			Fire Extinguisher Sills		1	No	1/D			
D	2	Stairwell next to Classroom W226	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A			
D	2	Stairwell next to Classroom W226	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A			
D	2	Stairwell next to Classroom W226	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A			
D	2	Stairwell next to Classroom W226	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W232	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1200	SF	0		Tan			1	No	1/D			
D	2	Classroom W232	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W232	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A			
D	2	Classroom W232	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W232	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W232	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D			
D	2	Classroom W232	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	150	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Classroom W232	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	120	SF	0			Movable Table Tops		1	No	1/D			
D	2	Classroom W233	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1200	SF	0		Tan			1	No	1/D			
D	2	Classroom W233	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W233	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A			
D	2	Classroom W233	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W233	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W233	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
D	2	Classroom W233	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	120	SF	0			Fixed Table Tops		1	No	1/D			
D	2	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x			
D	2	Classroom W233 Lab Prep Room	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	350	SF	0		Tan			1	No	1/D			
D	2	Classroom W233 Lab Prep Room	N/A	Concrete Block Wall		Non Suspect ACM	1050	SF	0					N/A	N/A	N/A			
D	2	Classroom W233 Lab Prep Room	N/A	Ceiling Tile 2' x 4'		NAD	350	SF	0					N/A	N/A	N/A			
D	2	Classroom W233 Lab Prep Room	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	120	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D			
D	2	Classroom W221	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1200	SF	0		Tan			1	No	1/D			
D	2	Classroom W221	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W221	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W221	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W221	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
D	2	Classroom W221	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	130	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Classroom W221 Lab Prep Room	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	550	SF	0		Tan			1	No	1/D			
D	2	Classroom W221 Lab Prep Room	N/A	Concrete Block Wall		Non Suspect ACM	1650	SF	0					N/A	N/A	N/A			
D	2	Classroom W221 Lab Prep Room	N/A	Ceiling Tile 2' x 4'		NAD	550	SF	0					N/A	N/A	N/A			
D	2	Classroom W221 Lab Prep Room	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	4	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W221 Lab Prep Room	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	100	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D			
D	2	Restroom inside Classroom W221 Lab Prep Room	x	x		x	x	x	x	x	x	No Access		x	x	x			
D	2	Classroom W223 Large Lab Prep Room	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	250	SF	0		Tan			1	No	1/D			
D	2	Classroom W223 Large Lab Prep Room	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A			
D	2	Classroom W223 Large Lab Prep Room	N/A	Ceiling Tile 2' x 4'		NAD	250	SF	0					N/A	N/A	N/A			
D	2	Classroom W223 Large Lab Prep Room	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W223 Large Lab Prep Room	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	60	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Classroom W223 Small Lab Prep Room	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	100	SF	0		Tan			1	No	1/D			
D	2	Classroom W223 Small Lab Prep Room	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
D	2	Classroom W223 Small Lab Prep Room	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A			
D	2	Classroom W223 Small Lab Prep Room	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	40	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D			
D	2	Classroom W223	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	900	SF	0		Tan			1	No	1/D			
D	2	Classroom W223	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	300	SF	0		Tan			1	No	1/D			
D	2	Classroom W223	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W223	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W223	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W223	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	210	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Classroom W231	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1200	SF	0		Tan			1	No	1/D			
D	2	Classroom W231	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W231	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A			
D	2	Classroom W231	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W231	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W231	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
D	2	Classroom W231	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	100	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Classroom W231	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	15	SF	0			Movable Table Tops		1	No	1/D			
D	2	Classroom W230	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	1200	SF	0		Tan			1	No	1/D			
D	2	Classroom W230	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A			
D	2	Classroom W230	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A			
D	2	Classroom W230	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A			
D	2	Classroom W230	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D			
D	2	Classroom W230	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	80	SF	0					1	No	1/D			
D	2	Classroom W230	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	160	SF	0			Fixed Table Tops		1	No	1/D			
D	2	Corner Lab Prep Room inside Classroom W230	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	100	SF	0		Tan			1	No	1/D			
D	2	Corner Lab Prep Room inside Classroom W230	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A			
D	2	Corner Lab Prep Room inside Classroom W230	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A			
D	2	Corner Lab Prep Room inside Classroom W230	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D			

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728			
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	2	Corner Lab Prep Room inside Classroom W230	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	50	SF	0			Fixed Table Top and Sink		1	No	1/D
D	2	Lab Prep Room along Hallway Wall inside Classroom W230	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	100	SF	0		Tan			1	No	1/D
D	2	Lab Prep Room along Hallway Wall inside Classroom W230	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room along Hallway Wall inside Classroom W230	N/A	Ceiling Tile 2' x 4'		NAD	100	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room along Hallway Wall inside Classroom W230	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	2	Lab Prep Room along Hallway Wall inside Classroom W230	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	50	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D
D	2	Lab Prep Room W229 next to Classroom W230	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	600	SF	0		Tan			1	No	1/D
D	2	Lab Prep Room W229 next to Classroom W230	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room W229 next to Classroom W230	N/A	Ceiling Tile 2' x 4'		NAD	600	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room W229 next to Classroom W230	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	90	SF	0			Fixed Table Tops		1	No	1/D
D	2	x	x	x		x	x	x	x	x	x	Need on site room name		x	x	x
D	2	Men's Staff Restroom next to Elevator	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	2	Men's Staff Restroom next to Elevator	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	2	Men's Staff Restroom next to Elevator	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A
D	2	Women's Staff Restroom across from Classroom W224	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	2	Women's Staff Restroom across from Classroom W224	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	2	Women's Staff Restroom across from Classroom W224	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A
D	2	Classroom W224	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1200	SF	0		Tan			1	No	1/D
D	2	Classroom W224	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	2	Classroom W224	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
D	2	Classroom W224	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	2	Classroom W224	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D
D	2	Classroom W225	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1200	SF	0		Tan			1	No	1/D
D	2	Classroom W225	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	2	Classroom W225	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
D	2	Classroom W225	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D
D	2	Classroom W225	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D
D	2	Classroom W225	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	270	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D
D	2	Lab Prep Room inside Classroom W225	M	Floor Tile VAT 9" x 9"	7010/01/02/47	Confirmed	80	SF	0		Tan			1	No	1/D
D	2	Lab Prep Room inside Classroom W225	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room inside Classroom W225	N/A	Ceiling Tile 2' x 4'		NAD	80	SF	0					N/A	N/A	N/A
D	2	Lab Prep Room inside Classroom W225	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	30	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D
D	2	Lab Prep Room inside Classroom W225	M	Transite Fume Hood	7010/01/02/SYN/BB/2370	Assumed	50	SF	0			Fume Hood		1	No	1/D
D	2	Chemical Storage Room inside Classroom W225	x	x		x	x	x	x	x	x	No Access		x	x	x
D	2	Chemical Storage Room inside Classroom W226	x	x		x	x	x	x	x	x	No Access		x	x	x
D	2	Classroom W226	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1200	SF	0		Tan			1	No	1/D
D	2	Classroom W226	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	2	Classroom W226	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
D	2	Classroom W226	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D
D	2	Classroom W226	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	120	SF	0					1	No	1/D
D	2	Classroom W226	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	270	SF	0			Fixed Table Top, Sink and Drying Rack		1	No	1/D
D	2	Classroom W226	M	Transite Fume Hood	7010/01/02/SYN/BB/2370	Assumed	50	SF	0			Fume Hood		1	No	1/D
D	2	Classroom W227	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1200	SF	0		Tan			1	No	1/D
D	2	Classroom W227	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	2	Classroom W227	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A
D	2	Classroom W227	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
D	2	Classroom W227	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D
D	2	Classroom W227	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	200	SF	0			Fixed Table Tops		1	No	1/D
D	2	Classroom W228	M	Floor Tile VAT 12" x 12"	7010/01/02/SS	Assumed	1200	SF	0		Tan			1	No	1/D
D	2	Classroom W228	N/A	Concrete Block Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	2	Classroom W228	N/A	Folding Partition Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A
D	2	Classroom W228	N/A	Ceiling Tile 2' x 4'		NAD	1200	SF	0					N/A	N/A	N/A
D	2	Classroom W228	M	Transite Sills	7010/01/02/SYN/BB/2300	Assumed	8	SF	0			Black Window Sill		1	No	1/D
D	2	Classroom W228	M	Transite Table Top	7010/01/02/SYN/BB/2330	Assumed	200	SF	0			Fixed Table Tops		1	No	1/D
D	2	Classroom W228	M	Blackboard Glue Dots	7010/02/01/SYN/BB/2600	Assumed	32	SF	0					1	No	1/D
D	3	Stairwell next to Classroom W334	N/A	Concrete Floor		Non Suspect ACM	250	SF	0					N/A	N/A	N/A
D	3	Stairwell next to Classroom W334	N/A	Concrete Block Wall		Non Suspect ACM	750	SF	0					N/A	N/A	N/A
D	3	Stairwell next to Classroom W334	N/A	Plaster Ceiling		NAD	250	SF	0					N/A	N/A	N/A
D	3	Stairwell next to Classroom W334	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	2	SF	0			Black Window Sill		1	No	1/D
D	3	Stairwell next to Classroom W334	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0					N/A	N/A	N/A
D	3	Main Hallway from Classroom W332 to Kitchen	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	1500	SF	0		Tan			1	No	1/D
D	3	Main Hallway from Classroom W332 to Kitchen	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF	0					N/A	N/A	N/A
D	3	Main Hallway from Classroom W332 to Kitchen	N/A	Ceiling Tile 2' x 4'		NAD	1500	SF	0					N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

E l e m e n t		F l o o r		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914										AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728				
				On Site Room Name		System Affected	Material Description		HID#	Confirmed, Assumed, NAD, Non Suspect ACM		Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes		Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)						
D	3	Main Hallway from Classroom W332 to Kitchen		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		2	SF	0			Fire Extinguisher Sills			1	No	1/D							
D	3	Main Hallway to Main (A) Building		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		300	SF	0		Tan				1	No	1/D							
D	3	Main Hallway to Main (A) Building		M	Floor Tile VAT 12" x 12"		7010/01/03/TT		Assumed		200	SF	0		Tan	Ramp			1	No	1/D							
D	3	Main Hallway to Main (A) Building		N/A	Concrete Block Wall				Non Suspect ACM		1800	SF	0						N/A	N/A	N/A							
D	3	Main Hallway to Main (A) Building		N/A	Ceiling Tile 2' x 4'				NAD		600	SF	0						N/A	N/A	N/A							
D	3	Main Hallway to Main (A) Building		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		25	SF	0						1	No	1/D							
D	3	Stairwell next to Kitchen		N/A	Concrete Floor				Non Suspect ACM		250	SF	0						N/A	N/A	N/A							
D	3	Stairwell next to Kitchen		N/A	Concrete Block Wall				Non Suspect ACM		750	SF	0						N/A	N/A	N/A							
D	3	Stairwell next to Kitchen		N/A	Plaster Ceiling				NAD		250	SF	0						N/A	N/A	N/A							
D	3	Stairwell next to Kitchen		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		2	SF	0			Black Window Sill			1	No	1/D							
D	3	Stairwell next to Kitchen		N/A	Fiberglass Pipe Insulation				Non Suspect ACM		20	LF	0						N/A	N/A	N/A							
D	3	Main Hallway outside ROTC		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		300	SF	0		Tan				1	No	1/D							
D	3	Main Hallway outside ROTC		N/A	Concrete Block Wall				Non Suspect ACM		900	SF	0						N/A	N/A	N/A							
D	3	Main Hallway outside ROTC		N/A	Ceiling Tile 2' x 4'				NAD		300	SF	0						N/A	N/A	N/A							
D	3	Stairwell 8 inside ROTC Area		N/A	Concrete Floor				Non Suspect ACM		250	SF	0						N/A	N/A	N/A							
D	3	Stairwell 8 inside ROTC Area		N/A	Concrete Block Wall				Non Suspect ACM		750	SF	0						N/A	N/A	N/A							
D	3	Stairwell 8 inside ROTC Area		N/A	Plaster Ceiling				NAD		250	SF	0						N/A	N/A	N/A							
D	3	Stairwell 8 inside ROTC Area		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		2	SF	0			Black Window Sill			1	No	1/D							
D	3	Hallway from ROTC to Stairwell 8		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		250	SF	0		Tan				1	No	1/D							
D	3	Hallway from ROTC to Stairwell 8		N/A	Concrete Block Wall				Non Suspect ACM		750	SF	0						N/A	N/A	N/A							
D	3	Hallway from ROTC to Stairwell 8		N/A	Ceiling Tile 2' x 4'				NAD		250	SF	0						N/A	N/A	N/A							
D	3	Classroom W334		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		1200	SF	0		Tan				1	No	1/D							
D	3	Classroom W334		N/A	Concrete Block Wall				Non Suspect ACM		3600	SF	0						N/A	N/A	N/A							
D	3	Classroom W334		N/A	Ceiling Tile 2' x 4'				NAD		1200	SF	0						N/A	N/A	N/A							
D	3	Classroom W334		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		6	SF	0			Black Window Sill			1	No	1/D							
D	3	Classroom W334		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		250	SF	0						1	No	1/D							
D	3	Classroom W335		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		1200	SF	0		Tan				1	No	1/D							
D	3	Classroom W335		N/A	Concrete Block Wall				Non Suspect ACM		3600	SF	0						N/A	N/A	N/A							
D	3	Classroom W335		N/A	Ceiling Tile 2' x 4'				NAD		1200	SF	0						N/A	N/A	N/A							
D	3	Classroom W335		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		8	SF	0			Black Window Sill			1	No	1/D							
D	3	Classroom W335		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		180	SF	0						1	No	1/D							
D	3	Classroom W335 Storage Closet		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		350	SF	0		Tan				1	No	1/D							
D	3	Classroom W335 Storage Closet		N/A	Concrete Block Wall				Non Suspect ACM		1050	SF	0						N/A	N/A	N/A							
D	3	Classroom W335 Storage Closet		N/A	Ceiling Tile 2' x 4'				NAD		350	SF	0						N/A	N/A	N/A							
D	3	Office 336 inside Classroom W335		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		200	SF	0		Grey				1	No	1/D							
D	3	Office 336 inside Classroom W335		N/A	Concrete Block Wall				Non Suspect ACM		600	SF	0						N/A	N/A	N/A							
D	3	Office 336 inside Classroom W335		N/A	Ceiling Tile 2' x 4'				NAD		200	SF	0						N/A	N/A	N/A							
D	3	Office 336 inside Classroom W335		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		32	SF	0			Appears Relatively New; 9x9s below? Includes W324 and W325			1	No	1/D							
D	3	Restaurant		M	Linoleum		7010/01/03/CC		Assumed		1200	SF	0						1	No	1/D							
D	3	Restaurant		N/A	Concrete Block Wall				Non Suspect ACM		3600	SF	0						N/A	N/A	N/A							
D	3	Restaurant		N/A	Ceiling Tile 2' x 4'				NAD		1200	SF	0						N/A	N/A	N/A							
D	3	Restaurant		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		10	SF	0			Black Window Sill			1	No	1/D							
D	3	Restaurant Storage Room		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		100	SF	0		Tan				1	No	1/D							
D	3	Restaurant Storage Room		N/A	Concrete Block Wall				Non Suspect ACM		300	SF	0						N/A	N/A	N/A							
D	3	Restaurant Storage Room		N/A	Ceiling Tile 2' x 4'				NAD		100	SF	0						N/A	N/A	N/A							
D	3	Kitchen		M	Floor Tile VAT 12" x 12"		7010/01/03/TT		Assumed		1500	SF	0		Black				1	No	1/D							
D	3	Kitchen		N/A	Concrete Block Wall				Non Suspect ACM		4500	SF	0						N/A	N/A	N/A							
D	3	Kitchen		N/A	Ceiling Tile 2' x 4'				NAD		1500	SF	0						N/A	N/A	N/A							
D	3	Kitchen		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		6	SF	0			Black Window Sill			1	No	1/D							
D	3	Kitchen		M	Sink Undercoat Mastic		7010/01/03/SYN/BB/2602		Assumed		6	SF	0			1 Sink			1	No	1/D							
D	3	Kitchen Ice Machine Room		N/A	Concrete Floor				Non Suspect ACM		50	SF	0						N/A	N/A	N/A							
D	3	Kitchen Ice Machine Room		N/A	Concrete Block Wall				Non Suspect ACM		150	SF	0						N/A	N/A	N/A							
D	3	Kitchen Ice Machine Room		N/A	Ceiling Tile 2' x 4'				NAD		50	SF	0						N/A	N/A	N/A							
D	3	Kitchen Office		x	x				x		x	x	x	x	x	No Access			x	x	x							
D	3	Kitchen Storage Room		M	Floor Tile VAT 12" x 12"		7010/01/03/TT		Assumed		350	SF	0		Tan				1	No	1/D							
D	3	Kitchen Storage Room		N/A	Concrete Block Wall				Non Suspect ACM		1050	SF	0						N/A	N/A	N/A							
D	3	Kitchen Storage Room		N/A	Ceiling Tile 2' x 4'				NAD		350	SF	0						N/A	N/A	N/A							
D	3	Classroom W333		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		1500	SF	0		Tan				1	No	1/D							
D	3	Classroom W333		N/A	Concrete Block Wall				Non Suspect ACM		4500	SF	0						N/A	N/A	N/A							
D	3	Classroom W333		N/A	Folding Partition Wall				Non Suspect ACM		350	SF	0						N/A	N/A	N/A							
D	3	Classroom W333		N/A	Ceiling Tile 2' x 4'				NAD		1500	SF	0						N/A	N/A	N/A							
D	3	Classroom W333		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		10	SF	0			Black Window Sill			1	No	1/D							
D	3	Classroom W333		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		200	SF	0						1	No	1/D							
D	3	Classroom W332		M	Floor Tile VAT 9" x 9"		7010/01/03/59		Confirmed		1500	SF	0		Tan				1	No	1/D							
D	3	Classroom W332		N/A	Concrete Block Wall				Non Suspect ACM		4500	SF	0						N/A	N/A	N/A							
D	3	Classroom W332		N/A	Folding Partition Wall				Non Suspect ACM		350	SF	0						N/A	N/A	N/A							
D	3	Classroom W332		N/A	Ceiling Tile 2' x 4'				NAD		1500	SF	0						N/A	N/A	N/A							
D	3	Classroom W332		M	Transite Sills		7010/01/03/SYN/BB/2300		Assumed		6	SF	0			Black Window Sill			1	No	1/D							
D	3	Classroom W332		M	Blackboard Glue Dots		7010/03/01/SYN/BB/2600		Assumed		200	SF	0						1	No	1/D							
D	3	x		x	x		x		x		x	x	x	x	x	Need on site room name			x	x	x							

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report							Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728					
E l e m e n t	F l o o r	On Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
D	3	IT MDF/Storage Room	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	50	SF	5	SF	Tan	Loose Tiles; Trash Chute Present; Roof Access		1	Yes	5/B
D	3	IT MDF/Storage Room	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	3	IT MDF/Storage Room	N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
D	3	Women's Staff Restroom across from Classroom W327	N/A	Ceramic Tile Floors		Non Suspect ACM	300	SF	0					N/A	N/A	N/A
D	3	Women's Staff Restroom across from Classroom W327	N/A	Concrete Block Wall		Non Suspect ACM	900	SF	0					N/A	N/A	N/A
D	3	Women's Staff Restroom across from Classroom W327	N/A	Plaster Ceiling		NAD	300	SF	0					N/A	N/A	N/A
D	3	Restaurant W336	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	800	SF	0		Tan			1	No	1/D
D	3	Restaurant W336	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
D	3	Restaurant W336	N/A	Sheetrock Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A
D	3	Restaurant W336	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A
D	3	Restaurant W336	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	3	Restaurant W336	M	Blackboard Glue Dots	7010/03/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D
D	3	Classroom W327	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	800	SF	0		Tan			1	No	1/D
D	3	Classroom W327	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0					N/A	N/A	N/A
D	3	Classroom W327	N/A	Sheetrock Wall		Non Suspect ACM	350	SF	0					N/A	N/A	N/A
D	3	Classroom W327	N/A	Ceiling Tile 2' x 4'		NAD	800	SF	0					N/A	N/A	N/A
D	3	Classroom W327	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	6	SF	0			Black Window Sill		1	No	1/D
D	3	Classroom W327	M	Blackboard Glue Dots	7010/03/01/SYN/BB/2600	Assumed	100	SF	0					1	No	1/D
D	3	Storage Room inside Classroom W327	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	120	SF	0		Tan			1	No	1/D
D	3	Storage Room inside Classroom W327	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	3	Storage Room inside Classroom W327	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
D	3	ROTC Office	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	400	SF	0		Tan			1	No	1/D
D	3	ROTC Office	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A
D	3	ROTC Office	N/A	Ceiling Tile 2' x 4'		NAD	400	SF	0					N/A	N/A	N/A
D	3	Storage Room in ROTC Office	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	72	SF	0		Tan			1	No	1/D
D	3	Storage Room in ROTC Office	N/A	Concrete Block Wall		Non Suspect ACM	216	SF	0					N/A	N/A	N/A
D	3	Storage Room in ROTC Office	N/A	Ceiling Tile 2' x 4'		NAD	72	SF	0					N/A	N/A	N/A
D	3	Restroom in ROTC Office	N/A	Ceramic Tile Floors		Non Suspect ACM	50	SF	0					N/A	N/A	N/A
D	3	Restroom in ROTC Office	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	3	Restroom in ROTC Office	N/A	Plaster Ceiling		NAD	50	SF	0					N/A	N/A	N/A
D	3	Storage Room next to ROTC Office	N/A	Ceramic Tile Floors		Non Suspect ACM	120	SF	0			Former Restroom		N/A	N/A	N/A
D	3	Storage Room next to ROTC Office	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	3	Storage Room next to ROTC Office	N/A	Plaster Ceiling		NAD	120	SF	0					N/A	N/A	N/A
D	3	ROTC Classroom	M	Floor Tile VAT 12" x 12"	7010/01/03/TT	Assumed	1200	SF	0		White Blue	Includes W329 and W339		1	No	1/D
D	3	ROTC Classroom	M	Floor Tile VAT 12" x 12"	7010/01/03/TT	Assumed	1200	SF	0					1	No	1/D
D	3	ROTC Classroom	N/A	Concrete Block Wall		Non Suspect ACM	7200	SF	0					N/A	N/A	N/A
D	3	ROTC Classroom	N/A	Ceiling Tile 2' x 4'		NAD	2400	SF	0					N/A	N/A	N/A
D	3	ROTC Classroom	M	Transite Sills	7010/01/03/SYN/BB/2300	Assumed	14	SF	0			Black Window Sill		1	No	1/D
D	3	ROTC Classroom	M	Sink Undercoat Mastic	7010/01/03/SYN/BB/2602	Assumed	6	SF	0			1 Sink		1	No	1/D
D	3	Larger Storage Room between ROTC Classroom and Women's Staff Restroom	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	150	SF	0		Tan			1	No	1/D
D	3	Larger Storage Room between ROTC Classroom and Women's Staff Restroom	N/A	Concrete Block Wall		Non Suspect ACM	450	SF	0					N/A	N/A	N/A
D	3	Larger Storage Room between ROTC Classroom and Women's Staff Restroom	N/A	Ceiling Tile 2' x 4'		NAD	150	SF	0					N/A	N/A	N/A
D	3	Smaller Storage Room between ROTC Classroom and Women's Staff Restroom	M	Floor Tile VAT 9" x 9"	7010/01/03/59	Confirmed	50	SF	0		Tan			1	No	1/D
D	3	Smaller Storage Room between ROTC Classroom and Women's Staff Restroom	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0					N/A	N/A	N/A
D	3	Smaller Storage Room between ROTC Classroom and Women's Staff Restroom	N/A	Ceiling Tile 2' x 4'		NAD	50	SF	0					N/A	N/A	N/A
D	3	Outdoor Roof Deck	N/A	Concrete Floor		Non Suspect ACM	1200	SF	0					N/A	N/A	N/A
D	3	Outdoor Roof Deck	N/A	Brick Wall		Non Suspect ACM	3600	SF	0					N/A	N/A	N/A
D	3	Storage Room in Outdoor Roof Deck	N/A	Concrete Floor		Non Suspect ACM	120	SF	0					N/A	N/A	N/A
D	3	Storage Room in Outdoor Roof Deck	N/A	Concrete Block Wall		Non Suspect ACM	360	SF	0					N/A	N/A	N/A
D	3	Storage Room in Outdoor Roof Deck	N/A	Ceiling Tile 2' x 4'		NAD	120	SF	0					N/A	N/A	N/A
A	4	3rd Floor Gymnasium Attic	N/A	Plaster Floor		NAD	5000	SF	0				"B"	N/A	N/A	N/A
A	4	3rd Floor Gymnasium Attic	N/A	Wood Catwalks		Non Suspect ACM	250	SF	0				"B"	N/A	N/A	N/A
A	4	3rd Floor Gymnasium Attic	N/A	Brick Wall		Non Suspect ACM	15000	SF	0				"B"	N/A	N/A	N/A
A	4	3rd Floor Gymnasium Attic	N/A	Concrete Ceiling		Non Suspect ACM	5000	SF	0				"B"	N/A	N/A	N/A
A	4	3rd Floor Gymnasium Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	400	LF	0				"B"	1	No	1/D
A	4	3rd Floor Gymnasium Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	50	EA	0				"B"	1	No	1/D
A	4	Oakland Street Attic	N/A	Plaster Floor		NAD	3000	SF	0				"B"	N/A	N/A	N/A
A	4	Oakland Street Attic	N/A	Wood Catwalks		Non Suspect ACM	150	SF	0				"B"	N/A	N/A	N/A
A	4	Oakland Street Attic	N/A	Brick Wall		Non Suspect ACM	9000	SF	0				"B"	N/A	N/A	N/A
A	4	Oakland Street Attic	N/A	Concrete Ceiling		Non Suspect ACM	3000	SF	0				"B"	N/A	N/A	N/A
A	4	Oakland Street Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	200	LF	0			Approximate - Did not fully enter	"B"	1	No	1/D
A	4	Oakland Street Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	25	EA	0			Approximate - Did not fully enter	"B"	1	No	1/D
A	4	Wakeling Street Attic	N/A	Plaster Floor		NAD	2000	SF	0				"B"	N/A	N/A	N/A

7010 Frankford HS 2015-2016 AHERA Three-Year Report.xls

Element		Floor		School District of Philadelphia Frankford High School 5000 Oxford Avenue, Philadelphia, PA 19124 ULCS# 7010 Year Built: 1914										AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report					Reinspection Date: March 21-25, 2016 Building Inspector: Bernard J Bryson Number: ACC-0125-6-031 Management Planner: Megan Vala Number: 740728				
On Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)								
A	4	Wakeling Street Attic	N/A	Wood Catwalks	Non Suspect ACM	100	SF	0				"B"	N/A	N/A	N/A								
A	4	Wakeling Street Attic	N/A	Brick Wall	Non Suspect ACM	6000	SF	0				"B"	N/A	N/A	N/A								
A	4	Wakeling Street Attic	N/A	Concrete Ceiling	Non Suspect ACM	2000	SF	0				"B"	N/A	N/A	N/A								
A	4	Wakeling Street Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	130	LF	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	Wakeling Street Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	25	EA	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	North Oxford Street Attic	N/A	Plaster Floor	NAD	2000	SF	0				"B"	N/A	N/A	N/A								
A	4	North Oxford Street Attic	N/A	Wood Catwalks	Non Suspect ACM	100	SF	0				"B"	N/A	N/A	N/A								
A	4	North Oxford Street Attic	N/A	Brick Wall	Non Suspect ACM	6000	SF	0				"B"	N/A	N/A	N/A								
A	4	North Oxford Street Attic	N/A	Concrete Ceiling	Non Suspect ACM	2000	SF	0				"B"	N/A	N/A	N/A								
A	4	North Oxford Street Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	130	LF	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	North Oxford Street Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	25	EA	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	South Oxford Street Attic	N/A	Plaster Floor	NAD	2000	SF	0				"B"	N/A	N/A	N/A								
A	4	South Oxford Street Attic	N/A	Wood Catwalks	Non Suspect ACM	100	SF	0				"B"	N/A	N/A	N/A								
A	4	South Oxford Street Attic	N/A	Brick Wall	Non Suspect ACM	6000	SF	0				"B"	N/A	N/A	N/A								
A	4	South Oxford Street Attic	N/A	Concrete Ceiling	Non Suspect ACM	2000	SF	0				"B"	N/A	N/A	N/A								
A	4	South Oxford Street Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	130	LF	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	South Oxford Street Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	25	EA	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	Harrison Street Attic	N/A	Plaster Floor	NAD	3000	SF	0				"B"	N/A	N/A	N/A								
A	4	Harrison Street Attic	N/A	Wood Catwalks	Non Suspect ACM	150	SF	0				"B"	N/A	N/A	N/A								
A	4	Harrison Street Attic	N/A	Brick Wall	Non Suspect ACM	9000	SF	0				"B"	N/A	N/A	N/A								
A	4	Harrison Street Attic	N/A	Concrete Ceiling	Non Suspect ACM	3000	SF	0				"B"	N/A	N/A	N/A								
A	4	Harrison Street Attic	T	Pipe Insulation 2-6 inch	7010/01/04/64	Confirmed	200	LF	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	4	Harrison Street Attic	T	Pipe Fitting Insulation	7010/01/04/69	Confirmed	25	EA	0		Approximate - Did not fully enter	"B"	1	No	1/D								
A	CS	Crawl Space accessible from Boiler Room	X	X	X	X	X	X			Does this crawl space exist? Previously listed as inaccessible due to 4" of water	"D"	X	X	X								
A	1	Unfinished Crawl space behind Auditorium - Restricted Area	N/A	Brick Wall	Non Suspect ACM	420	SF	0				"A"	N/A	N/A	N/A								
A	1	Unfinished Crawl space behind Auditorium - Restricted Area	N/A	Concrete Ceiling	Non Suspect ACM	140	SF	0				"A"	N/A	N/A	N/A								
A	1	Unfinished Crawl space behind Auditorium - Restricted Area	N/A	Fire Doors	Non Suspect ACM	1	EA	0			Metal Fire Door with Wood Interior	"A"	N/A	N/A	N/A								

Section III Certificates

A. Management Planner/Building Inspector Certificates

Section III – A

Management Planner/Building Inspector Certificates

These charts indicate the Name, Course Date, Expiration Date and Corresponding Certificate Number of the Management Planner and Building Inspector of individuals that participated in the AHERA 3 Year Inspection and Management Plan process of 2015/2016.

Management Planner	Date Granted	Expiration Date	Certificate Number
Monique Causley	2/15/2015	2/16/2016	ACC-0215-8-010
Monique Causley	2/16/2016	2/17/2017	ACC-0216-8-001
Megan Vala	5/22/2015	6/22/2016	740728
Mary Anne Lerro	4/5/2016	4/5/2017	742327

Building Inspector	Date Granted	Expiration Date	Certificate Number
Scott Magee	8/15/2015	8/15/2016	70016699C
William Garrity	8/15/2015	8/15/2016	70016699A
Bernard Brunner	10/2/2015	8/2/2016	45397
Mary Anne Lerro	3/3/2015	3/3/2016	740092
Mary Anne Lerro	4/5/2016	4/5/2017	742322
James Madden	12/11/2014	12/11/2015	ACC-1214-6-010
James Madden	12/3/2015	12/3/2016	ACC-1215-6-018
Troy Ray	3/15/2015	3/19/2016	ACC-0355-6-011
Ananth Vinjamuri	9/29/2015	9/29/2016	374
Shelton Williams	9/29/2015	9/29/2016	375
Paul Davis	2/12/2015	2/12/2016	ACC-0215-6-015
Paul Davis	2/2/2016	2/2/2017	741836
Bernard Bryson	2/16/2015	2/16/2016	ACC-0125-6-031
Bernard Bryson	2/15/2016	2/15/2017	ACC-0216-6-005
Alexander Roman	9/18/2015	9/18/2016	EHSBIR-150619-008
Norm Harrison	9/2/2015	9/2/2016	ACC-0915-6-011
Kelly Mayberry	2/20/2015	2/20/2016	EHSBIR-150220-005
Kelly Mayberry	2/18/2016	2/18/2017	EHSBIR-160218-006
Andrew Hine	5/6/2015	5/6/2016	AI05042015-3
Maryellen Leotta	2/12/2015	2/12/2016	ACC-0215-6-024

Certificate of Completion

awarded to

Monique Causley

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Management Planner Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/16/15

Course Date

N/A

Exam Date

2/16/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-8-010

Certificate Number

Mark K. Schlager
Training Director

Certificate of Completion

awarded to

Monique Causley

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Management Planner Refresher Course

under TSCA Title II

presented by

**ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449**

2/15/16

Course Date

N/A

Exam Date

2/15/17

Expiration Date

Not Provided

Social Security Number

ACC-0216-8-001

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Megan Vala

HAS SUCCESSFULLY COMPLETED A 16 HOUR COURSE ENTITLED

Asbestos Management Planner Initial

INCLUDING CLASSROOM INSTRUCTION

05/21/2015 to 05/22/2015


Exam passed on this 22nd day of May 2015 - Score - 94

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:


James A. Welte, CIH, President

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Management Planner Refresher

INCLUDING CLASSROOM INSTRUCTION

on this 5th day of April 2016

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:

James A. Welts
James A. Welts, CIH, President

EMSL ANALYTICAL, INC.

Certifies that

Scott Magee

has successfully completed the course of study for the

Asbestos Building Inspector Refresher Course

for Accreditation under TSCA Title II

EMSL Certificate No. 70016699C


Approved by:

PA Dept. of Labor and Industry
Accreditation # 137

Course Date: 8/15/2015
Granted: 8/15/2015
Expiration Date: 8/15/2016

Sponsored by:

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
Phone: (800) 220-3675
Fax: (856) 786-5973
www.emsl.com



Michael P. Menz

Michael P. Menz, CIH
Training Director

Environmental, Mold, Bacteria, IAQ, Asbestos, Lead, Forensic and Materials Testing Since 1981

EMSL ANALYTICAL, INC.

Certifies that

William Garrity

has successfully completed the course of study for the

Asbestos Building Inspector Refresher Course

for Accreditation under TSCA Title II

EMSL Certificate No. 70016699A


Approved by:

PA Dept. of Labor and Industry
Accreditation # 137

Course Date: 8/15/2015
Granted: 8/15/2015
Expiration Date: 8/15/2016

Sponsored by:

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
Phone: (800) 220-3675
Fax: (856) 786-5973
www.emsl.com



Michael P. Menz

Michael P. Menz, CIH
Training Director

Environmental, Mold, Bacteria, IAQ, Asbestos, Lead, Forensic and Materials Testing Since 1981

45397

National Asbestos & Environmental Training Institute

CERTIFICATE OF COMPLETION

AHERA/EPA Accredited Per 40 CFR Part 763
Asbestos Accreditation under TSCA Title II

This is to certify that


Bernard Brunner, Jr.

Successfully completed the course entitled

**1/2-Day New York State/EP A/AHERA Asbestos Building Inspector Annual Refresher on
October 2, 2015**

Examination Passed October 2, 2015

Expiration Date on October 2, 2016


Doris L. Adler
President, NAEETI

Per 10 NYCRR Part 73.2 (L) (1), DOH 2832 Certificate of Completion of Asbestos
Safety Training is the only official record of training for N.Y.S. students.

Language: English

ABIH 1/2 CM POINT

3321 Doris Avenue, Building B, Ocean, NJ 07712

Phone (732) 531-5571

Fax (732) 531-5956

www.naeti.com

Number 740092

Expiration Date:
03/03/2016

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Building Inspector Refresher

on this 3rd day of March 2015

Exam passed on this 3rd day of March 2015 - Score - 84

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:

James A. Welts

James A. Welts, CIH, President

Number 742322

Expiration Date:
04/05/2017

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Building Inspector Refresher

INCLUDING CLASSROOM INSTRUCTION

on this 5th day of April 2016

Exam passed on this 5th day of April 2016 - Score - 88

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:

James A. Welts

James A. Welts, CIH, President

Certificate of Completion

James Madden

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

12/11/14

Course Date

N/A

Exam Date

12/11/15

Expiration Date

Not Provided

Social Security Number

ACC-1214-6-010

Certificate Number

Mark K. Schlager
Mark K. Schlager
Training Director

Certificate of Completion

James Madden

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

12/3/15

Course Date

N/A

Exam Date

12/3/16

Expiration Date

Not Provided

Social Security Number

ACC-1215-6-018

Certificate Number

Mark K. Schlager
Training Director

Certificate of Completion

Troy A. Ray

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

**ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449**

3/19/15

Course Date

N/A

Exam Date

3/19/16

Expiration Date

Not Provided

Social Security Number

ACC-0355-6-011

Certificate Number

Mark K. Schlager
Training Director

CERTIFICATE NO 374

G&C Environmental Services, Inc. (#294)

2 Street Road, Newtown Square, Pennsylvania 19073

Telephone: (610) 993-9202 Facsimile: (610) 993-9232

Email: Training@gcenviro.com

www.GCenviro.com

This document certifies that Ananth K. Vinjamuri has successfully completed this

State of New York Department of Health Approved AHERA BUILDING INSPECTOR

REFRESHER COURSE, completed as required for asbestos accreditation under the Toxic

Substances Control Act, Title II. This course was held from 09/29/2015 to 09/29/2015.

The examination date was 09/29/2015. This certificate expires one year from the date of

successful completion of the examination 09/29/2016.

The official record of successful training completion is the New York State Department of Health certificate of asbestos safety training completion (DPH 2832).

Gail M. Conner
Training Director

Gail M. Conner

CERTIFICATE NO 375

G&C Environmental Services, Inc. (#294)

2 Street Road, Newtown Square, Pennsylvania 19073

Telephone: (610) 993-9202 Facsimile: (610) 993-9232

Email: Training@gcenviro.com

www.GCenviro.com

This document certifies that Shelton Williams has successfully completed this
State of New York Department of Health Approved AHERA BUILDING INSPECTOR

REFRESHER COURSE, completed as required for asbestos accreditation under the Toxic

Substances Control Act, Title II. This course was held from 09/29/2015 to 09/29/2015.
MM DD YR MM DD YR

The examination date was 09/29/2015. This certificate expires one year from the date of
MM DD YR
successful completion of the examination 09/29/2016.
MM DD YR

*The official record of successful training completion is the New York State Department of
Health certificate of asbestos safety training completion (DPH 2832).*

Gail M. Conner
Training Director

Gail M. Conner

Certificate of Completion

Paul M. Davis

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/12/15

Course Date

N/A

Exam Date

2/12/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-6-015

Certificate Number

Mark K. Schlager
Training Director

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Paul M. Davis

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED
Asbestos Building Inspector Refresher

INCLUDING CLASSROOM INSTRUCTION

on this 2nd day of February 2016

Exam passed on this 2nd day of February 2016 - Score - 92

Approved for AHERA Accreditation Under ISCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:

James A. Wells

James A. Wells, CIH, President

Certificate of Completion

Bernard J. Bryson

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/16/15
Course Date

N/A

Exam Date

2/16/16

Expiration Date

Not Provided

Social Security Number

ACC-0125-6-031

Certificate Number

Mark K. Schlager
Training Director

Certificate of Completion

Bernard J. Bryson

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/15/16

Course Date

N/A

Exam Date

2/15/17

Expiration Date

Not Provided

Social Security Number

ACC-0216-6-005

Certificate Number

Mark K. Schlager
Training Director

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:

Alexander Roman

SS#:XXX-XX-1743
Who has completed this 4-hour course and examination,
EPA Approved under TSCA Title II
AHERA / ASHARA Rule
40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.

A Division of BATTI, Inc.

Delaware Industrial Park • 6 Garfield Way
Newark, DE 19713-5817
(302) 737-3376 • Fax (302) 737-5764

Course Date: **September 18, 2015**
Date of Expiration: **September 18, 201**
Certification Number : **EHSBIR 150619-008**


Todd K. Zeisloff, Instructor


Neeraj K. Batta, President

Certificate of Completion

Norman Harrison

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08109
(856) 665-3449

9/2/15

Course Date

N/A

Exam Date

9/2/16


Expiration Date

Not Provided

Social Security Number

ACC-0915-6-011

Certificate Number


Mark A. Schlenger
Training Director

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:

Kelly Mayberry

SS#:XXX-XX-1551

Who has completed this 4-hour course and examination,
EPA Approved under TSCA Title II
AHERA / ASHARA Rule
40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.

A Division of BATTI, Inc.

Delaware Industrial Park • 6 Garfield Way

Newark, DE 19713-5817

(302) 737-3376 • Fax (302) 737-5764

Course Date: February 20, 2015

Date of Expiration: February 20, 2016

Certification Number : EHSBIR 150220-005


Todd K. Zeisloft, Instructor


Neeraj K. Batta, President

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:

Kelly Mayberry

SS#:XXX-XX-1551

Who has completed this 4-hour course and examination,

EPA Approved under TSCA Title II

AHERA / ASHARA Rule

40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.

A Division of BATTI, Inc.

Delaware Industrial Park • 6 Garfield Way
Newark, DE 19713-5817

(302) 737-3376 • Fax (302) 737-5764

Course Date: February 18, 2016

Date of Expiration: February 18, 2017

Certification Number : EHSBIR 160218-006



Todd K. Zeisloft, Instructor



Neeraj K. Batta, President

AEROSOL MONITORING & ANALYSIS, INC.

This is to certify that
ANDREW HINE

*has met the attendance requirements and successfully completed
the course entitled*

3-DAY EPA AHERA INSPECTOR
For Accreditation Under TSCA Title II

05/04/2015 to 05/06/2015

Course Date

05/06/2015

Exam Date

5/6/2016

Expiration Date

STEVE SIERAGI

Principal Instructor

Steve Sieragi

A105042015-3

Certification No.

E. Rush Barnett

Course Director

E. Rush Barnett

1331 Ashton Road

P.O.Box 646

Hanover, MD 21076

P: 410-684-3327

F: 410-684-3724

www.amatrainning.com

Certificate of Completion

Maryellen Leotta

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/12/15

Course Date

N/A

Exam Date

2/12/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-6-024

Certificate Number

Mark K. Schlüger
Training Director

Asbestos Hazard Emergency Response Act (AHERA) Environmental Compliance Audit Cross Reference Table

In response to the AHERA Environmental Compliance Audit a Cross Reference Table has been prepared for inclusion into the Environmental Management Plan. The purpose of this Cross Reference Table is to link the following documents to the AHERA Management Plan.

Cross Reference Table	
3 Year Reinspection Report follows this Cross Reference Table documentation.	
Subject Matter	Location of Required Documents
Designated Person	Pages 1 - 3
Annual Notification	Pages 4 - 5
6 Month Periodic Surveillance Outline of Events	Page 6
3 Year Re-inspections Outline of Events	Page 7
Asbestos Management Program (operations and maintenance)	Pages 8 - 19
Asbestos Investigation Report (AIR)	Attachment 1 Letter Dated August 4, 2006
Training (included in the Asbestos Management Program)	<p>The original records are centralized at the School District's Environmental Library. Copies are maintained on staff and are required to be maintained in the latest Reinspection Report.</p> <p>2 hour awareness training records for all Building Engineers, Custodian Assistants and maintenance personnel</p> <p>40 hour worker/supervisor training records for the OEMS A-Team and various AST tradesmen.</p>
Response Actions (monthly mailings if applicable)	<p>The original documents are on file at the School District's Environmental Library.</p> <p>Copies of the original are mailed to the Schools Main Office for retention with the Management Plan documentation. These documents are typically kept separate from the management plan in an update binder due to the potential volume of response action reports.</p>

SCHOOL DISTRICT OF PHILADELPHIA

ASBESTOS DESIGNATED PERSON

Gerald F Junod
Office of Capital Programs
Environmental Management & Services
440 N Broad Street, 3rd Floor
Philadelphia, PA 19130
Telephone: 215 400 6738
Fax: 215 400 4751

Drexel University- Asbestos Building Inspector Course	January 9-11, 1989 24 Hours
Drexel University- Asbestos Management Planner Course	January 12-13, 1989 16 Hours
Criterion Laboratories, Inc. - Asbestos Management Planner Course	October 11-12, 2012 16 Hours

<u>Annual Building Inspector Refreshers</u>	1990 to Present
4 Hours	
Drexel University	
Criterion Laboratories, Inc	
Access Training Services, Inc.	

<u>Annual Building Management Planner Refreshers</u>	1990 to 1994
4 Hours	
Drexel University	
Criterion Laboratories, Inc	2013 to Present
4 Hours	

Environmental Manager, School District of Philadelphia

Manages the design and implementation of asbestos and lead projects for the Capital Improvement Program and other District Departments including Facilities & Operations and Information Technology. Ensures that asbestos abatement and lead remediation projects are expertly designed and executed in accordance with industry best management practice standards and regulations.

Manager, City of Philadelphia Asbestos Control Program

Served as the Asbestos Control Program Manager for the City of Philadelphia, Department of Public Health, Air Management Services, Asbestos Control Unit from August 1, 2003 through October 23, 2006.

Mid Atlantic Regional Environmental Consortium (MAREC)

Former member with attendance and participation commitments of all quarterly EPA Region III and yearly National Asbestos Regulatory Conferences sponsored by the EPA and the National Conference of State Legislators respectively as a representative for the City of Philadelphia Department of Public Health Air Management Services from 1994 through 2006.

Philadelphia Environmental Task Force

Former member of the Philadelphia Environmental Task force as a representative and point of contact for the City of Philadelphia Department of Public Health Air Management Services Asbestos Control Unit from 2002 through 2006.

Asbestos Instructor

Worked as the primary instructor for the initial and annual Asbestos Project Inspector training and licensing program as mandated by City of Philadelphia Department of Public Health Asbestos Control Regulations from August 1994 through October 2006.

Worked as a lead instructor with an Environmental Consulting Firm and approved by the US EPA for the initial and annual refresher training courses for various asbestos occupational disciplines such as the Building Inspector, Management Planner and Worker/Supervisor from 1991 through 1994.

I certify that the general, local agency responsibilities as stipulated in Section 763.84 will be met.



Gerald F. Junod
Asbestos Designated Person
Environmental Manager
Office of Environmental Management and Services

SCHOOL DISTRICT OF PHILADELPHIA

Accreditation Information Statement

All persons who inspect for Asbestos Containing Building Materials (ACBM) and who will design or carry out response actions with respect to assumed and confirmed ACBM, will be accredited by an EPA approved course and/or a State Contractors Accreditation Program under Sections 206 (c) and 206 (b) of Title II of the ACT.

A handwritten signature in black ink, appearing to read 'Gerald F. Junod', is written over the printed name and title.

**Gerald F. Junod
Asbestos Designated Person
Environmental Manager
Office of Environmental Management and Services**

SCHOOL DISTRICT OF PHILADELPHIA
OFFICE OF CAPITAL PROGRAMS
440 NORTH BROAD STREET, SUITE 373
PHILADELPHIA, PENNSYLVANIA 19130

OFFICE OF ENVIRONMENTAL MANAGEMENT AND SERVICES

PHONE (215)-400-4750

September 2015

TO: Principals
Building Administrators/Occupants
Parents/Guardians

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: Annual EPA Notification Letter

Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 C.F.R. 763.84 (c)(d) of public access to environmental records, this letter is to acknowledge the availability of your facility's Asbestos Hazard Emergency Response Act (AHERA) Management Plan.

Each member of the school staff, parents/guardians, temporary workers and/or contractors, are required to receive a copy of the Notification Letter. At the direction of the Principal, a copy is to be posted on the bulletin boards and an appropriate amount of copies are to be generated for distribution.


Note: The AHERA Three-Year Reinspection reports, in colored binders; White with Pink, Tan, Black, Red, Dark Blue, Green, Yellow and White, are Federal EPA mandated inspection documents. The School District of Philadelphia is subject to severe monetary penalties if the reports and associated paperwork are not available to the EPA and the public upon request.

It is incumbent on designated school personnel to gather and retain this data as it is delivered, in one location for future review. Acceptable locations include the Principal's Office or Main Office for the primary data. The Building Engineer should maintain any secondary or duplicate copies.

If you have any questions, please call 215-400-4750. Thank you for your cooperation.



Fran Burns
Chief Operating Officer



Francine Locke, M.S., Director
Office of Environmental Management
and Services

c: Danielle Floyd

AHERA-4
8/21/15



School District of Philadelphia
OFFICIAL NOTICE

PLEASE POST

September 2015

TO: Principals
Building Administrators
Building Engineers
Building Occupants
Parents/Guardians

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: Annual Notification Letter: Asbestos Hazard Emergency Response Act

The Federal Register published on October 30, 1987, Subpart E, in Schools: Final Rule and Notice, 763.84 (c)(d) states that each local education agency shall ensure that workers and building occupants or guardians are to be informed at least once each school year about inspections, response actions and post-response action activities including re-inspections and periodic surveillance activities. The School District as the Local Education Agency (LEA), retains such reports that are available for public inspection in the Office of the Principal or Building Administrator.

The Principal or Building Administrator is required to do the following with this notification:

- 1) Post in a Public Place or Main Office
- 2) Inform Building Occupants
- 3) Send a copy of this notification to Parents or Guardians
- 4) Insert a copy into the latest AHERA Three-Year Reinspection report (white/pink binder) in your office or facility.

Handwritten signature of Fran Burns in black ink.

Fran Burns
Chief Operating Officer

Handwritten signature of Francine Locke in black ink.

Francine Locke, M.S., Director
Office of Environmental Management
and Services

c: Danielle Floyd

AHERA-4a
8/21/15

SCHOOL DISTRICT OF PHILADELPHIA
Education Center
440 North Broad Street
Philadelphia, Pennsylvania 19130

Office of Environmental Management and Services

215-400-4750

AHERA
Six Month Surveillance
Outline of Events

- Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 CFR 763.92(b), the following procedure is to be implemented. At least once every six (6) months after a Management Plan is in effect, each Local Education Agency (LEA) shall conduct a periodic surveillance in each building that it owns or leases that contains Asbestos Containing Building Materials (ACBM) or is assumed to contain ACBM.
- The first Bi-Annual Inspection starts in the Spring (March, April, May) and again in the Fall (October, November, December) of each year. The Building Engineer/Assistant should assist the Building Inspector with appropriate access to all areas including (Crawlspaces/Attics) and rooms in the facility. There is no action required of the Principal.
- The Building Inspector shall visually inspect all areas that are identified in the Management Plan as ACBM or assumed ACBM. The date of the surveillance is recorded, the inspectors name and any changes in the conditions of the materials.
- The Building Inspector shall make a copy of the inspection document and insert into the front of the latest Management Plan (AHERA Three Year Reinspection report). The original document is returned to the LEA's Environmental Library and filed.

SCHOOL DISTRICT OF PHILADELPHIA
Education Center
440 North Broad Street
Philadelphia, Pennsylvania 19130

Office of Environmental Management and Services

215-400-4750

AHERA
Three Year Reinspection
Outline of Events

- Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 CFR 763.85(b) the following procedure is to be implemented. At least once every three (3) years after a Management Plan is in effect, each Local Education Agency (LEA) shall conduct a reinspection of each building that it owns or leases that contains Asbestos Containing Building Material's (ACBM's) or is assumed to contain ACBM.
- Subsequent Three Year Re-inspections (2009, 2012, 2015, etc) shall start in the Fall (October, November, December, January). The Building Engineer/Assistant should assist the Building Inspector with appropriate access to all areas including (Crawlspaces/Attics) and rooms in the facility. There is no action required of the Principal.
- An accredited Building Inspector shall visually inspect and touch to determine friability, all areas that are identified in the Management Plan as ACBM or assumed ACBM. The date of the surveillance is recorded, the inspectors name and any changes in the conditions of the materials. The Building Inspectors state of accreditation and license number is required.
- After the inspection, the Building Inspector shall make a copy of the inspection documents and insert into the front of the latest Management Plan (AHERA Three Year Reinspection report). The original document is returned to the LEA's Environmental Library and filed.
- The Building Inspector shall return the reinspection data to the Management Planner to be assessed and determine appropriate response actions and a report issued (AHERA Three Year Reinspection report). One copy of the report is delivered to the schools Principal to be permanently retained with all previous environmental data. Another copy is retained in the LEA's Environmental Library.



School District of Philadelphia
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, PA 19130
(215) 400-4750

**School District of Philadelphia
Asbestos Management Program**

TABLE OF CONTENTS

Definitions.....	Page 9
1. Introduction.....	Page 10
2. Summary of Asbestos Management Plan	
3. Asbestos Management Plan Execution.....	Page 11
a. General Execution	
4. Summary of Program Execution	
a. Asbestos Management Plan Execution	
5. Responsibilities	
a. OEMS	
b. Asbestos Worker/Supervisor "A-TEAM".....	Page 12
c. Asbestos Designated Person	
d. Supervisor or Project Manager (Capital, Maintenance & Facilities)	
e. Employee Capital.....	Page 13
f. Employee Maintenance	
g. Employee Facilities and Custodial	
6. Requirements.....	Page 14
a. Employee Exposure Monitoring	
b. Employee Notification	
c. Observation of Monitoring	
d. Training Program	
e. Access of Information	
f. Record Keeping	
7. AHERA O&M Plan.....	Page 15
a. Controls	
8. O&M Response Actions.....	Page 16
a. Facility Maintenance Isolation of Area	
b. Unlikely Contact with ACM/PACM	
c. Accidental Disturbance of ACM/PACM	
d. Planned Disturbance of ACM/PACM	
e. Miscellaneous ACM/PACM.....	Page 17
f. Vinyl Asbestos Floor Tile	
g. Mastic/Adhesives	
h. Woven Vibration Dampers	
i. Other Work Practices	
j. Fiber Release Episodes	
9. References and Resources.....	Page 18

DEFINITIONS / ACRONYMS

ACM/PACM:	Asbestos Containing Material/Potential Asbestos Containing Material
AHERA:	Asbestos Hazard Emergency Response Act
AIR FORM:	Asbestos Inspection Report Form
Amended Water:	Water to which a surfactant (soap) has been added
AMP:	Asbestos Management Program/Asbestos Management Plan
Asbestos Designate Person:	Individual assigned by the district to oversee asbestos related issues.
Asbestos Regulated Area:	Location that is posted as an asbestos work area in which only approved and accredited personnel are permitted to enter
AST:	Asbestos Support Team involving approved and accredited school district tradespersons personnel that are school district person
A-TEAM:	School District of Philadelphia asbestos workers
CIP:	Capital Improvement Program
Consultant:	Asbestos consulting firm hired by the District
Demolition Directive:	Memorandum – August 4, 2006 from Patrick Henwood
EPA:	Environmental Protection Agency
In House Personnel:	School District of Philadelphia asbestos workers
LEA:	Local Education Agency
O&M:	Operations and Maintenance
OEMS:	Office of Environmental Management and Services
OSHA:	Occupational Safety and Health Administration
PEL:	Permissible Exposure Limit
PSD or SDP:	Philadelphia School District/School District of Philadelphia
PSIT:	Philadelphia School Improvement Team
STEL:	Short Term Exposure Limit

1. Introduction

The School District of Philadelphia, Asbestos Policy Statement:

“The School District of Philadelphia is dedicated to providing a safe and healthful work environment for its employees, students, faculty, contractors and visitors. In recognition of the potential health problems associated with asbestos, the School District of Philadelphia is committed to a comprehensive asbestos control program. This program is implemented and maintained through the School District of Philadelphia's Office of Environmental Management and Services (OEMS).”

OEMS has the responsibility of establishing procedures for asbestos abatement, asbestos inspection, air monitoring, renovation and demolition activities within all School District of Philadelphia owned or leased facilities.

These procedures are developed to ensure that:

- (1) People are not exposed to significant levels of asbestos fibers
- (2) Asbestos waste is handled and disposed of properly
- (3) Members of the School District of Philadelphia community have access to the Office of Environmental Management and Services for information, assistance, guidance, and interpretation regarding asbestos related matters.
- (4) Members of the School District of Philadelphia community have access to the Asbestos Management Plans as required and outlined in the US EPA AHERA regulations including annual written notification to all parents.
- (5) Compliance with all applicable Federal, State and Local Asbestos Regulations

Requirements outlined in this manual are mandatory in nature where the word “SHALL” is used and are advisory in nature where the word “SHOULD” is used.

2. Summary of Asbestos Management Program

The School District of Philadelphia's Asbestos Management Program was established to meet the requirements of Federal, State, and Local Regulations.

These regulations include, but are not limited to:

- US Environmental Protection Agency Asbestos Hazard Emergency Response Act (US EPA AHERA) and National Emissions Standard for Hazardous Air Pollutants subpart M, Part 61 (NESHAP);
- US Department of Labor, Occupational Safety and Health Administration (OSHA) General Industry Standard (29 CFR 1910.1001) and the OSHA Asbestos Standard for the Construction Industry (29 CFR 1926.1101);
- The Commonwealth of Pennsylvania, Department of Labor and Industry, Asbestos Occupations, Accreditation and Certification Act;
- The City of Philadelphia, Department of Public Health, Asbestos Control Regulations.

3. Asbestos Management Program Execution

a) General Execution

The Office of Environmental Management and Services (OEMS) develops, implements and manages safety and health programs for the School District of Philadelphia faculty, staff and students and assists with ensuring that all contractors comply with Federal, State and Local Environmental Regulations. The OEMS provides the oversight of School District of Philadelphia employees (Asbestos A-Team), environmental consultants, and asbestos abatement contractors for all projects within the School District of Philadelphia concerning Asbestos Containing Materials.

The control of safety and health hazards at the School District of Philadelphia is primarily through the implementation of engineering, work practice and administrative controls. Personal Protective Equipment (PPE) is used to supplement these controls or whenever the controls are not feasible or are in the process of being implemented. PPE is also recommended whenever exposures to chemical, physical or biological agents can be prevented or reduced by its use.

This written program establishes the procedures necessary to:

- 1) meet established standards and federal regulations for occupational exposure to asbestos fibers;
- 2) meet the requirements of the City of Philadelphia Asbestos Control Regulations which encompasses the disturbance and/or abatement of asbestos containing building materials;
- 3) provide the necessary health and safety protection to the School District of Philadelphia staff, faculty, students, contractors and visitors.

This program is strengthened by input and cooperation with the Philadelphia Federation of Teachers (PFT), Health and Welfare Fund.

4. Summary of Program Execution

a) Asbestos Management Program Execution

The Asbestos Management Program is administered by the Office of Environmental Management and Services (OEMS). OEMS provides the following services primarily through professional consultants:

- (1) exposure monitoring services;
- (2) building inspection/surveys (bulk sampling) for the identification of asbestos containing materials;
- (3) asbestos project design services;
- (4) asbestos abatement project and air monitoring services;
- (5) emergency response to fiber release episodes;
- (6) education/information;
- (7) medical monitoring;
- (8) training for School District of Philadelphia personnel

5. Responsibilities

a) Office of Environmental Management and Services

OEMS is responsible for performing the following functions:

- (1) Developing and administering of the Asbestos Management Program.
- (2) Providing asbestos-related services to all School District of Philadelphia departments.
- (3) Conducting required training of the Asbestos Management Program and working jointly with departments to schedule training.
- (4) Identifying and posting areas where labeling/signage are required.
- (5) Medical Monitoring of OEMS "A-TEAM" and other departments "AST" Asbestos Program staff.

- (6) Certification and training as required for OEMS “A-TEAM” and other departments “AST” Asbestos program staff.
- (7) Record keeping as outlined in Section 3.5 and all records as by required by US EPA AHERA regulations.

b) Asbestos Worker/Supervisor - “A-TEAM”

- (1) OEMS shall ensure that all “A-TEAM” workers/supervisors adhere to the following requirements:
 - a) Attend an initial Worker/Supervisor Asbestos Course;
 - b) Maintain the annual re-certification per EPA AHERA requirements and Commonwealth of Pennsylvania Asbestos Occupations, Accreditation and Certifications Act;
 - c) Undergo an annual Asbestos Medical Evaluation;
 - d) Undergo an annual Respirator Medical Clearance;
 - e) Undergo an annual Respirator Fit Testing.

c) Asbestos Designated Person

The Asbestos Designated Person is responsible for:

- (1) Assuring the health and safety of employees, students and visitors in the School District of Philadelphia facilities under his/her control.
- (2) Being kept informed of all areas under his or her jurisdiction where potential asbestos exposures exist and initiating protection programs that adhere to the Asbestos Management Program requirements of this manual.
- (3) Assuring that Asbestos Management Program requirements are adhered to by principal investigators, project managers, supervisors, or division heads, and School District of Philadelphia personnel under their supervision.
- (4) Ensuring that all employees within the Asbestos Management Program comply with (OSHA 1910.1001 (j) (7) (iv)) and the US EPA AHERA regulations by attending the required training.
- (5) Ensure the posting of:
 - a) Warning labels/signage
 - b) Commonwealth of Pennsylvania Asbestos Abatement and Demolition/Renovation Notification form
 - c) Asbestos Inspection Reports (AIR) form (where required)
 - d) Ensuring that Construction Projects follow the Demolition Directive procedures as outlined in the August 4, 2006 letter.

d) Supervisor or Project Manager (Capital, Maintenance and Facilities)

Each person in charge of a project, maintenance/repair, renovation/demolition, or other activity from the Departments of Capital, Maintenance, and/or Facilities, where asbestos containing material may be present is responsible for:

Identifying, with the assistance of OEMS, asbestos containing building materials prior to any disturbance of these materials. Various Federal (EPA and OSHA) and Local (City of Philadelphia Asbestos Control Regulations) require Asbestos Inspections prior to renovation/demolition activities. This shall be accomplished by always following the Asbestos Management Program Procedures as follows:

- (1) Ensure that the requirements of the Asbestos Management Program Procedures are followed by all personnel, trades, and contractors who are involved with the project;

- (2) Review of the required Asbestos Inspection Report (AIR) form (Attachment 1) and AHERA Management Plan documents prior to activities that may disturb any Asbestos Containing Materials;
- (3) Perform all project related duties as outlined in the Project Management Responsibilities;
- (4) Keep the department chairperson or director informed on any actions proposed or taken regarding the Asbestos Management Plan;
- (5) Ensuring that Construction Projects follow the Demolition Directive procedure outlined in the August 4, 2006 letter.

e) Employee – Capital

School District of Philadelphia Capital employees and/or consultants shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of the projects they are performing or managing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work order permit (a.k.a PSIT Service Request Form) and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed.
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode upon discovery of visible damage to asbestos containing materials.
- (3) Ensuring that Construction Projects follow the Demolition Directive procedures as outlined in the August 4, 2006 letter.

The types of projects represented as part of the Capital Improvement Program are as follows:

- (1) Complete Renovation of an existing building that addresses all facility component concerns and educational program needs;
- (2) Major Renovation of an existing building addressing significant facility component and educational improvements;
- (3) Addition to an existing building (either as an attachment or stand-alone structure) to accommodate needed program space;
- (4) Conversion of an existing facility to accommodate a change in educational program;
- (5) Facility Component Improvement of specific facility needs (i.e. electrical or HVAC system upgrades, ADA improvements, life safety improvements, exterior renovations, etc.)

f) Employee – Maintenance

School District of Philadelphia Maintenance employees shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of their duties or work they are performing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work order permit and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed.
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode or upon discovery of visible damage to asbestos containing materials.
- (3) All employees involved in maintenance activities shall attend required Asbestos Awareness training program within 60 days of employment.

g) Employee – Facilities & Custodial

School District of Philadelphia Facilities and Custodial employees shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of their duties or work they are performing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work permit and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed;
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode or upon discovery of visible damage to asbestos containing materials.
- (3) All employees involved in Facilities and Custodial activities shall attend require Asbestos Awareness training program within 60 days of employment.

6. Requirements

a) Employee Exposure Monitoring

When information indicates that an employee's exposure to asbestos fibers may equal or exceed an 8-hour time-weighted average of 0.1 f/cc * (per OSHA 1910.1001 & 1926.1101), OEMS shall develop and implement an asbestos exposure monitoring program. The sampling strategy shall be designed to identify employees by work task (job classification) that is exposed to asbestos fibers that exceed an 8-hour time-weighted average of 0.1 f/cc.

b) Employee Notification

OEMS shall notify in writing, each employee exposed to asbestos fibers at or above an 8-hour time weighted average of 0.1 f/cc.

c) Observation and Monitoring

OEMS shall provide employees or their representatives with an opportunity to observe any exposure measurements conducted.

d) Training Program

OEMS shall institute a training program which meets the requirements of AHERA for all employees who perform maintenance operations in a facility/school which contains asbestos containing materials or presumed asbestos containing materials and 1910.1001 (j), and the Commonwealth of Pennsylvania Department of Labor and Industry and the City of Philadelphia Asbestos Control Regulations. The affected departments shall ensure employee participation in this program. The OEMS "A-TEAM" and other departments "AST" Asbestos Program staff training shall be conducted annually for each employee as required by all Federal, State and Local for each asbestos discipline.

All Asbestos Awareness training as required by AHERA shall be performed within 60 days of employment and shall include:

- Health effects of asbestos
- Locations of ACM and PACM in the building/facility
- Recognition of CM and PACM damage and deterioration
- Requirements of the OSHA 1910.1001 standard relating to maintenance
- Proper response to fiber release episodes
- Procedure to be followed to isolate areas affected by fiber release

e) Access to Information

OEMS shall make available to affected employees or their representative's copies of the Occupational Safety and Health Administration (OSHA) General Industry Standard Part 1910.1001 and the department shall post a copy in the workplace.

f) Record Keeping

OEMS shall maintain an accurate record of all employee exposure measurements. OEMS and/or the School District of Philadelphia Human Resources Department shall maintain records of employee medical monitoring program. OEMS shall maintain all employee training records. All records shall be provided upon request to employees, former employees, representatives designated by the individual employee.

7. AHERA OPERATIONS AND MAINTENANCE PLAN

a) CONTROLS

i. Work Order System

Minimizing disruption of ACM/PACM during maintenance and renovation activities is the primary goal and task encountered by OEMS. Operations and maintenance employees and contractors should be warned to avoid conducting any maintenance work which may disturb ACM/PACM. Initiating a work order system, where all work orders or requests are channeled through the Office of Environmental Management and Services (OEMS), will be the method used to control and minimize disruption of ACM/PACM.

Any work performed by in-house personnel or contractors that could or will impact ACM/PACM shall be coordinated by OEMS. A completed Asbestos Inspection Report Form (Attachment 1) shall be issued to in-house personnel and/or all contractors whose work could impact ACM/PACM. This form should accompany each contract issued to an outside contractor and posted on the jobsite.

All work order requests for maintenance and renovation activities in areas where ACM/PACM is suspected or known to be present are to be submitted to OEMS prior to proceeding with work. OEMS is responsible for reviewing asbestos survey records for information about the presence of ACM/PACM in the area where the work is to be performed. OEMS should physically inspect the area to ensure existing records reflect actual conditions. If no asbestos is present, a work order is not necessary and the planned actions can proceed. If ACM/PACM is found to be present in the area, OEMS will sign the work order application and obtain an approved and accredited asbestos contractor or assign OEMS "A-TEAM" to abate the ACM/PACM.

ii. Regulated Areas

The owner will identify and regulate all areas where airborne concentrations of ACM/PACM exceed the Permissible Exposure Limit (PEL)* (Per OSHA determined to be 0.1 f/cc) and/or short term exposure limit (STEL) (Per OSHA determined to be 0.1 f/cc), or there is reasonable possibility that the (PEL) and/or (STEL) may be exceeded. All ACM/PACM removal activities involving thermal system insulation ACM/PACM (Class I), surfacing ACM/PACM (Class I), and miscellaneous ACM/PACM such as floor tile, roofing, and siding mastic, etc. (Class II), and repair and maintenance operations where thermal system insulation and surfacing ACM/PACM is likely to be disturbed (Class III) will be performed in accordance with federal, state, and local regulations. All asbestos abatement work and activities will be designed and managed as asbestos regulated areas. These areas will be demarcated and labeled.

iii. Warning Signs

Warning signs shall be displayed at all approaches to each asbestos regulated area. The asbestos abatement contractor will provide OSHA warning signs in all regulated areas during removal, repair, and other maintenance activities. OEMS will provide AIRs to all contractors who must inform all employees and supervisors working in locations contiguous to asbestos regulated areas of the potential hazards and work practices required.

iv. Warning Labels

Warning labels and/or signage shall be affixed to all raw materials, mixtures, scrap, waste, debris, and other products containing asbestos fibers, or to their containers. Generally, the asbestos abatement contractor or OEMS A-Team personnel will provide all warning labels for ACM/PACM containment.

8. O & M RESPONSE ACTIONS

The Asbestos Management Program general O&M procedures are outlined in this section. Additional requirements specific to asbestos abatement activities are included in the Project Design documents for all Asbestos Abatement Work. Regular cleaning, inspection, and reporting of ACM/PACM deterioration or other problems must be diligently practiced by all employees including custodial and maintenance personnel.

a) Facility Maintenance Isolation of Area Responsibilities

Maintenance personnel are often required to work in areas where ACM/PACM may potentially be disturbed. Most maintenance activities are conducted by in-house staff, outside contractors, or a combination.

Emergency fiber release episodes, such as pipe fitting or valve breaks, emergency boiler work, or mechanical equipment repair will be responded to by OEMS A-Team personnel or asbestos abatement contractor personnel. The owner's maintenance staff will: (1) isolate the emergency fiber release area; (2) post warning signs to prevent unauthorized access, and (3) notify their supervisor and OEMS. OEMS will ensure that the fiber release area remains isolated and is properly cleaned by and approved and accredited abatement contractor or by OEMS A-TEAM personnel.

b) Unlikely Contact with ACM/PACM

Maintenance activities or repairs which can be performed without contacting or disturbing the ACM/PACM require little more than normal care and good workmanship. For example, valves which are either uncovered or covered with non-asbestos insulation can be packed or repaired without disturbing asbestos insulation on nearby pipes. The major precaution is to ensure that maintenance and custodial personnel are familiar with procedures such as isolating the area, posting warning signs, and notifying OEMS in the event of any accidental ACM/PACM disturbance.

c) Accidental Disturbance of ACM/PACM

Maintenance and facilities personnel shall notify OEMS any time a fiber release is suspected. If friable ACM/PACM becomes airborne in the building,

d) Planned Disturbance of ACM/PACM

Maintenance activities that may impact ACM/PACM include access to a valve, flange, duct, or related system component.

Where asbestos-containing insulation must be removed to maintain or repair the thermal system, the ACM/PACM will imminently be disturbed. ACM/PACM removal work shall be conducted by OEMS A-Team personnel or an approved and accredited asbestos abatement contractor.

If friable ACM/PACM becomes airborne in the building, maintenance and facilities personnel shall secure the area and contact OEMS. OEMS shall respond accordingly.

e) Miscellaneous ACM/PACM

Miscellaneous types of ACM/PACM may include vinyl asbestos floor tiles, mastics/adhesives and woven vibration dampers. Disturbance of these materials should be avoided. Routine maintenance activities involving these materials should not pose a problem if handled properly. Questions on the proper removal and disposal of miscellaneous ACM/PACM should be directed to OEMS. OEMS will contact an approved and accredited asbestos abatement contractor or utilize OEMS A-TEAM personnel to assist with miscellaneous ACM/PACM clean-up activities.

f) Vinyl Asbestos Floor Tile

Asbestos-containing floor tiles in good condition are considered non-friable unless they are crushed, drilled, sawed, sanded or disturbed by any activity that breaks up the material. Routine maintenance of these materials should employ the use of non-abrasive buffers and wet cleaning technique. Broken or loose floor tiles should be removed and disposed of as asbestos waste by OEMS. Remaining debris should be vacuumed with a HEPA vacuum and the area wet mopped using amended water.

g) Mastics/Adhesives

Mastics and adhesives containing asbestos in good condition are considered non-friable and do not pose a potential health concern unless crushed, drilled, sawed, sanded, or otherwise abraded. Questions on the proper removal should be directed to OEMS.

h) Woven Vibration Dampers

Woven vibration dampers in good condition are considered non-friable and do not pose a potential health concern unless cut, crushed, drilled, sawed, sanded, or otherwise abraded. Questions on the proper removal should be directed to OEMS.

i) Other Work Practices

Any special work not included in this section should be addressed to OEMS for review prior to the initiation of work that may involve the disturbance of ACM/PACM.

j) Fiber Release Episodes

Facilities and maintenance staff should report to OEMS the presence of asbestos debris, water or physical damage to ACM/PACM, or any other evidence of possible fiber release. OEMS should have the OEMS A-Team personnel or an approved and accredited abatement contractor respond to the site to clean up debris and make repairs as soon as possible. OEMS will also contact a consultant to conduct air monitoring and prepare a report and submit at project completion to OEMS for each episode. OEMS will forward the reports for each site location AHERA Management Plan accordingly.

9. REFERENCES and RESOURCES

Applicable regulations for asbestos projects impacted by renovation, demolition, and maintenance activities.

- **Philadelphia Air Management Services – Asbestos Control Unit**
<http://www.phila.gov/health/units/ams/Asbestos/asbestos.html>
- **Pennsylvania Asbestos Occupations, Accreditation and Certification Act**
<http://www.dli.state.pa.us/landi/cwp/view.asp?a=185&q=56262&landiNav=>
- **United States Environmental Protection Agency Asbestos Home Page**
<http://www.epa.gov/asbestos/>
- **Occupational Safety and Health Administration (OSHA) Asbestos Home**
<http://www.osha.gov/SLTC/asbestos>