

SCHOOL DISTRICT OF PHILADELPHIA



Asbestos Hazard Emergency Response Act “AHERA”

THREE-YEAR RE-INSPECTION 2015-2016 and ASBESTOS MANAGEMENT PLAN for the

George Washington High School

**ULCS# 8030
Building # B803001-1
10175 Bustleton Avenue
Philadelphia, Pennsylvania
19116**

Year Built: 1963

February 2016

Conducted by:

Accredited Environmental Technologies, Incorporated
Batta Environmental Associates, Incorporated
Criterion Laboratories, Incorporated
Environmental Testing Consultants, LLC
G & C Environmental Services, Incorporated
KEM Partners, Incorporated
Synertech, Inc.
TTI Environmental, Inc.
USA Environmental Management, Inc.
The Vertex Companies, Inc.

Management Plan Prepared by:
Criterion Labs, Inc. and Synertech Inc.

This report must remain in the Main Office as mandated by the US EPA AHERA Regulations.

AHERA THREE-YEAR REINSPECTION VOLUME IX

Table of Contents

Transmittal Letter

Executive Summary

- I. Summary list of Confirmed Asbestos Containing Building Materials
- II. Summary list of Assumed Asbestos Contain Building Materials
- III. Summary list of Non-Asbestos Containing Building Materials
- IV. Summary list of Non Suspect Asbestos Containing Building Materials
- V. Summary List of Auditorium DATA for this location
- VI. Summary list of Attic and/or Crawlspace DATA for this location
- VII. Summary list of Pipe Chase/Pipe Shaft DATA for this location

Section I Report of Re-Inspection

- A. Introduction
- B. Three-Year Re-inspection IX Overview
- C. Post- Management Plan Activities and Changes
 - C.1 - Sampling and Analysis
 - C.2 - New Floor Tile Sampling
 - C.3 - Abatement Activity
 - C.4 - Periodic (Six-Month) Surveillance (Damaged Materials)

Section II Re-Inspection Data

- A. Introduction
- B. Re-Inspection Key Definitions
- C. Room by Room Location Log Report

Section III Certificates

- A. Management Planner/Building Inspector Certificates

Section IV	Cross Reference Table	Page 1-8
	Asbestos Management Program	Page 9-19

SCHOOL DISTRICT OF PHILADELPHIA
EDUCATIONAL CENTER
440 NORTH BROAD STREET
PHILADELPHIA, PENNSYLVANIA 19130

OFFICE OF ENVIRONMENTAL MANAGEMENT AND SERVICES

PHONE (215)-400-4750

January 2016

TO: All Principals
All Building Administrators

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: AHERA Three (3) Year Re-inspection IX report

In order to comply with the provisions of the Asbestos Hazard Emergency Response Act (AHERA) the attached report is submitted to you. The law requires that this report be kept in the Main/Principal's office. It cannot be removed from these locations. *If the school (program) is relocated to a different building, these environmental documents are to be safely retained for the next school/building occupants.* All asbestos reports must be available to the public and Federal EPA upon request.



Fran Burns
Chief Operation Officer

Francine Locke, M.S., Director
Office of Environmental Management
and Services

Executive Summary

This Asbestos Hazard Emergency Response Act (AHERA) Three-Year Re-inspection “Volume # IX” Management Plan at this location, has been completed and the report of re-inspection submitted to the School District of Philadelphia. The re-inspections in all School District of Philadelphia buildings of 2015-2016 were conducted and completed between October 5th, 2015 through March 30th, 2016 as a joint project by Accredited Environmental Technologies, Inc., Batta Environmental Associates, Inc., Criterion Laboratories, Inc., Environmental Testing Consultants, LLC, G & C Environmental Services, Inc., KEM Partners, Inc., Synertech, Inc., TTI Environmental, Inc., USA Environmental Management, Inc. and The Vertex Companies, Inc.

In general, the School District of Philadelphia Office of Environmental Management and Services conducts Environmental Impact Evaluations and provides Asbestos Inspection Reports prior to any renovation, demolition and/or maintenance activities. The AHERA report must be reviewed prior to any renovation, demolition and/or maintenance activities in order to avoid the unknowing disturbance to Asbestos Containing Building Materials identified within this location. In addition, prior to work activities above all drop ceilings this report should be reviewed to avoid potential disturbances to Asbestos Containing Materials. Refer to Section IV of the Cross Reference Table, for additional Asbestos Management Program information. Contact the Office of Environmental Management and Services to have an Environmental Impact Evaluation conducted prior to any renovation, demolition and/or maintenance activities within this facility.

The information contained in this report was obtained from the original Asbestos Management Plan for the school, from update reports on changes and activities since the completion of the 1st Management Plan for each location and from all prior inspections performed and documented in Volume # I through Volume VIII (dated respectively 1992, 1995, 1998, 2001, 2004, 2007, 2010 or 2013) (if applicable) - and by this Three-Year Re-inspection of this school. The re-inspection report/Management Plan of 2015-2016 were reviewed and prepared collectively by Management Planner Megan Vala, Mary Anne Lerro of Criterion Laboratories, Inc. and/or Monique Causley, of Synertech Inc.

The 2015-2016 inspection process included the addition of a comprehensive Room by Room Inventory of all Thermal (T), Surfacing (S) and Miscellaneous (M) Materials specific to each room of this facility. Inspections of each room's thermal, ceilings, walls, floors and miscellaneous items regardless of Asbestos Content are categorized on the Room by Room Location Log Report for this location. Rooms or areas of the facility that were not accessible at the time of the inspection are marked with an "X". The Room by Room Location Log Report is found in Section II C of this Management Plan.

All Presumed or Suspect Asbestos Containing Building Materials (ACBMs), listed in the following summary charts are categorized as Confirmed, Assumed, Non-Asbestos, and/or Non-Suspect (ACBMs) were identified in the original Management Plan, or in the Volume I through Volume VIII AHERA Three-Year Re-inspection reports, and were re-inspected as part of this project.

As mandated by the U S EPA AHERA regulations, periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Please feel free to contact the School District of Philadelphia's Office of Environmental Management and Services (OEMS) regarding any comments, questions, or concerns regarding this report or any Environmental related topic. OEMS staff can be reached at (215) 400 4750, via fax at (215) 400 4751 or via e-mail at flocke@philasd.org and/or gfunod@philasd.org.

Additional information can be found on our website. Here is the link to the OEMS website.
<http://webgui.phila.k12.pa.us/offices/e/environmental>

I. Summary list of Confirmed Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. *These materials have been sampled and Laboratory Analysis has CONFIRMED the presence of Asbestos. Contact OEMS prior to the disturbance of any of the following materials.*

Confirmed Asbestos Containing Building Materials for this location

Pipe Fitting Insulation
Floor Tile VAT 9" x 9"

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

II. Summary list of Assumed Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. These materials have not been sampled and should not be disturbed until verification of Asbestos Content. Contact OEMS for assessment and sampling prior to the disturbance of these materials.

Assumed Asbestos Containing Building Materials for this location

Black Glue Dots A/W Mirror	Floor Tile VAT 18" x 18"	Transite Sills
Blackboard Glue Dots	Radiator Insulation	Transite Sink
Floor Tile VAT 12" x 12"	Transite Electrical Panel	Vibration Damper Cloth

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

III. Summary list of Non-Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. *These materials have been sampled and Laboratory Analysis has indicated NO Asbestos present or NO ASBESTOS DETECTED (NAD).*

Non- Asbestos Containing Building Materials for this location

Acoustical Plaster Walls	Pipe Fitting Insulation
Ceiling Tile 1' x 1'	Plaster Ceiling

* *Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

** *Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

IV. Summary list of Non-Suspect Asbestos Containing Building Materials within this facility

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location. These materials are not typically known to contain Asbestos.

Non-Suspect Asbestos Containing Building Materials for this location

Brick Wall	Concrete Ceiling	Metal Deck
Carpet	Concrete Floor	Partition Room Dividers
Ceiling Tile 2' x 4'	Fiberglass Ceiling Tile 2' x 4'	Sheetrock Wall
Ceramic Tile Walls	Fiberglass Pipe Fitting Insulation	Terrazzo Floor
CMU	Fiberglass Pipe Insulation	Wood Floor
Concrete Block Wall	Metal Ceiling Panels	

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

V. Summary list of Auditorium DATA for this location

These charts are to be used for a quick reference of the Auditorium DATA within this facility. Sampling of the Auditorium Ceilings throughout the District is more difficult because of the various ceiling heights. As sampling occurs this information is updated on a case by case basis for each specific location and facility.

This is a list of known materials for this location's Auditorium

Auditorium		
Auditorium	Floor Tile VAT 12" x 12"	Assumed
Auditorium	Plaster Ceiling	NAD
Auditorium	Concrete Block Wall	Non Suspect ACM
Auditorium	Acoustical Plaster Walls	NAD

** Always refer to the Room by Room Logs for each specific material classification as the material classification findings may be different in various rooms throughout this facility.*

*** Some Materials may have multiple classifications (Confirmed, Assumed, NAD and Non Suspect) within this facility.*

VI. Summary list of Attic and/or Crawlspace DATA for this location

These charts are to be used for a quick reference regarding the Attics and/or Crawlspaces inspection DATA within this facility. Contact OEMS prior to entering any attic or crawlspace within this facility and refer to the below chart and legend for Category Rank determination. The Data relative to these spaces is updated as conditions change regarding Abatement or Renovation activity on a case by case basis for each specific location and facility. In general, Crawlspaces are below the basement or 1st floor and Attics are above the floor space.

Category Rank Legend

"A" - No Asbestos Containing Materials - Sample Results indicate NO ACM on pipes, fittings, elbows, or equipment located within this functional space, and NO VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"B" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space, HOWEVER, NO VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"C" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space, and LOCALIZED VISIBLE DEBRIS or DAMAGE observed at time of this inspection.
"D" - Asbestos Containing Materials Exist - Sample Results indicate ACM on pipes, fittings, elbows, or equipment located within this functional space and DISTRIBUTED VISIBLE DEBRIS or SIGNIFICANT DAMAGE observed at time of this inspection.
"E" - No Bulk Sample Results Available SUSPECT ACM OBSERVED. Contact OEMS immediately for additional instructions.

Attic/Crawlspace	Access Area	Floor Surface	Category Rank	Comments
Crawl Space	Crawl Space C	Dirt	D	Access Restricted Crawlspace Sealed
Crawl Space	Crawl Space A	Dirt	D	Access Restricted Crawlspace Sealed
Attic	Closet/Rear of Gym	Wire Lathe	A	

VII. Summary list of Pipe Chase/Pipe Shaft DATA for this location

These charts are to be used for a quick reference regarding the information known about the Pipe Chases and/or Pipe Shafts inspection DATA within this facility. Contact OEMS prior to performing renovation activities any Pipe Chase and/or Pipe Shaft within this facility and refer to the below chart and legend for Asbestos Content of various materials identified within each space. The Data relative to these spaces is updated as conditions change regarding Inspection, Abatement and/or Renovation activity on a case by case basis for each specific location and facility. In general, Pipe Chases are horizontal spaces and Pipe Shafts are vertical spaces.

Pipe Chases and Pipe Shafts need to be assessed.

Section I

Report of Re-Inspection

A. Introduction

B. Three-Year Re-Inspection IX Overview

C. Post-Management Plan Activities and Changes

C.1 Sampling and Analysis

C.2 New Floor Tile Sampling

C.3 Abatement Activity

C.4 Periodic Six-Month Surveillance (Damaged Materials)

Section I - A

Report of Re-inspection

Introduction

The Three-Year Re-inspection IX was performed to fulfill the requirements of 40 CFR Part 763 - the Asbestos Hazard Emergency Response Act (AHERA). As required by AHERA, each Local Education Agency (LEA) must re-inspect all known confirmed or assumed Asbestos Containing Building Material (ACBM) located in the LEA's facilities. This re-inspection is intended to update the original Asbestos Management Plan for the LEA's facilities.

Multiple Building Inspectors of several firms performed the 2015/2016 re-inspection. The re-inspection report/Management Plan of 2015-2016 were reviewed and prepared collectively by Management Planner Megan Vala, Mary Anne Lerro of Criterion Laboratories, Inc. and Monique Causley, of Synertech Inc.

All of the certificates can be found in Section III.

During the re-inspection of each School District of Philadelphia facility, all of the Management Plans for that facility were reviewed. Information from the conclusions section of that report is included in this report. Additionally, information on activities such as abatements, cleanings, sampling and inspections, which have taken place since the completion of the original Management Plan, were reviewed during the re-inspection. Information on those activities is included in this report.

As mandated by the U S EPA AHERA regulations, all future periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Section I - B

Three-Year Re-inspection IX Overview

Each homogeneous area of Asbestos Containing Building Material (ACBM) listed in the original Management Plan or in the 1992, 1995, 1998, 2001, etc., Three-Year Re-inspection reports were inspected for the AHERA Three-Year Re-inspection Volume IX, and the information for that material verified. Any changes to a homogeneous area listed in the updates to the Management Plans were verified. Any area of suspected ACBM found in the course of the re-inspection, and not listed in the Management Plan or updates, were either assumed to contain asbestos or sampled and analyzed to determine their asbestos content. Any such new areas either assumed to contain asbestos or determined through analysis to contain asbestos were included in the report of the Three-Year Re-inspection. The results of the AHERA Three-Year Re-inspection IX are tabulated in the Room by Room log reports located in *Section II-C* of this report.

As previously noted, all future periodic Six-Month inspections and Three-Year Re-inspections of this location will be performed and the Inspection Data in this report will be updated accordingly.

Section I – C.1

Post Management Plan Activities/Changes

Information on activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following: *Sampling and Analysis, New Tile Installation, Abatement Activity and Periodic Six-Month Surveillance Data.*

Sampling and Analysis

In the event Sampling occurs, data will be listed here.

Section I – C.2

Information on the installation of new floor tiles/renovation activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following:

New Floor Tile Sampling

In the event that new tile is installed, the material must be tested prior to installation.

Section I – C.3

Information on the Asbestos Abatement and renovation activities affecting Asbestos Containing Building Materials (ACBMs) at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Updates to the Management Plan include the following:

Abatement Activity

<i>Date</i>	<i>Floor</i>	<i>Location</i>	<i>Material</i>	<i>Color</i>	<i>Removed or Encapsulated</i>	<i>Quantity</i>
10/22/2015	1st	Classroom 13	Classroom	Brown	Removed	1198 SF
10/26/2015	3rd	Classroom 315	Classroom	Brown	Removed	16 SF
10/26/2015	3rd	Classroom 327	Classroom	Brown	Removed	20 SF
10/26/2015	1st	Classroom 100	Classroom	Black	Removed	5 SF
9/23/2016	1st	Classroom11A	Floor Tile 9" x 9"	Brown	Removed	500 SF
9/23/2016	1st	Classroom11A	Pipe Fitting Insulation	N/A	Enclosed	14 LF
9/27/2016	2nd	Classrooms 200	Floor Tile 9" x 9"	Green	Removed	20 SF
9/27/2016	2nd	Classrooms 204	Floor Tile 9" x 9"	Green	Removed	10 SF

Section I – C.4

Information on the AHERA inspection that noted damage to various Building Materials at this location is contained in updates to the Management Plan. These updates are kept on file by the School District of Philadelphia and were reviewed for this project. Work orders are created for Corrective Action responses and tracked for completion. Updates to the Management Plan include the following:

Periodic (Six-Month) Surveillance (Damaged Materials)

<i>Date</i>	<i>Element</i>	<i>Floor</i>	<i>On Site Room Name</i>	<i>Material</i>	<i>Amount of Material</i>	<i>Amount of Damage</i>
11/17/2016	1	3B	Classroom 316	Floor Tile VAT 9" x 9"	384 SF	12 SF
11/17/2016	1	3B	Classroom 329	Floor Tile VAT 9" x 9"	768 SF	10 SF
11/17/2016	1	3B	Vice Principal Office	Floor Tile VAT 9" x 9"	300 SF	2 SF
11/17/2016	1	2B	Classroom 228	Floor Tile VAT 9" x 9"	768 SF	20 SF
11/17/2016	1	1B	Main Office	Floor Tile VAT 12" x 12"	2400 SF	6 SF
11/17/2016	1	GDB	Generator Room	Pipe Fitting Insulation	2 EA	2 EA
11/17/2016	1	GDB	Service Closet	Pipe Fitting Insulation	10 EA	1 EA
11/17/2016	1	GDC	Classroom 22	Floor Tile VAT 9" x 9"	768 SF	10 SF
11/17/2016	1	1D	Weight Room 158	Black Glue Dots A/W Mirror	50 SF	20 SF
11/17/2016	1	GDD	Classroom 18	Floor Tile VAT 9" x 9"	1300 SF	10 SF
11/17/2016	1	GDD	Cafeteria Kitchen	Pipe Fitting Insulation	32 EA	3 EA
11/17/2016	1	GDD	Kitchen Office	Floor Tile VAT 9" x 9"	85 SF	5 SF
11/17/2016	1	GDD	Student Restroom #1	Floor Tile VAT 12" x 12"	35 SF	10 SF
11/17/2016	1	GDD	Locker Room Across from REC Room	Pipe Fitting Insulation	37 EA	1 EA

Section II

Re-Inspection Data

A. Introduction

B. Re-Inspection Key Definitions

C. Room by Room Location Log Report

Section II - A

Re-inspection Data

Introduction

The following information documents the Three-Year Re-inspection IX of the subject school/facility. The Homogeneous Area Reports were produced using the building inspector's field data on the facility. The key to the Homogeneous Area Report is outlined in the following pages of this report.

Section II - B
(page 1 of 4)

SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE YEAR RE-INSPECTION IX

ITEM	DEFINITION
ULCS#	Individual identification number assigned to each school within the School District of Philadelphia.
HOMOGENEOUS AREA ID#	Identification number assigned to each homogeneous area in a school/facility. Each section of the homogeneous area ID is significant. 1010/01/01/01 A B C D A. Is the ULCS# for the school. B. Designates the specific building/building area within the school. C. Designates the floor or level within the building/building area. D. Designates the homogeneous material within that floor or level. Note: Item D may be a number or a letter.
SYSTEM AFFECTED	Corresponds to the AHERA system for classifying materials. T : Thermal System S : Surfacing System M : Miscellaneous
ITEM AFFECTED	Is a description of the homogeneous material.
ORIGINAL INSPECTION DATA	This section contains the information found in the original Management Plan (1988-1989).
AMOUNT OF MATERIAL/ UNIT	Quantity of material, and measuring unit. Units include: Square Feet (SF) Each (EA) Linear Feet (LF) Cubic Feet (CF).

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

ITEM	DEFINITION
CND Condition	Corresponds to AHERA condition rating for materials. 0 : No Damage 1 : Damage 2 : Significant Damage
DP Damage Potential	Corresponds to the AHERA material assessment system. 1 : Potential for Damage 2 : Potential for Significant Damage
ASMD Assumed Asbestos	This means that a material was not sampled for asbestos content during the original Management Plan inspection.
RA Response Action	This corresponds to the AHERA system of response action rating for materials. 1 : Establish O&M Program 2 : Repair and Establish O&M Program 3 : Enclose 4 : Encapsulate 5 : Remove 6 : Partial Removal and Establish O&M Program
CHANGES	This section describes changes to the homogeneous material in the twenty-four years since the original AHERA inspection. The abbreviations are defined below. RMVD : Removed ENCL : Enclosed ENCP : Encapsulated DMGD : Damaged SMPLD : Sampled MTRL : Material RPRD : Repaired N/L : None Located RPLCD : Replaced

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE-YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

ITEM	DEFINITION												
THREE YEAR RE-INSPECTION	<p>This section contains the information obtained from the Three-Year Re-inspection IX. With three exceptions, the information categories are identical in format and meaning to those found in the original inspection data section. The three exceptions are defined below.</p>												
DMGD AMT Amount Damaged	<p>This section gives the quantity of damaged material in a homogeneous area. The quantity is shown in the same format as the amount of material/unit section.</p>												
NF Newly Friable	<p>This section identifies materials in the original Management Plan which have since become friable.</p>												
RA Response Action	<p>This rating is based on the AHERA regulations, and is comparable to the RA rating found in the "Original Inspection Data" section. The following table details the response actions.</p> <table><tr><td>1.</td><td>Establish O&M Program</td></tr><tr><td>2.</td><td>Repair and Establish O&M Program</td></tr><tr><td>3.</td><td>Enclose</td></tr><tr><td>4.</td><td>Encapsulate</td></tr><tr><td>5.</td><td>Remove</td></tr><tr><td>6.</td><td>Partial Removal and Establish O&M Program</td></tr></table> <p>a. High Priority Response The homogeneous material has been scheduled for abatement or other response action.</p> <p>b. Medium Priority Response The homogeneous material will be scheduled for abatement or other response action as soon as the high priority responses have been addressed.</p> <p>c. Low Priority Response The homogeneous material will be scheduled for abatement or other response action as soon as the medium priority responses have been addressed.</p> <p>d. On-Going Response/Operations and Maintenance The homogeneous material does not require abatement or other response action at present, and should be included in the facility's on-going operations and maintenance program.</p>	1.	Establish O&M Program	2.	Repair and Establish O&M Program	3.	Enclose	4.	Encapsulate	5.	Remove	6.	Partial Removal and Establish O&M Program
1.	Establish O&M Program												
2.	Repair and Establish O&M Program												
3.	Enclose												
4.	Encapsulate												
5.	Remove												
6.	Partial Removal and Establish O&M Program												

**SCHOOL DISTRICT OF PHILADELPHIA
AHERA THREE-YEAR RE-INSPECTION IX**

RE-INSPECTION FORM KEY

The information presented in the changes section has been compiled from a variety of sources, including the Re-inspection and the following:

- * Quality Control/Quality Assurance Reports of asbestos abatement projects, prepared by consultants to the School District.
- * Permit and Notification Forms for asbestos abatement projects.
- * Periodic Surveillance Forms
- * Operations and Maintenance activities performed by School District personnel.
- * Verbal information from School District personnel.
- * Reports of sampling and analysis of suspected materials by both School District personnel and outside consultants.

**ROOM BY
ROOM
LOCATION LOG
REPORT**

This section gives information, including damage amount and location, for a specific homogeneous material on a room-by-room basis and follows the Re-inspection form.

NOTE: The disparate nature of the above sources of information prohibits the verification of much information within the scope of the AHERA Three-Year Re-inspection. Discrepancies and omissions may exist in this information, and therefore is included on an "as is" basis. The inspectors for the Three-Year Re-inspection IX evaluated homogeneous areas based on the materials current condition and location, as evidenced during the inspector's site visit.

Section II - C

Room by Room Location Log Report

These charts are to be used for a quick reference* in order to avoid the unknowing disturbance of Asbestos Containing Materials during any and all Operations, Maintenance, Renovation, and/or Demolition activities at this location.

NOTE:

*Contact OEMS prior to the disturbance of any of the materials that are listed as **Confirmed and/or Assumed**.*

The quantities listed for (NAD) non-asbestos containing materials and/or Non-Suspect Materials are only estimated and were not measured for the purpose of this report. Field verification of quantities for renovation purposes would be necessary.

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F i o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	3B	Classroom 300	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 300	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 300	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 300	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 300	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 302	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 302	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 302	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 302	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 302	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 304	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 304	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 304	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 304	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 304	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 306	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 306	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 306	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 306	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 306	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 306	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Classroom 308	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 308	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 308	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 308	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 308	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 310	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 310	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 310	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 310	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 310	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 312	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 312	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 312	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 312	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 312	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 312	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Classroom 314	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 314	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 314	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 314	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 314	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 316	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	384	SF	12	SF	Multi	Water stained, tiles may begin to pop up		1	No	B/C
1	3B	Classroom 316	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 316	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 316	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 316	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 316	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	384	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 318	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 318	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 318	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 318	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 318	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 320	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 320	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 320	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 320	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 320	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 322	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 322	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 322	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 322	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 322	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 324	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 324	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 324	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 324	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 324	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 324	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Book Room Next to Classroom 326	X	X		X	X	X	X	X	X	No access		X	X	X
1	3B	Classroom 326	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 326	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 326	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 326	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 326	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
Element	Floor	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	3B	Classroom 326	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Classroom 328	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 328	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 328	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 328	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 328	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 328	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Closet in Classroom 328	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	120	SF	0	SF	Grey			1	No	1/D
1	3B	Closet in Classroom 328	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	3B	Closet in Classroom 328	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	3B	Closet in Classroom 328	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0	LF				N/A	N/A	N/A
1	3B	Closet in Classroom 328	T	Pipe Fitting Insulation	8030/01/03/36	Confirmed	2	EA	0	EA				1	No	1/D
1	3B	Book Room Next to Classroom 328	X	X		X	X	X	X	X	X	No access		X	X	X
1	3B	Classroom 330	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 330	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	22	SF	0	SF	Brown			1	No	1/D
1	3B	Classroom 330	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 330	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 330	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 330	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 330	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Classroom 332	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	250	SF	0	SF	Brown			1	No	1/D
1	3B	Classroom 332	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	600	SF	0	SF	Brown			1	No	1/D
1	3B	Classroom 332	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 332	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 332	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 332	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 332	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	3B	Classroom 334	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 334	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 334	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 334	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 334	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Mini Connector at Back of Classroom 334 and 336	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	80	SF	0	SF	Multi			1	No	1/D
1	3B	Mini Connector at Back of Classroom 334 and 336	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0	SF				N/A	N/A	N/A
1	3B	Mini Connector at Back of Classroom 334 and 336	N/A	Concrete Block Wall		Non Suspect ACM	160	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 334 and 336	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 334 and 336	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	120	SF	0	SF	Multi			1	No	1/D
1	3B	Storage Closet Between Classroom 334 and 336	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 334 and 336	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0	LF				N/A	N/A	N/A
1	3B	Classroom 336	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	936	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 336	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 336	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 336	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 336	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 338	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	936	SF	0	SF	Grey			1	No	1/D
1	3B	Classroom 338	N/A	Concrete Ceiling		Non Suspect ACM	936	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 338	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 338	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 338	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Girl's Restroom	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 303	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Brown			1	No	1/D
1	3B	Classroom 303	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 303	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 303	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 303	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 305	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 305	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 305	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 305	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 305	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 307	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 307	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 307	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 307	M	Transite Sills	8030/01/03/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 307	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Room T2-1	X	X		X	X	X	X	X	X	No access		X	X	X
1	3B	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	3B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	3B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	3B	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	3B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	3B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 315	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
Element	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	3B	Classroom 315	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 315	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 315	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 315	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Science Department Office Storage	N/A	Concrete Floor		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Conference Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	384	SF	0	SF	Tan			1	No	1/D
1	3B	Science Department Conference Room	N/A	Concrete Ceiling		Non Suspect ACM	384	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Conference Room	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Conference Room	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Science Department Conference Room	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Science Department Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	160	SF	0	SF		Need VAT color		1	No	1/D
1	3B	Science Department Office	N/A	Concrete Ceiling		Non Suspect ACM	160	SF	0	SF				N/A	N/A	N/A
1	3B	Science Department Office	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 321	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 321	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 321	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 321	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 321	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Girl's Restroom at Classroom 321	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom at Classroom 321	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom at Classroom 321	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	3B	Boy's Restroom at Classroom 327	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Boy's Restroom at Classroom 327	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Boy's Restroom at Classroom 327	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	3B	Girl's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 327	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	960	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 327	N/A	Concrete Ceiling		Non Suspect ACM	960	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 327	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 327	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 327	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Mini Connector at Back of Classroom 327 and 329	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	80	SF	0	SF	Grey			1	No	1/D
1	3B	Mini Connector at Back of Classroom 327 and 329	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0	SF				N/A	N/A	N/A
1	3B	Mini Connector at Back of Classroom 327 and 329	N/A	Concrete Block Wall		Non Suspect ACM	160	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 327 and 329	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 327 and 329	N/A	Concrete Floor		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 327 and 329	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	3B	Storage Closet Between Classroom 327 and 329	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0	LF				N/A	N/A	N/A
1	3B	Classroom 329	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	10	SF	Grey	Cracked Tiles		1	No	6/C
1	3B	Classroom 329	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 329	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 329	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 329	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Vice Principal Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	300	SF	2	SF	Brown	Cracked Tiles		1	No	6/C
1	3B	Vice Principal Office	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	3B	Vice Principal Office	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	3B	Men's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	25	SF	0	SF	Tan			1	No	1/D
1	3B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	3B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	50	SF	0	SF				N/A	N/A	N/A
1	3B	Women's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	25	SF	0	SF	Tan			1	No	1/D
1	3B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	3B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	50	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 335	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	960	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 335	N/A	Concrete Ceiling		Non Suspect ACM	960	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 335	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 335	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 335	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 337	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	384	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 337	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 337	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 337	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 337	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 337	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	384	SF	0	SF	Multi			1	No	1/D
1	3B	Classroom 339	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	3B	Classroom 339	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 339	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	3B	Classroom 339	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Classroom 339	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	3B	Science Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	310	SF	0	SF	Tan			1	No	1/D
1	3B	Science Office	N/A	Concrete Ceiling		Non Suspect ACM	310	SF	0	SF				N/A	N/A	N/A
1	3B	Science Office	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	3B	Science Office	M	Transite Sills	8030/01/03/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

Element		Floor		School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963		AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
On-Site Room Name		System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
1	3B	Science Office	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	3B	Science Laboratory	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	144	SF	0	SF	Tan		1	No	1/D				
1	3B	Science Laboratory	N/A	Concrete Ceiling		Non Suspect ACM	144	SF	0	SF			N/A	N/A	N/A				
1	3B	Science Laboratory	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF			N/A	N/A	N/A				
1	3B	Classroom 334 Laboratory	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey		1	No	1/D				
1	3B	Classroom 334 Laboratory	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF			N/A	N/A	N/A				
1	3B	Classroom 334 Laboratory	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF			N/A	N/A	N/A				
1	3B	Classroom 334 Laboratory	M	Transite Sills	8030/01/03/CR/1H/2300	Assumed	5	SF	0	SF			1	No	1/D				
1	3B	Classroom 334 Laboratory	M	Blackboard Glue Dots	8030/01/03/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	3B	Classroom 334 Laboratory	M	Transite Sink	8030/01/03/CR/ML/2340	Assumed	10	SF	0	SF			1	No	1/D				
1	3B	Boy's Restroom at Classroom 339	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF			N/A	N/A	N/A				
1	3B	Boy's Restroom at Classroom 339	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF			N/A	N/A	N/A				
1	3B	Boy's Restroom at Classroom 339	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 300-312	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	2124	SF	0	SF	Multi		1	No	1/D				
1	3B	Hallway Classroom 300-312	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 300-312	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 300-312	T	Radiator Insulation	8030/01/03/CR/ML/1600	Assumed	24	SF	0	SF			1	No	1/D				
1	3B	Hallway Classroom 324-330	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	2124	SF	0	SF	Multi		1	No	1/D				
1	3B	Hallway Classroom 324-330	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 324-330	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 324-330	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF			N/A	N/A	N/A				
1	3B	Hallway Classroom 324-330	T	Radiator Insulation	8030/01/03/CR/ML/1600	Assumed	24	SF	0	SF			1	No	1/D				
1	3B	Hallway Classroom 314-322	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1980	SF	0	SF	Multi		1	No	1/D				
1	3B	Hallway Classroom 314-322	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 314-322	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 314-322	T	Radiator Insulation	8030/01/03/CR/ML/1600	Assumed	24	SF	0	SF			1	No	1/D				
1	3B	Hallway Classroom 332-339	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1980	SF	0	SF	Multi		1	No	1/D				
1	3B	Hallway Classroom 332-339	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 332-339	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF			N/A	N/A	N/A				
1	3B	Hallway Classroom 332-339	T	Radiator Insulation	8030/01/03/CR/ML/1600	Assumed	24	SF	0	SF			1	No	1/D				
1	3B	Stairs adjacent to Classroom 300	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	156	SF	0	SF	Multi		1	No	1/D				
1	3B	Stairs adjacent to Classroom 300	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 300	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 300	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 300	T	Radiator Insulation	8030/01/03/CR/ML/1600	Assumed	10	SF	0	SF			1	No	1/D				
1	3B	Stairs adjacent to Classroom 312	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	156	SF	0	SF	Multi		1	No	1/D				
1	3B	Stairs adjacent to Classroom 312	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 312	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 312	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 324	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	156	SF	0	SF	Multi		1	No	1/D				
1	3B	Stairs adjacent to Classroom 324	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 324	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 324	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 330	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	156	SF	0	SF	Multi		1	No	1/D				
1	3B	Stairs adjacent to Classroom 330	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 330	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF			N/A	N/A	N/A				
1	3B	Stairs adjacent to Classroom 330	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 200	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey		1	No	1/D				
1	2B	Classroom 200	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 200	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 200	M	Transite Sills	8030/01/02/CR/1H/2300	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 200	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 200	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0	LF			N/A	N/A	N/A				
1	2B	Classroom 200	N/A	Pipe Fitting Insulation		NAD	3	EA	0	EA			N/A	N/A	N/A				
1	2B	Classroom 202	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey		1	No	1/D				
1	2B	Classroom 202	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 202	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 202	M	Transite Sills	8030/01/02/CR/1H/2300	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 202	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 202	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF			N/A	N/A	N/A				
1	2B	Classroom 202	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA			N/A	N/A	N/A				
1	2B	Classroom 204	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey		1	No	1/D				
1	2B	Classroom 204	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 204	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 204	M	Transite Sills	8030/01/02/CR/1H/2300	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 204	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 204	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF			N/A	N/A	N/A				
1	2B	Classroom 204	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA			N/A	N/A	N/A				
1	2B	Classroom 206	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey		1	No	1/D				
1	2B	Classroom 206	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 206	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF			N/A	N/A	N/A				
1	2B	Classroom 206	M	Transite Sills	8030/01/02/CR/1H/2300	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 206	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF			1	No	1/D				
1	2B	Classroom 206	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF			N/A	N/A	N/A				
1	2B	Classroom 206	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA			N/A	N/A	N/A				

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	2B	Classroom 208	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 208	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 208	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 208	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 208	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 208	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 208	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 210	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 210	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 210	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 210	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 210	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 210	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 210	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 212	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 212	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 212	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 212	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 212	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 212	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 212	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 214	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 214	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 214	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 214	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 214	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 214	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 214	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 216	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 216	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 216	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 216	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 216	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 216	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 216	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 220/218	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	1200	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 220/218	N/A	Concrete Ceiling		Non Suspect ACM	1320	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 220/218	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 220/218	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	10	SF	0	SF				1	No	1/D
1	2B	Classroom 220/218	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	10	SF	0	SF				1	No	1/D
1	2B	Classroom 220/218	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 220/218	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 220/218	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	120	SF	0	SF	White			1	No	1/D
1	2B	Classroom 220/218	N/A	Partition Room Dividers		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 222	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 222	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 222	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 222	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 222	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 222	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 222	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 224	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 224	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 224	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 224	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 224	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 224	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	44	LF	4	LF				N/A	N/A	N/A
1	2B	Classroom 224	N/A	Pipe Fitting Insulation		NAD	17	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 226	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 226	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 226	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 226	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 226	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 226	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 226	N/A	Pipe Fitting Insulation		NAD	20	EA	1	EA		Water stained		N/A	N/A	N/A
1	2B	Classroom 228	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	20	SF	Grey	Missing tiles in one area in middle of room. Possible tripping hazard		1	No	6/C
1	2B	Classroom 228	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 228	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 228	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 228	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 228	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	3	LF				N/A	N/A	N/A
1	2B	Classroom 228	N/A	Pipe Fitting Insulation		NAD	11	EA	3	EA		Water stained		N/A	N/A	N/A
1	2B	Classroom 230	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 230	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 230	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010				
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	2B	Classroom 230		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 230		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 230		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	60	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 230		N/A	Pipe Fitting Insulation		NAD	15	EA	1	EA				N/A	N/A	N/A
1	2B	Classroom 232		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 232		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 232		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 232		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 232		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 232		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	2	LF				N/A	N/A	N/A
1	2B	Classroom 232		N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 234		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	2B	Classroom 234		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 234		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 234		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 234		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 234		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 236		N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 236		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 236		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 236		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 238		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 238		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 238		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 240		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 240		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 240		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 240		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 240		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 240		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	1	LF				N/A	N/A	N/A
1	2B	Classroom 242		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	2B	Classroom 242		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 242		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 242		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 242		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 242		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 244		N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 244		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	2B	Classroom 244		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 244		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 244		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 244		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 244		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 246		N/A	Pipe Fitting Insulation		NAD	2	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 246		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Brown			1	No	1/D
1	2B	Classroom 246		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 246		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 246		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 246		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 246		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 246		N/A	Pipe Fitting Insulation		NAD	2	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 212		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 212		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 212		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 212		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 212		M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 212		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	80	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 212		N/A	Pipe Fitting Insulation		NAD	14	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 203		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Brown			1	No	1/D
1	2B	Classroom 203		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 203		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 203		M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 203		N/A	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 203		N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 205		N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 205		M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 205		N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 205		N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F i o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	2B	Classroom 205	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 205	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 205	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 205	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 207	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 207	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 207	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 207	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 207	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 207	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 207	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Room S2-1	X	X		X	X	X	X	X	X	No access		X	X	X
1	2B	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	2B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	2B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	2B	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	2B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	2B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 215	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 215	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 215	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 215	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 215	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 215	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 215	N/A	Pipe Fitting Insulation		NAD	7	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 221	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 221	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 221	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 221	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 221	N/A	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 221	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 221	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Book Storage	N/A	Concrete Floor		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage	N/A	Concrete Ceiling		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Teacher's Lounge/Copy Room	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Teacher's Lounge/Copy Room	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Teacher's Lounge/Copy Room	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Teacher's Lounge/Copy Room	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Teacher's Lounge/Copy Room	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Teacher's Lounge/Copy Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Teacher's Lounge/Copy Room	N/A	Pipe Fitting Insulation		NAD	7	EA	0	EA				N/A	N/A	N/A
1	2B	Office 223	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Office 223	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Office 223	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Girl's Restroom at Classroom 221	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Girl's Restroom at Classroom 221	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Girl's Restroom at Classroom 221	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 233	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 233	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 233	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 229	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 229	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 229	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 229	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 229	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 229	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 229	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 229	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 231	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 231	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 231	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 231	M	Transite Sills	8030/01/02/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 231	M	Blackboard Glue Dots	8030/01/02/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 231	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 231	N/A	Pipe Fitting Insulation		NAD	8	EA	0	EA				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 231	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 231	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Book Storage adjacent to Classroom 231	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Assistant Principal Office	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Assistant Principal Office	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Assistant Principal Office	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Assistant Principal Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Assistant Principal Office	N/A	Pipe Fitting Insulation		NAD	2	EA	0	EA				N/A	N/A	N/A
1	2B	Men's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/02/23	Confirmed	768	SF	0	SF	Tan			1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	2B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Women's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Office Storage	N/A	Concrete Floor		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	224	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Conference Room	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	384	SF	0	SF	Tan			1	No	1/D
1	2B	History Department Conference Room	N/A	Concrete Ceiling		Non Suspect ACM	384	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Conference Room	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Conference Room	M	Transite Sills	8030/01/02/CRI/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	History Department Conference Room	M	Blackboard Glue Dots	8030/01/02/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	History Department Office	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	160	SF	0	SF		Need VAT color		1	No	1/D
1	2B	History Department Office	N/A	Concrete Ceiling		Non Suspect ACM	160	SF	0	SF				N/A	N/A	N/A
1	2B	History Department Office	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 241	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 241	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 241	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 241	M	Transite Sills	8030/01/02/CRI/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 241	M	Blackboard Glue Dots	8030/01/02/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 241	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	2B	Classroom 241	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 243	M	Floor Tile VAT 9" x 9"	8030/01/02/33	Confirmed	384	SF	0	SF	Tan			1	No	1/D
1	2B	Classroom 243	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 243	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	2B	Classroom 243	M	Transite Sills	8030/01/02/CRI/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 243	M	Blackboard Glue Dots	8030/01/02/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	2B	Classroom 243	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	2	LF				N/A	N/A	N/A
1	2B	Classroom 243	N/A	Pipe Fitting Insulation		NAD	4	EA	0	EA				N/A	N/A	N/A
1	2B	Classroom 243	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	384	SF	0	SF		Need VAT color		1	No	1/D
1	2B	Girl's Restroom at Classroom 203	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Girl's Restroom at Classroom 203	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Girl's Restroom at Classroom 203	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 243	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 243	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A
1	2B	Boy's Restroom at Classroom 243	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 200-212	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	2124	SF	0	SF	Multi			1	No	1/D
1	2B	Hallway Classroom 200-212	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 200-212	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 200-212	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	2B	Hallway Classroom 224-236	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	2124	SF	0	SF	Multi			1	No	1/D
1	2B	Hallway Classroom 224-236	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 224-236	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 224-236	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF				N/A	N/A	N/A
1	2B	Hallway Classroom 224-236	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	2B	Hallway Classroom 214-221	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	1980	SF	0	SF	Multi			1	No	1/D
1	2B	Hallway Classroom 214-221	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 214-221	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 214-221	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	2B	Hallway Classroom 238-246	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	1980	SF	0	SF	Multi			1	No	1/D
1	2B	Hallway Classroom 238-246	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 238-246	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF				N/A	N/A	N/A
1	2B	Hallway Classroom 238-246	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	2B	Stairs adjacent to Classroom 200	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	2B	Stairs adjacent to Classroom 200	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 200	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 200	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 212	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	2B	Stairs adjacent to Classroom 212	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 212	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 212	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 212	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	10	SF	0	SF				1	No	1/D
1	2B	Stairs adjacent to Classroom 224	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	2B	Stairs adjacent to Classroom 224	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 224	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 224	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 224	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	10	SF	0	SF				1	No	1/D
1	2B	Stairs adjacent to Classroom 236	M	Floor Tile VAT 12" x 12"	8030/01/02/A5	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	2B	Stairs adjacent to Classroom 236	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 236	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 236	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	2B	Stairs adjacent to Classroom 236	T	Radiator Insulation	8030/01/02/CRI/ML/1600	Assumed	10	SF	0	SF				1	No	1/D
1	1B	Classroom 107	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1B	Classroom 107	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1B	Classroom 107	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 107	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 107	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 107	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	1B	Classroom 107	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	1B	Classroom 109	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1B	Classroom 109	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 109	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 109	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 109	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 109	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	1B	Classroom 109	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	1B	Classroom 111	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	1B	Classroom 111	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 111	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 111	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 111	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 111	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	1B	Classroom 111	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D
1	1B	Classroom 111	N/A	Partition Room Dividers		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1B	Storage Room adjacent to Classroom 111	N/A	Concrete Floor		Non Suspect ACM	112	SF	0	SF				N/A	N/A	N/A
1	1B	Storage Room adjacent to Classroom 111	N/A	Concrete Ceiling		Non Suspect ACM	112	SF	0	SF				N/A	N/A	N/A
1	1B	Storage Room adjacent to Classroom 111	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1B	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1B	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 121	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1B	Classroom 121	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 121	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 121	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 121	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 121	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	1B	Classroom 121	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	1B	Language Office Conference Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	384	SF	0	SF	Grey			1	No	1/D
1	1B	Language Office Conference Room	N/A	Concrete Ceiling		Non Suspect ACM	384	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office Conference Room	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office Conference Room	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Language Office Conference Room	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Language Office Conference Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF				N/A	N/A	N/A
1	1B	Language Office Conference Room	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA		Need VAT color		1	No	1/D
1	1B	Language Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	144	SF	0	SF				1	No	1/D
1	1B	Language Office	N/A	Concrete Ceiling		Non Suspect ACM	144	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office Storage	N/A	Concrete Floor		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	1B	Language Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 123	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1B	Classroom 123	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 123	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Classroom 123	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 123	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1B	Classroom 123	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	1B	Classroom 123	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	1B	IMC	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	3600	SF	0	SF	White			1	No	1/D
1	1B	IMC	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	600	SF	0	SF	Blue			1	No	1/D
1	1B	IMC	N/A	Ceiling Tile 1' x 1'		NAD	3600	SF	0	SF				N/A	N/A	N/A
1	1B	IMC	N/A	Concrete Block Wall		Non Suspect ACM	5000	SF	0	SF				N/A	N/A	N/A
1	1B	IMC	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	45	LF	0	LF				N/A	N/A	N/A
1	1B	IMC	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	7	EA	0	EA				1	No	1/D
1	1B	IMC Copy Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	75	SF	0	SF	Brown			1	No	1/D
1	1B	IMC Copy Room	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A
1	1B	IMC Copy Room	N/A	Concrete Ceiling		Non Suspect ACM	75	SF	0	SF				N/A	N/A	N/A
1	1B	IMC Lounge	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D
1	1B	IMC Lounge	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1B	IMC Lounge	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1B	F2-2 Closet	X	X		X	X	X	X	X		No access		X	X	X
1	1B	Teacher's Lounge	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	1B	Teacher's Lounge	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1B	Teacher's Lounge	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1B	Men's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	1B	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1B	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010				
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1B	Women's Restroom	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan				1	No	1/D
1	1B	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF					N/A	N/A	N/A
1	1B	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1B	Classroom 157	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey				1	No	1/D
1	1B	Classroom 157	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF					N/A	N/A	N/A
1	1B	Classroom 157	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1B	Classroom 157	M	Transite Sills	8030/01/01/CR/I/H/2300	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Classroom 157	M	Blackboard Glue Dots	8030/01/01/CR/I/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Classroom 157	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF					N/A	N/A	N/A
1	1B	Classroom 157	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA					1	No	1/D
1	1B	Roster Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan				1	No	1/D
1	1B	Roster Office	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF					N/A	N/A	N/A
1	1B	Roster Office	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1B	Roster Office	M	Transite Sills	8030/01/01/CR/I/H/2300	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Roster Office	M	Blackboard Glue Dots	8030/01/01/CR/I/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Roster Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF					N/A	N/A	N/A
1	1B	Roster Office	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA					1	No	1/D
1	1B	Roster Office	N/A	Partition Room Dividers		Non Suspect ACM	200	SF	0	SF					N/A	N/A	N/A
1	1B	Mail Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan				1	No	1/D
1	1B	Mail Room	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF					N/A	N/A	N/A
1	1B	Mail Room	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1B	Mail Room	M	Transite Sills	8030/01/01/CR/I/H/2300	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Mail Room	M	Blackboard Glue Dots	8030/01/01/CR/I/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	1B	Mail Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF					N/A	N/A	N/A
1	1B	Mail Room	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA					1	No	1/D
1	1B	Girl's Restroom Next to Mail Room	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF					N/A	N/A	N/A
1	1B	Girl's Restroom Next to Mail Room	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF					N/A	N/A	N/A
1	1B	Girl's Restroom Next to Mail Room	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1B	Boy's Restroom Next to Mail Room	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF					N/A	N/A	N/A
1	1B	Boy's Restroom Next to Mail Room	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF					N/A	N/A	N/A
1	1B	Boy's Restroom Next to Mail Room	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor's Suite Lobby	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor's Suite Lobby	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor's Suite Lobby	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor's Suite Copy Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor's Suite Copy Room	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor's Suite Copy Room	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office A	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office A	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office A	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office B	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office B	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office B	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office C	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office C	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office C	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office D	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office D	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office D	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office E	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office E	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office E	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office F	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office F	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office F	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office G	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Tan				1	No	1/D
1	1B	Counselor Office G	N/A	Ceiling Tile 1' x 1'		NAD	45	SF	0	SF					N/A	N/A	N/A
1	1B	Counselor Office G	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1B	Outside Bilingual Counseling Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	65	SF	0	SF	Grey				1	No	1/D
1	1B	Outside Bilingual Counseling Office	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	65	SF	0	SF					N/A	N/A	N/A
1	1B	Outside Bilingual Counseling Office	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0	SF					N/A	N/A	N/A
1	1B	Small Conference Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	75	SF	0	SF	Grey				1	No	1/D
1	1B	Small Conference Room	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	75	SF	0	SF					N/A	N/A	N/A
1	1B	Small Conference Room	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	0	SF					N/A	N/A	N/A
1	1B	Bilingual Counseling Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	65	SF	0	SF	Grey				1	No	1/D
1	1B	Bilingual Counseling Office	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	65	SF	0	SF					N/A	N/A	N/A
1	1B	Bilingual Counseling Office	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0	SF					N/A	N/A	N/A
1	1B	Storage Next to Bilingual Counseling Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	65	SF	0	SF	Grey				1	No	1/D
1	1B	Storage Next to Bilingual Counseling Office	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	65	SF	0	SF					N/A	N/A	N/A
1	1B	Storage Next to Bilingual Counseling Office	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0	SF					N/A	N/A	N/A
1	1B	Special Needs Suite Lobby	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	360	SF	0	SF	Grey				1	No	1/D
1	1B	Special Needs Suite Lobby	N/A	Concrete Ceiling		Non Suspect ACM	360	SF	0	SF					N/A	N/A	N/A
1	1B	Special Needs Suite Lobby	N/A	Concrete Block Wall		Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1B	Special Needs Office A	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	45	SF	0	SF	Grey				1	No	1/D
1	1B	Special Needs Office A	N/A	Concrete Ceiling		Non Suspect ACM	45	SF	0	SF					N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010						
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)		
1	1B		Special Needs Office A	N/A	Concrete Block Wall		Non Suspect ACM	90	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office B	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	175	SF	0	SF	Grey			1	No	1/D		
1	1B		Special Needs Office B	N/A	Concrete Ceiling		Non Suspect ACM	175	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office B	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office C	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	175	SF	0	SF	Grey			1	No	1/D		
1	1B		Special Needs Office C	N/A	Concrete Ceiling		Non Suspect ACM	175	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office C	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office D	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	175	SF	0	SF	Grey			1	No	1/D		
1	1B		Special Needs Office D	N/A	Concrete Ceiling		Non Suspect ACM	175	SF	0	SF				N/A	N/A	N/A		
1	1B		Special Needs Office D	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 110	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 110	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 110	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 110	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 110	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 110	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 110	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 112	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 112	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 112	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 112	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 112	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 112	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 112	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 114	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 114	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 114	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 114	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 114	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 114	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 114	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 116	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 116	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 116	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 116	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 116	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 116	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 116	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 118	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 118	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 118	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 118	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 118	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 118	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 118	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 120	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 120	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 120	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 120	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 120	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 120	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 120	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 122	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 122	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 122	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 122	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 122	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 122	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 122	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 124	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 124	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 124	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 124	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 124	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 124	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 124	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Classroom 126	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D		
1	1B		Classroom 126	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 126	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A		
1	1B		Classroom 126	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 126	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D		
1	1B		Classroom 126	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A		
1	1B		Classroom 126	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D		
1	1B		Room F2-3	X	X		X	X	X	X	X	No access			X	X	X		
1	1B		Classroom 127	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D		

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010							
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)				
1	1B	Classroom 127	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A				
1	1B	Classroom 127	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A				
1	1B	Classroom 127	M	Transite Sills	8030/01/01/CR/IIH/2300	Assumed	5	SF	0	SF				1	No	1/D				
1	1B	Classroom 127	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D				
1	1B	Left Side Storage Closet in Classroom 127	N/A	Concrete Floor		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	Left Side Storage Closet in Classroom 127	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	Left Side Storage Closet in Classroom 127	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	Left Side Storage Closet in Classroom 127	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	22	LF	0	LF				N/A	N/A	N/A				
1	1B	Left Side Storage Closet in Classroom 127	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D				
1	1B	Right Side Storage Closet in Classroom 127	N/A	Concrete Floor		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	Right Side Storage Closet in Classroom 127	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	Right Side Storage Closet in Classroom 127	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	Right Side Storage Closet in Classroom 127	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	22	LF	0	LF				N/A	N/A	N/A				
1	1B	Right Side Storage Closet in Classroom 127	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D				
1	1B	ID Office	N/A	Carpet		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	ID Office	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	ID Office	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	ID Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0	LF				N/A	N/A	N/A				
1	1B	ID Office	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	1	EA	0	EA				1	No	1/D				
1	1B	129E Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	150	SF	0	SF	Tan			1	No	1/D				
1	1B	129E Office	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	129E Office	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	129E Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A				
1	1B	129E Office	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	3	EA	0	EA				1	No	1/D				
1	1B	L-127 Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	150	SF	0	SF	Brown			1	No	1/D				
1	1B	L-127 Office	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	L-127 Office	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	L-127 Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A				
1	1B	L-127 Office	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	5	EA	0	EA				1	No	1/D				
1	1B	Finance Office	X	X		X	X	X	X	X	X	No access		X	X	X				
1	1B	Office 139B	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	150	SF	0	SF	Brown			1	No	1/D				
1	1B	Office 139B	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A				
1	1B	Office 139B	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A				
1	1B	Office 139B	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A				
1	1B	Office 139B	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	5	EA	0	EA				1	No	1/D				
1	1B	L-130 Office	X	X		X	X	X	X	X	X	No access		X	X	X				
1	1B	Culinary Arts Kitchen Classroom 155 Back Storage(The Classroom is part of Section C)	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A				
1	1B	Culinary Arts Kitchen Classroom 155 Back Storage(The Classroom is part of Section C)	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A				
1	1B	Culinary Arts Kitchen Classroom 155 Back Storage(The Classroom is part of Section C)	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A				
1	1B	Culinary Arts Kitchen Classroom 155 Back Storage(The Classroom is part of Section C)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	18	LF	0	LF				N/A	N/A	N/A				
1	1B	Culinary Arts Kitchen Classroom 155 Back Storage(The Classroom is part of Section C)	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	6	EA	0	EA				1	No	1/D				
1	1B	Yearbook Room	X	X		X	X	X	X	X	X	No access		X	X	X				
1	1B	Main Office Restroom	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Multi			1	No	1/D				
1	1B	Main Office Restroom	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A				
1	1B	Main Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A				
1	1B	Empty Office Next to Main Office Restroom	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	190	SF	0	SF	Blue			1	No	1/D				
1	1B	Empty Office Next to Main Office Restroom	N/A	Ceiling Tile 1' x 1'		NAD	190	SF	0	SF				N/A	N/A	N/A				
1	1B	Empty Office Next to Main Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	380	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Meeting Room	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	190	SF	0	SF	Blue			1	No	1/D				
1	1B	Vice Principal Meeting Room	N/A	Ceiling Tile 1' x 1'		NAD	190	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Meeting Room	N/A	Concrete Block Wall		Non Suspect ACM	380	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Meeting Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	14	LF	0	LF				N/A	N/A	N/A				
1	1B	Vice Principal Meeting Room	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D				
1	1B	Vice Principal Office #3	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Blue			1	No	1/D				
1	1B	Vice Principal Office #3	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #3	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #3	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	1	LF	0	LF				N/A	N/A	N/A				
1	1B	Vice Principal Office #3	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D				
1	1B	Vice Principal Office #2	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Blue			1	No	1/D				
1	1B	Vice Principal Office #2	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #2	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #2	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0	LF				N/A	N/A	N/A				
1	1B	Vice Principal Office #2	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D				
1	1B	Vice Principal Office #1	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Blue			1	No	1/D				
1	1B	Vice Principal Office #1	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #1	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A				
1	1B	Vice Principal Office #1	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0	LF				N/A	N/A	N/A				
1	1B	Vice Principal Office #1	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D				
1	1B	Main Office	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2400	SF	6	SF	Multi			1	No	6/C				
1	1B	Main Office	N/A	Ceiling Tile 1' x 1'		NAD	2400	SF	10	SF		Water Stains		N/A	N/A	N/A				
1	1B	Main Office	N/A	Concrete Block Wall		Non Suspect ACM	4800	SF	0	SF				N/A	N/A	N/A				

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1B	Main Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	22	LF	0	LF				N/A	N/A	N/A
1	1B	Main Office		Pipe Fitting Insulation	8030/01/01/37	Confirmed	6	EA	0	EA				1	No	1/D
1	1B	Main Office Storage	N/A	Concrete Floor		Non Suspect ACM	220	SF	0	SF		Water Stains		N/A	N/A	N/A
1	1B	Main Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	220	SF	0	SF				N/A	N/A	N/A
1	1B	Main Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	440	SF	0	SF				N/A	N/A	N/A
1	1B	Main Office Storage	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	22	LF	0	LF				N/A	N/A	N/A
1	1B	Main Office Storage	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	1	EA	0	EA				1	No	1/D
1	1B	Main Office Storage	M	Vibration Damper Cloth	8030/01/01/11	Assumed	12	SF	0	SF				1	No	1/D
1	1B	Principal's Office	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	400	SF	0	SF	Multi			1	No	1/D
1	1B	Principal's Office	N/A	Ceiling Tile 1' x 1'		NAD	400	SF	0	SF		Water Stains		N/A	N/A	N/A
1	1B	Principal's Office	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	1B	Principal's Office Restroom	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	40	SF	0	SF	Multi			1	No	1/D
1	1B	Principal's Office Restroom	N/A	Ceiling Tile 1' x 1'		NAD	40	SF	0	SF		Water Stains		N/A	N/A	N/A
1	1B	Principal's Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	10	SF		Efflorescence		N/A	N/A	N/A
1	1B	Principal's Office Closet	N/A	Concrete Floor		Non Suspect ACM	45	SF	0	SF				N/A	N/A	N/A
1	1B	Principal's Office Closet	N/A	Concrete Ceiling		Non Suspect ACM	45	SF	0	SF		Water Stains		N/A	N/A	N/A
1	1B	Principal's Office Closet	N/A	Concrete Block Wall		Non Suspect ACM	90	SF	0	SF				N/A	N/A	N/A
1	1B	Principal's Office Closet	M	Vibration Damper Cloth	8030/01/01/11	Assumed	8	SF	0	SF				1	No	1/D
1	1B	Hallway Classroom Counselor's Suite to Classroom 116	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2124	SF	0	SF	Multi			1	No	1/D
1	1B	Hallway Classroom Counselor's Suite to Classroom 116	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom Counselor's Suite to Classroom 116	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom Counselor's Suite to Classroom 116	T	Radiator Insulation	8030/01/01/CR/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	1B	Hallway Classroom 116 to F2-3 Closet	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2124	SF	0	SF	Multi			1	No	1/D
1	1B	Hallway Classroom 116 to F2-3 Closet	N/A	Concrete Ceiling		Non Suspect ACM	2124	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom 116 to F2-3 Closet	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom 116 to F2-3 Closet	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	2	LF				N/A	N/A	N/A
1	1B	Hallway Classroom 116 to F2-3 Closet	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	1B	Hallway Classroom 116 to F2-3 Closet	T	Radiator Insulation	8030/01/01/CR/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	1B	Hallway Classroom 127-159	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1980	SF	0	SF	Multi			1	No	1/D
1	1B	Hallway Classroom 127-159	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom 127-159	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway Classroom 127-159	T	Radiator Insulation	8030/01/01/CR/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	1B	Hallway from Yearbook Room to Main Office	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1980	SF	0	SF	Multi			1	No	1/D
1	1B	Hallway from Yearbook Room to Main Office	N/A	Concrete Ceiling		Non Suspect ACM	1980	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway from Yearbook Room to Main Office	N/A	Concrete Block Wall		Non Suspect ACM	2500	SF	0	SF				N/A	N/A	N/A
1	1B	Hallway from Yearbook Room to Main Office	T	Radiator Insulation	8030/01/01/CR/ML/1600	Assumed	24	SF	0	SF				1	No	1/D
1	1B	Stairs adjacent to Counselor's Suite	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	1B	Stairs adjacent to Counselor's Suite	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Counselor's Suite	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Counselor's Suite	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 116	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	1B	Stairs adjacent to Classroom 116	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 116	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 116	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 126	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	1B	Stairs adjacent to Classroom 126	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 126	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Classroom 126	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Yearbook Room	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	156	SF	0	SF	Multi			1	No	1/D
1	1B	Stairs adjacent to Yearbook Room	N/A	Concrete Floor		Non Suspect ACM	156	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Yearbook Room	N/A	Concrete Ceiling		Non Suspect ACM	312	SF	0	SF				N/A	N/A	N/A
1	1B	Stairs adjacent to Yearbook Room	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 7	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 7	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 7	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 7	M	Transite Sills	8030/01/0G/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 7	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 7	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 7	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Classroom 9	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 9	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 9	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 9	M	Transite Sills	8030/01/0G/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 9	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 9	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	80	LF	10	LF		Stained		N/A	N/A	N/A
1	GDB	Classroom 9	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	15	EA	0	EA				1	No	1/D
1	GDB	Classroom 11	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 11	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 11	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 11	M	Transite Sills	8030/01/0G/CR/ML/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 11	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 11	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 11	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Service Closet	X	X		X	X	X	X	X		No access		X	X	X
1	GDB	Room 11A	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	350	SF	0	SF	Blue			1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010				
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDB	Room 11A	Room 11A	N/A	Concrete Ceiling		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A
1	GDB	Room 11A	Room 11A	N/A	Concrete Block Wall		Non Suspect ACM	700	SF	0	SF				N/A	N/A	N/A
1	GDB	Room 11A	Room 11A	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	55	LF	0	LF				N/A	N/A	N/A
1	GDB	Room 11A	Room 11A	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	8	EA	0	EA				1	No	1/D
1	GDB	Storage Closet in Room 11A	Storage Closet in Room 11A	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	150	SF	0	SF	Blue			1	No	1/D
1	GDB	Storage Closet in Room 11A	Storage Closet in Room 11A	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF				N/A	N/A	N/A
1	GDB	Storage Closet in Room 11A	Storage Closet in Room 11A	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	GDB	Office in Room 11A	Office in Room 11A	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	200	SF	0	SF	Blue			1	No	1/D
1	GDB	Office in Room 11A	Office in Room 11A	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	GDB	Office in Room 11A	Office in Room 11A	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 29	Classroom 29	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Multi			1	No	1/D
1	GDB	Classroom 29	Classroom 29	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 29	Classroom 29	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 29	Classroom 29	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 29	Classroom 29	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 29	Classroom 29	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	10	LF				N/A	N/A	N/A
1	GDB	Classroom 29	Classroom 29	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Classroom 31	Classroom 31	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 31	Classroom 31	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 31	Classroom 31	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 31	Classroom 31	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 31	Classroom 31	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 31	Classroom 31	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 31	Classroom 31	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Classroom 33	Classroom 33	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 33	Classroom 33	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 33	Classroom 33	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 33	Classroom 33	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 33	Classroom 33	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 33	Classroom 33	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 33	Classroom 33	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Generator Room	Generator Room	N/A	Concrete Floor		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A
1	GDB	Generator Room	Generator Room	N/A	Concrete Ceiling		Non Suspect ACM	350	SF	0	SF				N/A	N/A	N/A
1	GDB	Generator Room	Generator Room	N/A	Concrete Block Wall		Non Suspect ACM	700	SF	0	SF				N/A	N/A	N/A
1	GDB	Generator Room	Generator Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	90	LF	12	LF				N/A	N/A	N/A
1	GDB	Generator Room	Generator Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	2	EA				1	Yes	2/B
1	GDB	Classroom 35	Classroom 35	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 35	Classroom 35	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 35	Classroom 35	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 35	Classroom 35	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 35	Classroom 35	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 35	Classroom 35	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 35	Classroom 35	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Classroom 37	Classroom 37	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 37	Classroom 37	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 37	Classroom 37	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 37	Classroom 37	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 37	Classroom 37	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 37	Classroom 37	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 37	Classroom 37	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Classroom 39	Classroom 39	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDB	Classroom 39	Classroom 39	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 39	Classroom 39	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 39	Classroom 39	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 39	Classroom 39	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 39	Classroom 39	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 39	Classroom 39	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDB	Boys Restroom	Boys Restroom	X	X		X	X	X	X	X	X	No Access		X	X	X
1	GDB	Service Closet	Service Closet	N/A	Concrete Floor		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	GDB	Service Closet	Service Closet	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	GDB	Service Closet	Service Closet	N/A	Concrete Block Wall		Non Suspect ACM	50	SF	0	SF				N/A	N/A	N/A
1	GDB	Service Closet	Service Closet	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	15	LF	0	LF				N/A	N/A	N/A
1	GDB	Service Closet	Service Closet	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	10	EA	1	EA				1	Yes	2/B
1	GDB	Girls Restroom	Girls Restroom	X	X		X	X	X	X	X	X	No Access		X	X	X
1	GDB	Classroom 1	Classroom 1	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Brown			1	No	1/D
1	GDB	Classroom 1	Classroom 1	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 1	Classroom 1	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 1	Classroom 1	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 1	Classroom 1	M	Blackboard Glue Dots	8030/01/0G/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDB	Classroom 1	Classroom 1	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF				N/A	N/A	N/A
1	GDB	Classroom 1	Classroom 1	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	1	EA	0	EA				1	No	1/D
1	GDB	Classroom 3	Classroom 3	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	GDB	Classroom 3	Classroom 3	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 3	Classroom 3	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDB	Classroom 3	Classroom 3	M	Transite Sills	8030/01/0G/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016				
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison				
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011				
ULCS# 8030													Management Planner: Monique Causley				
Year Built: 1963													Certificate Number: ACC-0215-8-010				
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDB	Classroom 3	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	LF	0	SF					1	No	1/D
1	GDB	Classroom 3	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF					N/A	N/A	N/A
1	GDB	Classroom 3	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA					1	No	1/D
1	GDB	Classroom 5	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF		Grey			1	No	1/D
1	GDB	Classroom 5	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 5	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 5	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDB	Classroom 5	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDB	Classroom 5	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF					N/A	N/A	N/A
1	GDB	Classroom 5	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA					1	No	1/D
1	GDB	Mens Faculty Restroom	X	X		X	X	X	X	X	X	X	No access		X	X	X
1	GDB	Womens Faculty Restroom	X	X		X	X	X	X	X	X	X	No access		X	X	X
1	GDB	Classroom 25	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF		Multi			1	No	1/D
1	GDB	Classroom 25	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 25	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 25	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDB	Classroom 25	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDB	Classroom 25	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	16	LF	0	LF					N/A	N/A	N/A
1	GDB	Classroom 25	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA					1	No	1/D
1	GDB	Classroom 25 Closet	N/A	Concrete Floor		Non Suspect ACM	40	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 25 Closet	N/A	Concrete Ceiling		Non Suspect ACM	40	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 25 Closet	N/A	Concrete Block Wall		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	GDB	Classroom 25 Closet	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	26	LF	0	LF					N/A	N/A	N/A
1	GDB	Classroom 25 Closet	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	8	EA	0	EA					1	No	1/D
1	GDB	Back Room	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDB	Back Room	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDB	Back Room	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	GDB	Back Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	45	LF	0	LF					N/A	N/A	N/A
1	GDB	Back Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	8	EA	0	EA					1	No	1/D
1	GDB	Storage Closet in Discipline Office(Discipline Office Part of	N/A	Concrete Floor		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	GDB	Storage Closet in Discipline Office(Discipline Office Part of	N/A	Concrete Ceiling		Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	GDB	Storage Closet in Discipline Office(Discipline Office Part of	N/A	Concrete Block Wall		Non Suspect ACM	160	SF	0	SF					N/A	N/A	N/A
1	GDB	Storage Closet in Discipline Office(Discipline Office Part of	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0	LF					N/A	N/A	N/A
1	GDB	Storage Closet in Discipline Office(Discipline Office Part of	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	6	EA	0	EA					1	No	1/D
1	GDB	Custodial Service Storage and Lounge	N/A	Concrete Floor		Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	GDB	Custodial Service Storage and Lounge	N/A	Concrete Ceiling		Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	GDB	Custodial Service Storage and Lounge	N/A	Concrete Block Wall		Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	GDB	Custodial Service Storage and Lounge	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	66	LF	0	LF					N/A	N/A	N/A
1	GDC	Garage Across Classroom 13	N/A	Concrete Floor		Non Suspect ACM	200	SF	0	SF					N/A	N/A	N/A
1	GDC	Garage Across Classroom 13	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF					N/A	N/A	N/A
1	GDC	Garage Across Classroom 13	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	GDC	Garage Across Classroom 13	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	6	LF					N/A	N/A	N/A
1	GDC	Garage Across Classroom 13	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	1	EA	0	EA					1	No	1/D
1	GDC	Classroom 013	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	768	SF	0	SF		Grey			1	No	1/D
1	GDC	Classroom 013	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 013	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 013	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 013	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 013	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF					N/A	N/A	N/A
1	GDC	Classroom 013 Closet	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 013 Closet	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 013 Closet	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 015	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF		Tan			1	No	1/D
1	GDC	Classroom 015	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 015	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 015	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 015	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 015	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF					N/A	N/A	N/A
1	GDC	Classroom 015	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA					1	No	1/D
1	GDC	Classroom 017 (Sewing)	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	1240	SF	0	SF		Grey			1	No	1/D
1	GDC	Classroom 017 (Sewing)	N/A	Ceiling Tile 1' x 1'		NAD	1240	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 017 (Sewing)	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 017 (Sewing)	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 017 (Sewing)	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 017 (Sewing)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF					N/A	N/A	N/A
1	GDC	Classroom 017 (Sewing)	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA					1	No	1/D
1	GDC	Classroom 019 (Business Academy)	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	1240	SF	0	SF		Grey			1	No	1/D
1	GDC	Classroom 019 (Business Academy)	N/A	Ceiling Tile 1' x 1'		NAD	124	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 019 (Business Academy)	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF					N/A	N/A	N/A
1	GDC	Classroom 019 (Business Academy)	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 019 (Business Academy)	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF					1	No	1/D
1	GDC	Classroom 019 (Business Academy)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF					N/A	N/A	N/A
1	GDC	Classroom 019 (Business Academy)	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA					1	No	1/D
1	GDC	Classroom 021	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF		Grey			1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDC	Classroom 021	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 021	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 021	M	Transite Sills	8030/01/0G/CR/I/H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 021	M	Blackboard Glue Dots	8030/01/0G/CR/I/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 021	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	101	LF	0	LF				N/A	N/A	N/A
1	GDC	Classroom 021	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	32	EA	0	EA				1	No	1/D
1	GDC	Classroom 023	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDC	Classroom 023	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 023	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 023	M	Transite Sills	8030/01/0G/CR/I/H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 023	M	Blackboard Glue Dots	8030/01/0G/CR/I/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 023	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	GDC	Classroom 023	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	9	EA	0	EA				1	No	1/D
1	GDC	Classroom 023	N/A	Sheetrock Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 014	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	GDC	Classroom 014	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 014	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 014	M	Transite Sills	8030/01/0G/CR/I/H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 014	M	Blackboard Glue Dots	8030/01/0G/CR/I/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 014	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF				N/A	N/A	N/A
1	GDC	Classroom 014	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA				1	No	1/D
1	GDC	Classroom 12	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Womens Faculty Restroom	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Service Closet 16	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	GDC	Service Closet 16	N/A	Concrete Floor		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	GDC	Service Closet 16	N/A	Concrete Block Wall		Non Suspect ACM	50	LF	0	LF				N/A	N/A	N/A
1	GDC	Service Closet 16	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	1	EA	0	EA				1	No	1/D
1	GDC	Mens Faculty Restroom	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Girls Restroom	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Boys Restroom	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Classroom 22	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	768	SF	10	SF	Brown	Water stains		1	No	6/C
1	GDC	Classroom 22	N/A	Ceiling Tile 1' x 1'		NAD	768	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 22	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 22	M	Transite Sills	8030/01/0G/CR/I/H/2300	Assumed	14	SF	0	SF				1	No	1/D
1	GDC	Classroom 22	M	Blackboard Glue Dots	8030/01/0G/CR/I/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDC	Classroom 22	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	66	LF	0	LF				N/A	N/A	N/A
1	GDC	Classroom 22	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	5	EA	0	EA				1	No	1/D
1	GDC	Classroom 22	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	17	EA	0	EA				N/A	N/A	N/A
1	GDC	Classroom 22 Closet	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 22 Closet	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 22 Closet	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	GDC	Classroom 22 Closet	M	Transite Sills	8030/01/0G/CR/I/H/2300	Assumed	4	SF	0	SF				1	No	1/D
1	GDC	Classroom 22 Closet	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	GDC	Classroom 22 Closet	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	7	EA	0	EA				1	No	1/D
1	GDC	Boys Restroom	N/A	Concrete Floor		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDC	Boys Restroom	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDC	Boys Restroom	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	GDC	Girls Restroom	N/A	Concrete Floor		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDC	Girls Restroom	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	GDC	Girls Restroom	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	GDC	Service Closet	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	School Police	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Service Closet	X	X		X	X	X	X	X	X	No access		X	X	X
1	GDC	Building Engineer's Office	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	120	SF	0	SF	Multi			1	No	1/D
1	GDC	Building Engineer's Office	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Storage	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Restroom	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	60	SF	0	SF	Multi			1	No	1/D
1	GDC	Building Engineer's Office Restroom	N/A	Concrete Ceiling		Non Suspect ACM	60	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	120	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	34	LF	0	LF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Restroom	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	5	EA	0	EA				1	No	1/D
1	GDC	Building Engineer's Office Closet	N/A	Concrete Floor		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Closet	N/A	Concrete Ceiling		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Closet	N/A	Concrete Block Wall		Non Suspect ACM	70	SF	0	SF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Closet	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	2	LF	0	LF				N/A	N/A	N/A
1	GDC	Building Engineer's Office Closet	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	2	EA	0	EA				1	No	1/D
1	GDC	Hallway from Classroom 13-17	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1548	SF	0	SF	Multi			1	No	1/D
1	GDC	Hallway from Classroom 13-17	N/A	Concrete Ceiling		Non Suspect ACM	1548	SF	0	SF				N/A	N/A	N/A
1	GDC	Hallway from Classroom 13-17	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	GDC	Hallway from Classroom 13-17	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	6	LF	0	LF				N/A	N/A	N/A
1	GDC	Hallway from Classroom 13-17	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA				1	No	1/D
1	GDC	Hallway from BE Office to Classroom 22	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1548	SF	0	SF	Multi			1	No	1/D

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia		AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016				
George Washington High School (9-12)		Room by Room Location Log Report										Building Inspector: Norman Harrison				
10175 Bustleton Avenue, Philadelphia, PA 19116												Certificate Number: ACC-0915-6-011				
ULCS# 8030												Management Planner: Monique Causley				
Year Built: 1963												Certificate Number: ACC-0215-8-010				
Element	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDC	Hallway from BE Office to Classroom 22	N/A	Concrete Ceiling		Non Suspect ACM	1548	SF	0	SF				N/A	N/A	N/A
1	GDC	Hallway from BE Office to Classroom 22	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	1C	Girl's Restroom at Classroom 106	N/A	Concrete Floor		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Girl's Restroom at Classroom 106	N/A	Concrete Ceiling		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Girl's Restroom at Classroom 106	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom at Classroom 161	N/A	Concrete Floor		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom at Classroom 161	N/A	Concrete Ceiling		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom at Classroom 161	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 152 (Culinary)	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	2150	SF	0	SF	Brown			1	No	1/D
1	1C	Classroom 152 (Culinary)	N/A	Concrete Ceiling		Non Suspect ACM	2150	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 152 (Culinary)	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 152 (Culinary)	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 152 (Culinary)	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 152 (Culinary)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	1C	Classroom 152 (Culinary)	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D
1	1C	Business 156	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	400	SF	0	EA	Tan			1	No	1/D
1	1C	Business 156	N/A	Carpet		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1C	Business 156	N/A	Concrete Ceiling		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	1C	Business 156	N/A	Concrete Block Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1C	Business 156	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Business 156 Closet	X	X		X	X	X	X	X	X	No access		X	X	X
1	1C	Classroom 151	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	1488	SF	0	SF	Grey			1	No	1/D
1	1C	Classroom 151	N/A	Concrete Ceiling		Non Suspect ACM	1488	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 151	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 151	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 151	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 151	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	40	LF	0	LF				N/A	N/A	N/A
1	1C	Classroom 151	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D
1	1C	CAFE	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	450	SF	0	SF	Grey			1	No	1/D
1	1C	CAFE	N/A	Ceiling Tile 1' x 1'		NAD	450	SF	0	SF				N/A	N/A	N/A
1	1C	CAFE	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	1C	CAFE	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	CAFE Small Closet	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	20	SF	0	SF	Grey			1	No	1/D
1	1C	CAFE Small Closet	N/A	Ceiling Tile 1' x 1'		NAD	20	SF	0	SF				N/A	N/A	N/A
1	1C	CAFE Small Closet	N/A	Concrete Block Wall		Non Suspect ACM	40	SF	0	SF				N/A	N/A	N/A
1	1C	CAFE Storage	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Grey			1	No	1/D
1	1C	CAFE Storage	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A
1	1C	CAFE Storage	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 154 (Culinary Arts)	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Brown			1	No	1/D
1	1C	Classroom 154 (Culinary Arts)	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 154 (Culinary Arts)	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 154 (Culinary Arts)	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 154 (Culinary Arts)	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Room F3-1	X	X		X	X	X	X	X	X	No access		X	X	X
1	1C	Kitchen (Culinary Arts)	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1200	SF	0	SF	Grey			1	No	1/D
1	1C	Kitchen (Culinary Arts)	N/A	Concrete Ceiling		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1C	Kitchen (Culinary Arts)	N/A	Concrete Block Wall		Non Suspect ACM	1500	SF	0	SF				N/A	N/A	N/A
1	1C	Kitchen (Culinary Arts)	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Kitchen (Culinary Arts)	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Kitchen (Culinary Arts)	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0	LF				N/A	N/A	N/A
1	1C	Kitchen (Culinary Arts)	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	20	EA	0	EA				1	No	1/D
1	1C	Kitchen (Culinary Arts) Custodial Closet	N/A	Concrete Floor		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	1C	Kitchen (Culinary Arts) Custodial Closet	N/A	Concrete Ceiling		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	1C	Kitchen (Culinary Arts) Custodial Closet	N/A	Concrete Block Wall		Non Suspect ACM	70	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 127	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1C	Classroom 127	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 127	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 127	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 127	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 128	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Grey			1	No	1/D
1	1C	Classroom 128	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 128	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 128	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 128	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Art Classroom 129	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	768	SF	0	SF	Tan			1	No	1/D
1	1C	Art Classroom 129	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1C	Art Classroom 129	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1C	Art Classroom 129	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Art Classroom 129	M	Blackboard Glue Dots	8030/01/01/CR/1M/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Art Classroom 129 Closet	N/A	Concrete Floor		Non Suspect ACM	65	SF	0	SF				N/A	N/A	N/A
1	1C	Art Classroom 129 Closet	N/A	Concrete Ceiling		Non Suspect ACM	65	SF	0	SF				N/A	N/A	N/A
1	1C	Art Classroom 129 Closet	N/A	Concrete Block Wall		Non Suspect ACM	150	SF	10	SF		Crack Along Height of Wall		N/A	N/A	N/A
1	1C	Classroom 130	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	768	SF	0	SF	Tan			1	No	1/D
1	1C	Classroom 130	N/A	Concrete Ceiling		Non Suspect ACM	768	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 130	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1C	Classroom 130	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 130	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 131	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	768	SF	0	SF	Tan			1	No	1/D
1	1C	Classroom 131	N/A	Ceiling Tile 1" x 1"		NAD	768	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 131	N/A	Concrete Block Wall		Non Suspect ACM	1000	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 131	M	Transite Sills	8030/01/01/CR/IH/2300	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 131	M	Blackboard Glue Dots	8030/01/01/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1C	Classroom 131 Closet	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 131 Closet	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Classroom 131 Closet	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1C	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Men's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1C	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1C	Women's Restroom	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1C	Service Closet Next to Women's Restroom	X	X		X	X	X	X	X	X	No access		X	X	X
1	1C	Girl's Restroom Across Classroom 131	N/A	Concrete Floor		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Girl's Restroom Across Classroom 131	N/A	Concrete Ceiling		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Girl's Restroom Across Classroom 131	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom Across Classroom 131	N/A	Concrete Floor		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom Across Classroom 131	N/A	Concrete Ceiling		Non Suspect ACM	176	SF	0	SF				N/A	N/A	N/A
1	1C	Boy's Restroom Across Classroom 131	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1C	Hallway from Classroom 128-131	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1548	SF	0	SF	Multi			1	No	1/D
1	1C	Hallway from Classroom 128-131	N/A	Concrete Ceiling		Non Suspect ACM	1548	SF	0	SF				N/A	N/A	N/A
1	1C	Hallway from Classroom 128-131	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	1C	Hallway from Classroom 128-131	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0	LF				N/A	N/A	N/A
1	1C	Hallway from Classroom 128-131	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D
1	1C	Hallway from Classroom 151-154	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1548	SF	0	SF	Multi			1	No	1/D
1	1C	Hallway from Classroom 151-154	N/A	Concrete Ceiling		Non Suspect ACM	1548	SF	0	SF				N/A	N/A	N/A
1	1C	Hallway from Classroom 151-154	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	1C	Hallway from Classroom 151-154	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0	LF				N/A	N/A	N/A
1	1C	Hallway from Classroom 151-154	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	EA	0	EA				1	No	1/D
1	GDE	Classroom 401	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Grey			1	No	1/D
1	GDE	Classroom 401	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Terrazzo Floor		Non Suspect ACM	884	SF	0	SF	Mosaic/Marble			N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	M	Transite Sink	8030/01/0G/CR/ML/2340	Assumed	10	SF	0	SF				1	No	1/D
1	GDE	Classroom 401	N/A	Concrete Floor		Non Suspect ACM	442	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Concrete Ceiling		Non Suspect ACM	442	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 401	N/A	Brick Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 403	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Grey			1	No	1/D
1	GDE	Classroom 403	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 403	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 406	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Grey			1	No	1/D
1	GDE	Classroom 406	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 406	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 408	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Tan			1	No	1/D
1	GDE	Classroom 408	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 408	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 410	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Green			1	No	1/D
1	GDE	Classroom 410	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 410	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 410	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDE	Classroom 409	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Tan			1	No	1/D
1	GDE	Classroom 409	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 409	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 409	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDE	Classroom 412	M	Floor Tile VAT 18" x 18"	8030/01/0G/CR/ML/2070	Assumed	884	SF	0	SF	Multi			1	No	1/D
1	GDE	Classroom 412	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 412	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 412	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDE	Classroom 411	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Green			1	No	1/D
1	GDE	Classroom 411	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	GDE	Classroom 411	N/A	Brick Wall		Non Suspect ACM	1200	SF	30	SF		Efflorescence		N/A	N/A	N/A
1	GDE	Classroom 411	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDE	Classroom 414	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	884	SF	0	SF	Green			1	No	1/D
1	GDE	Classroom 414	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	85	SF		Water damage, 15 SF Mold Efflorescence		N/A	N/A	N/A
1	GDE	Classroom 414	N/A	Brick Wall		Non Suspect ACM	1200	SF	100	SF				N/A	N/A	N/A
1	GDE	Classroom 414	M	Blackboard Glue Dots	8030/01/0G/CR/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	GDE	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	GDE	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	GDE	Men's Restroom	N/A	Brick Wall		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F i o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDE	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	GDE	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	GDE	Women's Restroom	N/A	Brick Wall		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDE	Girl's Restroom	N/A	Concrete Floor		Non Suspect ACM	376	SF	0	SF				N/A	N/A	N/A
1	GDE	Girl's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	376	SF	0	SF				N/A	N/A	N/A
1	GDE	Girl's Restroom	N/A	Brick Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	GDE	Boy's Restroom	N/A	Concrete Floor		Non Suspect ACM	376	SF	0	SF				N/A	N/A	N/A
1	GDE	Boy's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	376	SF	0	SF				N/A	N/A	N/A
1	GDE	Boy's Restroom	N/A	Brick Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	1E	Girl's Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	60	LF	0	LF				N/A	N/A	N/A
1	1E	Girl's Restroom	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	4	EA	0	EA				1	No	1/D
1	1E	Girl's Restroom	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	20	EA	0	EA				N/A	N/A	N/A
1	1E	Boy's Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0	LF				N/A	N/A	N/A
1	1E	Boy's Restroom	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	1	EA	0	EA				1	No	1/D
1	1E	Storage Room adjacent to Classroom 409	N/A	Concrete Floor		Non Suspect ACM	360	SF	0	SF				N/A	N/A	N/A
1	1E	Storage Room adjacent to Classroom 409	N/A	Concrete Ceiling		Non Suspect ACM	360	SF	0	SF				N/A	N/A	N/A
1	1E	Storage Room adjacent to Classroom 409	N/A	Brick Wall		Non Suspect ACM	550	SF	0	SF				N/A	N/A	N/A
1	1E	Hallway Classroom 401-414	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1840	SF	0	SF	Multi	Need VAT color		1	No	1/D
1	1E	Hallway Classroom 401-414	N/A	Ceiling Tile 2' x 4'		Non Suspect ACM	1840	SF	0	SF				N/A	N/A	N/A
1	1E	Hallway Classroom 401-414	N/A	Brick Wall		Non Suspect ACM	2300	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Concrete Floor		Non Suspect ACM	270	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Concrete Ceiling		Non Suspect ACM	270	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Brick Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1E	Hallway Classroom 501-514	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1840	SF	0	SF	Multi	Need VAT color		1	No	1/D
1	1E	Hallway Classroom 501-514	N/A	Ceiling Tile 2' x 4'		Non Suspect ACM	1840	SF	8	SF		Water Stains		N/A	N/A	N/A
1	1E	Hallway Classroom 501-514	N/A	Brick Wall		Non Suspect ACM	2300	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Concrete Floor		Non Suspect ACM	270	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Concrete Ceiling		Non Suspect ACM	270	SF	0	SF				N/A	N/A	N/A
1	1E	Stairs adjacent to Bridge	N/A	Brick Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 501	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Tan			1	No	1/D
1	1E	Classroom 501	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 501	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 501	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 503	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Green			1	No	1/D
1	1E	Classroom 503	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	10	SF		Water damage		N/A	N/A	N/A
1	1E	Classroom 503	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 503	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 502	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Green			1	No	1/D
1	1E	Classroom 502	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 502	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 502	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Office adjacent to Classroom 502	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Blue			1	No	1/D
1	1E	Office adjacent to Classroom 502	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Office adjacent to Classroom 502	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 504	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Tan			1	No	1/D
1	1E	Classroom 504	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 504	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 504	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 506	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	884	SF	0	SF	Tan			1	No	1/D
1	1E	Classroom 506	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 506	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 506	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 508	N/A	Carpet		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 508	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 508	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 508	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 510	N/A	Carpet		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 510	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 510	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 510	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Dean's Office	N/A	Carpet		Non Suspect ACM	442	SF	0	SF				N/A	N/A	N/A
1	1E	Dean's Office	N/A	Concrete Ceiling		Non Suspect ACM	442	SF	0	SF				N/A	N/A	N/A
1	1E	Dean's Office	N/A	Brick Wall		Non Suspect ACM	700	SF	0	SF				N/A	N/A	N/A
1	1E	Dean's Office	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Classroom 509	N/A	Carpet		Non Suspect ACM	884	SF	0	SF	Green			N/A	N/A	N/A
1	1E	Classroom 509	N/A	Concrete Ceiling		Non Suspect ACM	884	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 509	N/A	Brick Wall		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1E	Classroom 509	M	Blackboard Glue Dots	8030/01/01/CRI/ML/2600	Assumed	5	SF	0	SF				1	No	1/D
1	1E	Men's Restroom	N/A	Concrete Floor		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	1E	Men's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	1E	Men's Restroom	N/A	Brick Wall		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1E	Women's Restroom	N/A	Concrete Floor		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	1E	Women's Restroom	N/A	Concrete Ceiling		Non Suspect ACM	36	SF	0	SF				N/A	N/A	N/A
1	1E	Women's Restroom	N/A	Brick Wall		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1E	Girl's Restroom	N/A	Concrete Floor		Non Suspect ACM	376	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010						
			Element	Floor	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)

1	1E	Girl's Restroom	N/A	Concrete Ceiling			Non Suspect ACM	376	SF	0	SF					N/A	N/A	N/A
1	1E	Girl's Restroom	N/A	Brick Wall			Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	1E	Boy's Restroom	N/A	Concrete Floor			Non Suspect ACM	376	SF	0	SF					N/A	N/A	N/A
1	1E	Boy's Restroom	N/A	Concrete Ceiling			Non Suspect ACM	376	SF	0	SF					N/A	N/A	N/A
1	1E	Boy's Restroom	N/A	Brick Wall			Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 100	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	368	SF	0	SF	Multi				1	No	1/D
1	1A	Classroom 100	N/A	Concrete Ceiling			Non Suspect ACM	736	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 100	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 100	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	368	SF	0	SF	Multi				1	No	1/D
1	1A	Teacher's Lounge	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	736	SF	0	SF	Grey				1	No	1/D
1	1A	Teacher's Lounge	N/A	Concrete Ceiling			Non Suspect ACM	736	SF	0	SF					N/A	N/A	N/A
1	1A	Teacher's Lounge	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #1	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	288	SF	0	SF	Grey				1	No	1/D
1	1A	Health Suite #1	N/A	Concrete Ceiling			Non Suspect ACM	288	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #1	N/A	Concrete Block Wall			Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #2	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	216	SF	0	SF	Grey				1	No	1/D
1	1A	Health Suite #2	N/A	Concrete Ceiling			Non Suspect ACM	216	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #2	N/A	Concrete Block Wall			Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #3	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	360	SF	0	SF	Multi				1	No	1/D
1	1A	Health Suite #3	N/A	Concrete Ceiling			Non Suspect ACM	360	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #3	N/A	Concrete Block Wall			Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #4	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	143	SF	0	SF	Grey				1	No	1/D
1	1A	Health Suite #4	N/A	Concrete Ceiling			Non Suspect ACM	143	SF	0	SF					N/A	N/A	N/A
1	1A	Health Suite #4	N/A	Concrete Block Wall			Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	1A	Mens Faculty Restroom	N/A	Concrete Floor			Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	1A	Mens Faculty Restroom	N/A	Concrete Ceiling			Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	1A	Mens Faculty Restroom	N/A	Concrete Block Wall			Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1A	Womens Faculty Restroom	N/A	Concrete Floor			Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	1A	Womens Faculty Restroom	N/A	Concrete Ceiling			Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	1A	Womens Faculty Restroom	N/A	Concrete Block Wall			Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1A	Ticket Room	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	25	SF	0	SF	Tan				1	No	1/D
1	1A	Ticket Room	N/A	Concrete Ceiling			Non Suspect ACM	25	SF	0	SF					N/A	N/A	N/A
1	1A	Ticket Room	N/A	Concrete Block Wall			Non Suspect ACM	50	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 156	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	736	SF	0	SF	Green				1	No	1/D
1	1A	Classroom 156	N/A	Concrete Ceiling			Non Suspect ACM	736	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 156	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Kitchen Classroom 156	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	250	SF	0	SF	Tan				1	No	1/D
1	1A	Kitchen Classroom 156	N/A	Concrete Ceiling			Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	1A	Kitchen Classroom 156	N/A	Concrete Block Wall			Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 156 Restroom	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	736	SF	0	SF	Tan				1	No	1/D
1	1A	Classroom 156 Restroom	N/A	Concrete Ceiling			Non Suspect ACM	736	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 156 Restroom	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	650	SF	0	SF	Grey				1	No	1/D
1	1A	Classroom 158	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	75	SF	0	SF	Multi				1	No	1/D
1	1A	Classroom 158	N/A	Ceiling Tile 1" x 1"			NAD	725	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158 Kitchen	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	300	SF	0	SF	Tan				1	No	1/D
1	1A	Classroom 158 Kitchen	N/A	Concrete Ceiling			Non Suspect ACM	300	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158 Kitchen	N/A	Concrete Block Wall			Non Suspect ACM	600	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158 Kitchen Restroom	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	25	SF	0	SF	Tan				1	No	1/D
1	1A	Classroom 158 Kitchen Restroom	N/A	Concrete Ceiling			Non Suspect ACM	25	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 158 Kitchen Restroom	N/A	Concrete Block Wall			Non Suspect ACM	50	SF	0	SF					N/A	N/A	N/A
1	1A	Costume Storage	N/A	Concrete Floor			Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1A	Costume Storage	N/A	Concrete Ceiling			Non Suspect ACM	400	SF	0	SF					N/A	N/A	N/A
1	1A	Costume Storage	N/A	Concrete Block Wall			Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 160	M	Floor Tile VAT 9" x 9"	8030/01/03/35		Confirmed	736	SF	0	SF	Tan				1	No	1/D
1	1A	Classroom 160	N/A	Concrete Ceiling			Non Suspect ACM	736	SF	0	SF					N/A	N/A	N/A
1	1A	Classroom 160	N/A	Concrete Block Wall			Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1A	Auditorium	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	10,500	SF	0	SF	Grey				1	No	1/D
1	1A	Auditorium	N/A	Plaster Ceiling			NAD	13000	SF	0	SF					N/A	N/A	N/A
1	1A	Auditorium	N/A	Concrete Block Wall			Non Suspect ACM	3400	SF	0	SF					N/A	N/A	N/A
1	1A	Auditorium	N/A	Acoustical Plaster Walls			NAD	1450	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Room in Back of Auditorium A	X	X			X	X	X	X	X	X	No access			X	X	X
1	1A	Storage Room in Back of Auditorium B	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	40	SF	0	SF	Grey				1	No	1/D
1	1A	Storage Room in Back of Auditorium B	N/A	Concrete Block Wall			Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Room in Back of Auditorium B	N/A	Metal Deck			Non Suspect ACM	40	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Room in Back of Auditorium B	M	Transite Electrical Panel	8030/01/01/CR/ML/2350		Assumed	14	SF	0	SF					1	No	1/D
1	1A	Storage Room in Back of Auditorium C	M	Floor Tile VAT 12" x 12"	8030/01/01/38		Assumed	40	SF	0	SF	Grey				1	No	1/D
1	1A	Storage Room in Back of Auditorium C	N/A	Concrete Block Wall			Non Suspect ACM	80	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Room in Back of Auditorium C	N/A	Metal Deck			Non Suspect ACM	40	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Room in Back of Auditorium D	X	X			X	X	X	X	X	X	No access			X	X	X
1	1A	Stage	N/A	Wood Floor			Non Suspect ACM	2405	SF	0	SF					N/A	N/A	N/A
1	1A	Stage	N/A	Concrete Ceiling			Non Suspect ACM	2405	SF	0	SF					N/A	N/A	N/A
1	1A	Stage	N/A	Concrete Block Wall			Non Suspect ACM	5000	SF	0	SF					N/A	N/A	N/A
1	1A	Storage Along Right Side of Auditorium	X	X			X	X	X	X	X	X	No Access			X	X	X

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia		AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016					
George Washington High School (9-12)		Room by Room Location Log Report										Building Inspector: Norman Harrison					
10175 Bustleton Avenue, Philadelphia, PA 19116												Certificate Number: ACC-0915-6-011					
ULCS# 8030												Management Planner: Monique Causley					
Year Built: 1963												Certificate Number: ACC-0215-8-010					
E l e m e n t	F i o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)	
1	1A	Storage Along Left Side of Storage	N/A	Plaster Ceiling		NAD	300	SF	35	SF				N/A	N/A	N/A	
1	1A	Storage Along Left Side of Storage	N/A	Concrete Floor		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A	
1	1A	Storage Along Left Side of Storage	N/A	Concrete Block Wall		Non Suspect ACM	550	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Storage	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	175	SF	0	SF	Multi			1	No	1/D	
1	1A	Music Storage	N/A	Concrete Ceiling		Non Suspect ACM	175	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Storage	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 162	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	4802	SF	0	SF	Multi			1	No	1/D	
1	1A	Music Classroom 162	N/A	Ceiling Tile 1' x 1'		NAD	4802	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 162	N/A	Concrete Block Wall		Non Suspect ACM	6000	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 162	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	20	SF	0	SF				1	No	1/D	
1	1A	Music Classroom 162 Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Brown			1	No	1/D	
1	1A	Music Classroom 162 Office	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 162 Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A	
1	1A	Little Music Room Next to Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Little Music Room Next to Office	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Little Music Room Next to Office	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A	
1	1A	Storage Room	X	X		X	X	X	X	X	X	No Access		X	X	X	
1	1A	Girl's Restroom Next to Music Classroom 162	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A	
1	1A	Girl's Restroom Next to Music Classroom 162	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A	
1	1A	Girl's Restroom Next to Music Classroom 162	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A	
1	1A	Boy's Restroom Next to Music Classroom 164	N/A	Concrete Floor		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A	
1	1A	Boy's Restroom Next to Music Classroom 164	N/A	Concrete Ceiling		Non Suspect ACM	266	SF	0	SF				N/A	N/A	N/A	
1	1A	Boy's Restroom Next to Music Classroom 164	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #1	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #1	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #1	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #2	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #2	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #2	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #3	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #3	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #3	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #4	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #4	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #4	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #5	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #5	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #5	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #6	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #6	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #6	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #7	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	100	SF	0	SF	Brown			1	No	1/D	
1	1A	Practice Room #7	N/A	Ceiling Tile 1' x 1'		NAD	100	SF	0	SF				N/A	N/A	N/A	
1	1A	Practice Room #7	N/A	Concrete Block Wall		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway between Practice Rooms	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	225	SF	0	SF	Brown			1	No	1/D	
1	1A	Hallway between Practice Rooms	N/A	Ceiling Tile 1' x 1'		NAD	225	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway between Practice Rooms	N/A	Concrete Block Wall		Non Suspect ACM	550	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 164	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	4802	SF	0	SF	Multi			1	No	1/D	
1	1A	Music Classroom 164	N/A	Ceiling Tile 1' x 1'		NAD	4802	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 164	N/A	Concrete Block Wall		Non Suspect ACM	6000	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 164	M	Transite Sills	8030/01/01/CR/1H/2300	Assumed	20	SF	0	SF				1	No	1/D	
1	1A	Music Classroom 164 Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Brown			1	No	1/D	
1	1A	Music Classroom 164 Office	N/A	Ceiling Tile 1' x 1'		NAD	200	SF	0	SF				N/A	N/A	N/A	
1	1A	Music Classroom 164 Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway in Front of Auditorium	N/A	Terrazzo Floor		Non Suspect ACM	2700	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway in Front of Auditorium	N/A	Ceiling Tile 1' x 1'		NAD	2700	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway in Front of Auditorium	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 156 to 160	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2850	SF	0	SF	Multi			1	No	1/D	
1	1A	Hallway from Classroom 156 to 160	N/A	Ceiling Tile 1' x 1'		NAD	2850	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 156 to 160	N/A	Concrete Block Wall		Non Suspect ACM	3200	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 156 to 160	T	Radiator Insulation	8030/01/01/CR/1M/1600	Assumed	24	SF	0	SF				1	No	1/D	
1	1A	Hallway from Classroom 162 to 164	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2500	SF	0	SF	Multi			1	No	1/D	
1	1A	Hallway from Classroom 162 to 164	N/A	Ceiling Tile 1' x 1'		NAD	2500	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 162 to 164	N/A	Concrete Block Wall		Non Suspect ACM	2800	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 162 to 164	T	Radiator Insulation	8030/01/01/CR/1M/1600	Assumed	24	SF	0	SF				1	No	1/D	
1	1A	Hallway from Classroom 100 to Ticket Room	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	2500	SF	0	SF	Multi			1	No	1/D	
1	1A	Hallway from Classroom 100 to Ticket Room	N/A	Ceiling Tile 1' x 1'		NAD	2500	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 100 to Ticket Room	N/A	Concrete Block Wall		Non Suspect ACM	2800	SF	0	SF				N/A	N/A	N/A	
1	1A	Hallway from Classroom 100 to Ticket Room	T	Radiator Insulation	8030/01/01/CR/1M/1600	Assumed	24	SF	0	SF				1	No	1/D	
1	1D	Classroom 132	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	1100	SF	0	SF	Brown			1	No	1/D	
1	1D	Classroom 132	N/A	Concrete Ceiling		Non Suspect ACM	1100	SF	0	SF				N/A	N/A	N/A	
1	1D	Classroom 132	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A	
1	1D	Classroom 132 Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Brown			1	No	1/D	
1	1D	Classroom 132 Office	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A	
1	1D	Classroom 132 Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A	

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
Element	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1D	Storage next to Classroom 132 Office	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1D	Storage next to Classroom 132 Office	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	1D	Storage next to Classroom 132 Office	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1D	Large Storage in Classroom 132	N/A	Concrete Floor		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1D	Large Storage in Classroom 132	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1D	Large Storage in Classroom 132	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 Electrical Shop	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	1100	SF	0	SF	Grey			1	No	1/D
1	1D	Classroom 134 Electrical Shop	N/A	Concrete Ceiling		Non Suspect ACM	1100	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 Electrical Shop	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 Electrical Shop Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Brown			1	No	1/D
1	1D	Classroom 134 Electrical Shop Office	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 Electrical Shop Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 & 136 Storage	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	250	SF	0	SF	Brown			1	No	1/D
1	1D	Classroom 134 & 136 Storage	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 & 136 Storage	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 134 & 136 Storage	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0	LF				N/A	N/A	N/A
1	1D	Classroom 134 & 136 Storage	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	9	Ea	0	EA				1	No	1/D
1	1D	Classroom 134 & 136 Storage	M	Vibration Damper Cloth	8030/01/01/11	Assumed	4	SF	0	SF				1	No	1/D
1	1D	Classroom 136	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	1300	SF	0	SF	Brown			1	No	1/D
1	1D	Classroom 136	N/A	Concrete Ceiling		Non Suspect ACM	1300	SF	0	SF				N/A	N/A	N/A
1	1D	Classroom 136	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138	N/A	Concrete Floor		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138	N/A	Concrete Ceiling		Non Suspect ACM	1200	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138 Storage	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138 Storage	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	1D	Weight Room 138 Storage	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	1D	Training Room 140	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	900	SF	0	SF	Brown			1	No	1/D
1	1D	Training Room 140	N/A	Concrete Ceiling		Non Suspect ACM	900	SF	0	SF				N/A	N/A	N/A
1	1D	Training Room 140	N/A	Concrete Block Wall		Non Suspect ACM	1800	SF	0	SF				N/A	N/A	N/A
1	1D	Training Room 140	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	Ea	0	EA				1	No	1/D
1	1D	Girls Locker Room	X	X		X	X	X	X	X	X	No access		X	X	X
1	1D	Dance 142C	N/A	Wood Floor		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	1D	Dance 142C	N/A	Concrete Ceiling		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	1D	Dance 142C	N/A	Concrete Block Wall		Non Suspect ACM	3500	SF	0	SF				N/A	N/A	N/A
1	1D	Dance 142C	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	2	Ea	0	EA				1	No	1/D
1	1D	Room 144B	N/A	Concrete Floor		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144B	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144B	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144A	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Tan			1	No	1/D
1	1D	Room 144A	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144A	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	700	SF	0	SF	Brown			1	No	1/D
1	1D	Room 144	N/A	Concrete Ceiling		Non Suspect ACM	700	SF	0	SF				N/A	N/A	N/A
1	1D	Room 144	N/A	Concrete Block Wall		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	1D	Basketball Gym(Gym 1 & 2 Combined)	N/A	Wood Floor		Non Suspect ACM	7500	SF	0	SF				N/A	N/A	N/A
1	1D	Basketball Gym(Gym 1 & 2 Combined)	N/A	Concrete Ceiling		Non Suspect ACM	7500	SF	0	SF				N/A	N/A	N/A
1	1D	Basketball Gym(Gym 1 & 2 Combined)	N/A	Concrete Block Wall		Non Suspect ACM	6000	SF	0	SF				N/A	N/A	N/A
1	1D	Basketball Gym(Gym 1 & 2 Combined)	N/A	Partition Room Dividers		Non Suspect ACM	1800	SF	0	SF				N/A	N/A	N/A
1	1D	Gym Storage	N/A	Concrete Floor		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1D	Gym Storage	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1D	Gym Storage	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 2 Office	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	200	SF	0	SF	Tan			1	No	1/D
1	1D	Gym 2 Office	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 2 Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Gym Storage	X	X		X	X	X	X	X	X	No Access		X	X	X
1	1D	Gym 3	N/A	Wood Floor		Non Suspect ACM	3500	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 3	N/A	Concrete Ceiling		Non Suspect ACM	3500	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 3	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 3	N/A	Partition Room Dividers		Non Suspect ACM	900	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 3 Storage	X	X		X	X	X	X	X	X	No Access		X	X	X
1	1D	Gym 3 Office	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	200	SF	0	SF	Blue			1	No	1/D
1	1D	Gym 3 Office	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 3 Office	N/A	Concrete Block Wall		Non Suspect ACM	400	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 4	N/A	Wood Floor		Non Suspect ACM	3500	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 4	N/A	Concrete Ceiling		Non Suspect ACM	3500	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 4	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	1D	Gym 4 Storage	X	X		X	X	X	X	X	X	No Access		X	X	X
1	1D	Mini Hallway Connecting Gym 3 and 4	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	300	SF	0	SF	Tan			1	No	1/D
1	1D	Mini Hallway Connecting Gym 3 and 4	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	1D	Mini Hallway Connecting Gym 3 and 4	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	1D	Room F4-3	X	X		X	X	X	X	X	X	No Access		X	X	X
1	1D	Teacher Office 142A	N/A	Concrete Floor		Non Suspect ACM	400	SF	10	SF		Check Space Number Next Inspection, water damage		N/A	N/A	N/A
1	1D	Teacher Office 142A	N/A	Concrete Ceiling		Non Suspect ACM	400	SF	0	SF		Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Teacher Office 142A	N/A	Concrete Block Wall		Non Suspect ACM	800	SF	0	SF		Check Space Number Next Inspection		N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010				
Element	Floor	Room	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	1D	Teacher Office 142A	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	1	EA	0	EA			Check Space Number Next Inspection		1	No	1/D
1	1D	Storage Next to Teacher Office 142A	N/A	Concrete Floor		Non Suspect ACM	200	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Storage Next to Teacher Office 142A	N/A	Concrete Ceiling		Non Suspect ACM	200	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Storage Next to Teacher Office 142A	N/A	Ceramic Tile Walls		Non Suspect ACM	400	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Restroom in Teacher Office 142A	N/A	Concrete Floor		Non Suspect ACM	50	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Restroom in Teacher Office 142A	N/A	Concrete Ceiling		Non Suspect ACM	50	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Restroom in Teacher Office 142A	N/A	Ceramic Tile Walls		Non Suspect ACM	100	SF	0	SF			Check Space Number Next Inspection		N/A	N/A	N/A
1	1D	Classroom 146	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	700	SF	0	SF	Tan				1	No	1/D
1	1D	Classroom 146	N/A	Concrete Ceiling		Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1D	Classroom 146	N/A	Concrete Block Wall		Non Suspect ACM	1400	SF	0	SF					N/A	N/A	N/A
1	1D	Classroom 146	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	1	EA	0	EA					1	No	1/D
1	1D	Classroom 146	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	12	LF	0	LF					N/A	N/A	N/A
1	1D	Classroom 146	M	Transite Sills	8030/01/01/CR/IIH/2300	Assumed	25	SF	0	SF					1	No	1/D
1	1D	Room 148	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	700	SF	0	SF	Tan				1	No	1/D
1	1D	Room 148	N/A	Concrete Ceiling		Non Suspect ACM	700	SF	0	SF					N/A	N/A	N/A
1	1D	Room 148	N/A	Concrete Block Wall		Non Suspect ACM	1400	SF	0	SF					N/A	N/A	N/A
1	1D	Weight Room 158	N/A	Carpet		Non Suspect ACM	1000	SF	0	SF					N/A	N/A	N/A
1	1D	Weight Room 158	M	Floor Tile VAT 9" x 9"	8030/01/03/35	Confirmed	1000	SF	0	SF	Tan		Underneath Carpet		1	No	1/D
1	1D	Weight Room 158	N/A	Ceiling Tile 1" x 1"		NAD	1000	SF	0	SF					N/A	N/A	N/A
1	1D	Weight Room 158	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF					N/A	N/A	N/A
1	1D	Weight Room 158	M	Black Glue Dots A/W Mirror	8030/01/01/CR/II/2600	Assumed	50	SF	20	SF					1	No	6/C
1	1D	Closet in Weight Room 158	N/A	Concrete Floor		Non Suspect ACM	25	SF	0	SF					N/A	N/A	N/A
1	1D	Closet in Weight Room 158	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF					N/A	N/A	N/A
1	1D	Closet in Weight Room 158	N/A	Concrete Block Wall		Non Suspect ACM	50	SF	0	SF					N/A	N/A	N/A
1	1D	Closet in Weight Room 158	T	Pipe Fitting Insulation	8030/01/01/37	Confirmed	5	EA	0	EA					1	No	1/D
1	1D	Closet in Weight Room 158	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	25	LF	0	LF					N/A	N/A	N/A
1	1D	Closet in Weight Room 158	M	Vibration Damper Cloth	8030/01/01/11	Assumed	16	SF	0	SF					1	No	1/D
1	1D	Section D 1st Floor Hallway	M	Floor Tile VAT 12" x 12"	8030/01/01/38	Assumed	7000	SF	0	SF	Multi				1	No	1/D
1	1D	Section D 1st Floor Hallway	N/A	Concrete Ceiling		Non Suspect ACM	7000	SF	0	SF					N/A	N/A	N/A
1	1D	Section D 1st Floor Hallway	N/A	Concrete Block Wall		Non Suspect ACM	4000	SF	0	SF					N/A	N/A	N/A
1	1D	Section D 1st Floor Hallway	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	18	EA	0	EA					N/A	N/A	N/A
1	1D	Section D 1st Floor Hallway	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF					N/A	N/A	N/A
1	1D	Section D 1st Floor Hallway	T	Radiator Insulation	8030/01/01/CR/II/1600	Assumed	60	SF	0	SF					1	No	1/D
1	GDD	Classroom 16	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1200	SF	0	SF	Red				1	No	1/D
1	GDD	Classroom 16	N/A	Concrete Ceiling		Non Suspect ACM	1200	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 16	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 16	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	22	EA	0	EA					1	No	1/D
1	GDD	Classroom 16	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	56	LF	0	LF					N/A	N/A	N/A
1	GDD	Storage in Classroom 16	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	120	SF	0	SF	Red				1	No	1/D
1	GDD	Storage in Classroom 16	N/A	Concrete Ceiling		Non Suspect ACM	120	SF	0	SF					N/A	N/A	N/A
1	GDD	Storage in Classroom 16	N/A	Concrete Block Wall		Non Suspect ACM	240	SF	0	SF					N/A	N/A	N/A
1	GDD	Storage in Classroom 16	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	1	EA	0	EA					1	No	1/D
1	GDD	Storage in Classroom 16	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	22	LF	0	LF					N/A	N/A	N/A
1	GDD	Other Storage in Classroom 16	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	100	SF	0	SF	Red				1	No	1/D
1	GDD	Other Storage in Classroom 16	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF					N/A	N/A	N/A
1	GDD	Other Storage in Classroom 16	N/A	Concrete Block Wall		Non Suspect ACM	200	SF	0	SF					N/A	N/A	N/A
1	GDD	Other Storage in Classroom 16	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	3	EA	0	EA					1	No	1/D
1	GDD	Other Storage in Classroom 16	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	32	LF	0	LF					N/A	N/A	N/A
1	GDD	Office in Classroom 16	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	250	SF	0	SF	Red				1	No	1/D
1	GDD	Office in Classroom 16	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDD	Office in Classroom 16	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	GDD	Office in Classroom 16	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	14	EA	0	EA					1	No	1/D
1	GDD	Office in Classroom 16	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	30	LF	0	LF					N/A	N/A	N/A
1	GDD	Office in Classroom 16	M	Vibration Damper Cloth	8030/01/0G/EE	Assumed	4	SF	0	SF					1	No	1/D
1	GDD	Classroom 18	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	1300	SF	10	SF	Multi				1	No	6/C
1	GDD	Classroom 18	N/A	Concrete Ceiling		Non Suspect ACM	1300	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18	N/A	Concrete Block Wall		Non Suspect ACM	2400	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	14	EA	0	EA					1	No	1/D
1	GDD	Classroom 18	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	56	LF	0	LF					N/A	N/A	N/A
1	GDD	Classroom 18 Storage	N/A	Concrete Floor		Non Suspect ACM	150	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Storage	N/A	Concrete Ceiling		Non Suspect ACM	150	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Storage	N/A	Concrete Block Wall		Non Suspect ACM	300	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Storage	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	4	EA	0	EA					1	No	1/D
1	GDD	Classroom 18 Storage	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	18	LF	0	LF					N/A	N/A	N/A
1	GDD	Classroom 18 Middle Storage	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Middle Storage	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Middle Storage	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Office	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	175	SF	0	SF	Tan				1	No	1/D
1	GDD	Classroom 18 Office	N/A	Concrete Ceiling		Non Suspect ACM	175	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Office	N/A	Concrete Block Wall		Non Suspect ACM	350	SF	0	SF					N/A	N/A	N/A
1	GDD	Classroom 18 Office	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	3	EA	0	EA					1	No	1/D
1	GDD	Classroom 18 Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	8	LF	0	LF					N/A	N/A	N/A
1	GDD	Room Next to 18	X	X		X	X	X	X	X	X		No Access		X	X	X
1	GDD	REC Room	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	5000	SF	0	SF	Multi				1	No	1/D
1	GDD	REC Room	N/A	Ceiling Tile 1" x 1"		NAD	5000	SF	0	SF					N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia			AHERA Three-Year Reinspection 2015-2016										Reinspection Date: 02/09/2016			
George Washington High School (9-12)			Room by Room Location Log Report										Building Inspector: Norman Harrison			
10175 Bustleton Avenue, Philadelphia, PA 19116													Certificate Number: ACC-0915-6-011			
ULCS# 8030													Management Planner: Monique Causley			
Year Built: 1963													Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDD	REC Room	N/A	Concrete Block Wall		Non Suspect ACM	6000	SF	0	SF				N/A	N/A	N/A
1	GDD	REC Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	14	EA	0	EA				1	No	1/D
1	GDD	REC Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	200	LF	14	LF				N/A	N/A	N/A
1	GDD	REC Room	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	8	EA	3	EA				N/A	N/A	N/A
1	GDD	Cafeteria	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	13200	SF	0	SF	Multi			1	No	1/D
1	GDD	Cafeteria	N/A	Metal Ceiling Panels		Non Suspect ACM	13200	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria	N/A	Concrete Block Wall		Non Suspect ACM	4500	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Serving Area	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	2000	SF	0	SF	Multi			1	No	1/D
1	GDD	Cafeteria Serving Area	N/A	Metal Ceiling Panels		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Serving Area	N/A	Concrete Block Wall		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Kitchen	N/A	Concrete Floor		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Kitchen	N/A	Concrete Ceiling		Non Suspect ACM	800	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Kitchen	N/A	Concrete Block Wall		Non Suspect ACM	1600	SF	0	SF				N/A	N/A	N/A
1	GDD	Cafeteria Kitchen	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	32	EA	3	EA		Spray painted orange		1	Yes	2/B
1	GDD	Cafeteria Kitchen	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	80	LF	0	LF				N/A	N/A	N/A
1	GDD	Cafeteria Kitchen	M	Vibration Damper Cloth	8030/01/0G/EE	Assumed	10	SF	0	SF				1	No	1/D
1	GDD	Cafeteria Kitchen	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	26	SF	0	SF				1	No	1/D
1	GDD	Kitchen Office	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	85	SF	5	SF	Tan	Cracked Tiles		1	No	6/C
1	GDD	Kitchen Office	N/A	Concrete Ceiling		Non Suspect ACM	85	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Office	N/A	Concrete Block Wall		Non Suspect ACM	170	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Office	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	9	EA	0	EA		Spray painted orange		1	No	1/D
1	GDD	Kitchen Office	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	0	LF				N/A	N/A	N/A
1	GDD	Kitchen Office Restroom	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	25	SF	0	SF	Tan			1	No	1/D
1	GDD	Kitchen Office Restroom	N/A	Concrete Ceiling		Non Suspect ACM	25	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Office Restroom	N/A	Concrete Block Wall		Non Suspect ACM	50	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Office Storage	M	Floor Tile VAT 9" x 9"	8030/01/0G/05	Confirmed	15	SF	0	SF	Tan			1	No	1/D
1	GDD	Kitchen Office Storage	N/A	Concrete Ceiling		Non Suspect ACM	15	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Office Storage	N/A	Concrete Block Wall		Non Suspect ACM	30	SF	0	SF				N/A	N/A	N/A
1	GDD	Kitchen Fridge	X	X		X	X	X	X	X	X	No Access		X	X	X
1	GDD	Compressor Room	N/A	Concrete Floor		Non Suspect ACM	45	SF	0	SF				N/A	N/A	N/A
1	GDD	Compressor Room	N/A	Concrete Ceiling		Non Suspect ACM	45	SF	0	SF				N/A	N/A	N/A
1	GDD	Compressor Room	N/A	Concrete Block Wall		Non Suspect ACM	90	SF	0	SF				N/A	N/A	N/A
1	GDD	Compressor Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	13	EA	0	EA				1	No	1/D
1	GDD	Compressor Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	20	LF	0	LF				N/A	N/A	N/A
1	GDD	Compressor Room	M	Transite Electrical Panel	8030/01/0G/CR/ML/2350	Assumed	50	SF	0	SF				1	No	1/D
1	GDD	Ladies Locker Room	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	GDD	Ladies Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	GDD	Ladies Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	GDD	Ladies Locker Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	25	EA	0	EA				1	No	1/D
1	GDD	Ladies Locker Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	7	LF	0	LF				N/A	N/A	N/A
1	GDD	Ladies Locker Room Restroom	N/A	Concrete Floor		Non Suspect ACM	30	SF	0	SF				N/A	N/A	N/A
1	GDD	Ladies Locker Room Restroom	N/A	Concrete Ceiling		Non Suspect ACM	30	SF	0	SF				N/A	N/A	N/A
1	GDD	Ladies Locker Room Restroom	N/A	Concrete Block Wall		Non Suspect ACM	60	SF	0	SF				N/A	N/A	N/A
1	GDD	Mens Restroom Next to Ladies Locker Room	N/A	Concrete Floor		Non Suspect ACM	30	SF	0	SF				N/A	N/A	N/A
1	GDD	Mens Restroom Next to Ladies Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	30	SF	0	SF				N/A	N/A	N/A
1	GDD	Mens Restroom Next to Ladies Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	60	SF	0	SF				N/A	N/A	N/A
1	GDD	Mens Restroom Next to Ladies Locker Room	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	4	SF	0	SF				1	No	1/D
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	N/A	Concrete Floor		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	N/A	Concrete Block Wall		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	16	EA	0	EA				1	No	1/D
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	12	SF	0	SF				1	No	1/D
1	GDD	Mini Hallway from Kitchen to Ladies Locker Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	50	LF	0	LF				N/A	N/A	N/A
1	GDD	The Beacon	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	1400	SF	0	SF	Green			1	No	1/D
1	GDD	The Beacon	N/A	Metal Ceiling Panels		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	GDD	The Beacon	N/A	Concrete Block Wall		Non Suspect ACM	2100	SF	0	SF				N/A	N/A	N/A
1	GDD	The Beacon	M	Transite Sills	8030/01/0G/CR/IIH/2300	Assumed	30	SF	0	SF				1	No	1/D
1	GDD	The Beacon	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	51	EA	0	EA				1	No	1/D
1	GDD	The Beacon	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	120	LF	0	LF				N/A	N/A	N/A
1	GDD	Student Restroom #1	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	35	SF	10	SF	Green			1	No	6/C
1	GDD	Student Restroom #1	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	GDD	Student Restroom #1	N/A	Concrete Block Wall		Non Suspect ACM	70	SF	0	SF				N/A	N/A	N/A
1	GDD	Student Restroom #2	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	35	SF	0	SF	Green			1	No	1/D
1	GDD	Student Restroom #2	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	GDD	Student Restroom #2	N/A	Concrete Block Wall		Non Suspect ACM	70	SF	0	SF				N/A	N/A	N/A
1	GDD	Staff Restroom	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	35	SF	0	SF	Green			1	No	1/D
1	GDD	Staff Restroom	N/A	Fiberglass Ceiling Tile 2' x 4'		Non Suspect ACM	35	SF	0	SF				N/A	N/A	N/A
1	GDD	Staff Restroom	N/A	Concrete Block Wall		Non Suspect ACM	70	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room	N/A	Concrete Floor		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room	N/A	Concrete Ceiling		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room	N/A	Concrete Block Wall		Non Suspect ACM	2200	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	37	EA	1	EA				1	Yes	2/B
1	GDD	Locker Room Across from REC Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	75	LF	0	LF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Across from REC Room Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A

8030 George Washington HS 2015-2016 AHERA Three Year Report

School District of Philadelphia George Washington High School (9-12) 10175 Bustleton Avenue, Philadelphia, PA 19116 ULCS# 8030 Year Built: 1963			AHERA Three-Year Reinspection 2015-2016 Room by Room Location Log Report										Reinspection Date: 02/09/2016 Building Inspector: Norman Harrison Certificate Number: ACC-0915-6-011 Management Planner: Monique Causley Certificate Number: ACC-0215-8-010			
E l e m e n t	F l o o r	On-Site Room Name	System Affected	Material Description	HID#	Confirmed, Assumed, NAD, Non Suspect ACM	Amount of Material	SF LF EA	Amount of Damage	SF LF EA	Color required for VAT	Comments/Description/Notes	Attic Crawl Space Ranking	Damage Potential (DP)	Newly Friable (NF)	Response Action (RA)
1	GDD	Locker Room Across from REC Room Restroom	N/A	Ceramic Tile Walls		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room	N/A	Concrete Floor		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room	N/A	Concrete Ceiling		Non Suspect ACM	1400	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room	N/A	Concrete Block Wall		Non Suspect ACM	2200	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	37	EA	0	EA				1	No	1/D
1	GDD	Locker Room Next to Beacon Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	75	LF	0	LF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room Restroom	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room Restroom	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	GDD	Locker Room Next to Beacon Room Restroom	N/A	Ceramic Tile Walls		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	GDD	Section D Ground Hallway	M	Floor Tile VAT 12" x 12"	8030/01/03/A6	Assumed	6000	SF	0	SF	Multi			1	No	1/D
1	GDD	Section D Ground Hallway	N/A	Concrete Ceiling		Non Suspect ACM	6000	SF	0	SF				N/A	N/A	N/A
1	GDD	Section D Ground Hallway	N/A	Concrete Block Wall		Non Suspect ACM	3000	SF	0	SF				N/A	N/A	N/A
1	GDD	Section D Ground Hallway	T	Pipe Fitting Insulation	8030/01/0G/22	Confirmed	3	EA	0	EA				1	No	1/D
1	GDD	Section D Ground Hallway	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	4	LF	0	LF				N/A	N/A	N/A
1	GDD	Section D Ground Hallway	T	Radiator Insulation	8030/01/0G/CRI/ML/1600	Assumed	60	SF	0	SF				1	No	1/D
1	BSD	Boiler Room	N/A	Concrete Floor		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	BSD	Boiler Room	N/A	Concrete Ceiling		Non Suspect ACM	2000	SF	0	SF				N/A	N/A	N/A
1	BSD	Boiler Room	N/A	CMU		Non Suspect ACM	4500	SF	0	SF				N/A	N/A	N/A
1	BSD	Boiler Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	350	LF	0	LF				N/A	N/A	N/A
1	BSD	Boiler Room	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	110	EA	0	EA				N/A	N/A	N/A
1	BSD	Long Room Next to Boiler Room	N/A	Concrete Floor		Non Suspect ACM	4000	SF	0	SF				N/A	N/A	N/A
1	BSD	Long Room Next to Boiler Room	N/A	Concrete Ceiling		Non Suspect ACM	4000	SF	0	SF				N/A	N/A	N/A
1	BSD	Long Room Next to Boiler Room	N/A	CMU		Non Suspect ACM	4500	SF	0	SF				N/A	N/A	N/A
1	BSD	Long Room Next to Boiler Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	300	LF	0	LF				N/A	N/A	N/A
1	BSD	Long Room Next to Boiler Room	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	50	EA	0	EA				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	N/A	Concrete Floor		Non Suspect ACM	900	SF	0	SF				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	N/A	Concrete Ceiling		Non Suspect ACM	900	SF	0	SF				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	N/A	CMU		Non Suspect ACM	1800	SF	0	SF				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	100	LF	0	LF				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	N/A	Fiberglass Pipe Fitting Insulation		Non Suspect ACM	30	EA	0	EA				N/A	N/A	N/A
1	BSD	Room Next to Boiler Room	T	Pipe Fitting Insulation	8030/01/0B/09	Confirmed	7	EA	0	EA				1	No	1/D
1	BSD	Old Restroom	N/A	Concrete Floor		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Restroom	N/A	Concrete Ceiling		Non Suspect ACM	300	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Restroom	N/A	CMU		Non Suspect ACM	600	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Restroom	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	10	LF	10	LF				N/A	N/A	N/A
1	BSD	Old Restroom	T	Pipe Fitting Insulation	8030/01/0B/09	Confirmed	2	EA	0	EA				1	No	1/D
1	BSD	Room Next to Old Restroom	X	X		X	X	X	X	X	X	No Access		X	X	X
1	BSD	Room Across from Old Restroom	X	X		X	X	X	X	X	X	No Access		X	X	X
1	BSD	Old Pump Room	N/A	Concrete Floor		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Pump Room	N/A	Concrete Ceiling		Non Suspect ACM	100	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Pump Room	N/A	CMU		Non Suspect ACM	200	SF	0	SF				N/A	N/A	N/A
1	BSD	Old Pump Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	28	LF	8	LF		Water Stained		N/A	N/A	N/A
1	BSD	Hallway from Old Restroom to Old Pump Room	N/A	Concrete Floor		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	BSD	Hallway from Old Restroom to Old Pump Room	N/A	Concrete Ceiling		Non Suspect ACM	250	SF	0	SF				N/A	N/A	N/A
1	BSD	Hallway from Old Restroom to Old Pump Room	N/A	CMU		Non Suspect ACM	500	SF	0	SF				N/A	N/A	N/A
1	BSD	Hallway from Old Restroom to Old Pump Room	N/A	Fiberglass Pipe Insulation		Non Suspect ACM	15	LF	0	LF				N/A	N/A	N/A
1	CSA	Crawl Space C	X	X		X	X	X	X	X	X	Access Restricted Crawlspace Sealed	No Ranking	X	X	X
1	CSC	Crawl Space A	X	X		X	X	X	X	X	X	Access Restricted Crawlspace Sealed	No Ranking	X	X	X
1	A	Attic- Closet/Rear of Gym	X	X		X	X	X	X	X	X		A	X	X	X

Section III Certificates

A. Management Planner/Building Inspector Certificates

Section III – A

Management Planner/Building Inspector Certificates

These charts indicate the Name, Course Date, Expiration Date and Corresponding Certificate Number of the Management Planner and Building Inspector of individuals that participated in the AHERA 3 Year Inspection and Management Plan process of 2015/2016.

Management Planner	Date Granted	Expiration Date	Certificate Number
Monique Causley	2/15/2015	2/16/2016	ACC-0215-8-010
Monique Causley	2/16/2016	2/17/2017	ACC-0216-8-001
Megan Vala	5/22/2015	6/22/2016	740728
Mary Anne Lerro	4/5/2016	4/5/2017	742327

Building Inspector	Date Granted	Expiration Date	Certificate Number
Scott Magee	8/15/2015	8/15/2016	70016699C
William Garrity	8/15/2015	8/15/2016	70016699A
Bernard Brunner	10/2/2015	8/2/2016	45397
Mary Anne Lerro	3/3/2015	3/3/2016	740092
Mary Anne Lerro	4/5/2016	4/5/2017	742322
James Madden	12/11/2014	12/11/2015	ACC-1214-6-010
James Madden	12/3/2015	12/3/2016	ACC-1215-6-018
Troy Ray	3/15/2015	3/19/2016	ACC-0355-6-011
Ananth Vinjamuri	9/29/2015	9/29/2016	374
Shelton Williams	9/29/2015	9/29/2016	375
Paul Davis	2/12/2015	2/12/2016	ACC-0215-6-015
Paul Davis	2/2/2016	2/2/2017	741836
Bernard Bryson	2/16/2015	2/16/2016	ACC-0125-6-031
Bernard Bryson	2/15/2016	2/15/2017	ACC-0216-6-005
Alexander Roman	9/18/2015	9/18/2016	EHSBIR-150619-008
Norm Harrison	9/2/2015	9/2/2016	ACC-0915-6-011
Kelly Mayberry	2/20/2015	2/20/2016	EHSBIR-150220-005
Kelly Mayberry	2/18/2016	2/18/2017	EHSBIR-160218-006
Andrew Hine	5/6/2015	5/6/2016	AI05042015-3
Maryellen Leotta	2/12/2015	2/12/2016	ACC-0215-6-024

Certificate of Completion

awarded to

Monique Causley

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Management Planner Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/16/15

Course Date

N/A

Exam Date

2/16/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-8-010

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Completion

awarded to

Monique Causley

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Management Planner Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/15/16

Course Date

N/A

Exam Date

2/15/17

Expiration Date

Not Provided

Social Security Number

ACC-0216-8-001

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Megan Vala

HAS SUCCESSFULLY COMPLETED A 16 HOUR COURSE ENTITLED

Asbestos Management Planner Initial

INCLUDING CLASSROOM INSTRUCTION

05/21/2015 to 05/22/2015

Exam passed on this 22nd day of May 2015 - Score - 94

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:



James A. Welts, CIH, President

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Management Planner Refresher

INCLUDING CLASSROOM INSTRUCTION


on this 5th day of April 2016

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:



James A. Welts, CIH, President

EMSL ANALYTICAL, INC.

Certifies that

Scott Magee

has successfully completed the course of study for the

Asbestos Building Inspector Refresher Course

for Accreditation under TSCA Title II

EMSL Certificate No. 70016699C


Approved by:

PA Dept. of Labor and Industry
Accreditation # 137

Course Date: 8/15/2015
Granted: 8/15/2015
Expiration Date: 8/15/2016

Sponsored by:

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
Phone: (800) 220-3675
Fax: (856) 786-5973
www.emsl.com



Michael P. Menz

Michael P. Menz, CIH
Training Director

Environmental, Mold, Bacteria, IAQ, Asbestos, Lead, Forensic and Materials Testing Since 1981

EMSL ANALYTICAL, INC.

Certifies that

William Garrity

has successfully completed the course of study for the

Asbestos Building Inspector Refresher Course for Accreditation under TSCA Title II

EMSL Certificate No. 70016699A


Approved by:

PA Dept. of Labor and Industry
Accreditation # 137

Course Date: 8/15/2015
Granted: 8/15/2015
Expiration Date: 8/15/2016

Sponsored by:

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
Phone: (800) 220-3675
Fax: (856) 786-5973
www.emsl.com



Michael P. Menz

Michael P. Menz, CIH
Training Director

Environmental, Mold, Bacteria, IAQ, Asbestos, Lead, Forensic and Materials Testing Since 1981

45397

National Asbestos & Environmental Training Institute

CERTIFICATE OF COMPLETION

AHERA/EPA Accredited Per 40 CFR Part 763
Asbestos Accreditation under TSCA Title II

This is to certify that


Bernard Brunner, Jr.

Successfully completed the course entitled

**1/2-Day New York State/EPA/AHERA Asbestos Building Inspector Annual Refresher on
October 2, 2015**

Examination Passed October 2, 2015

Expiration Date on October 2, 2016


Doris L. Adler
President, NAEETI

Per 10 NYCRR Part 73.2 (L) (1), DOH 2832 Certificate of Completion of Asbestos
Safety Training is the only official record of training for N.Y.S. students.

Language: English

ABIH 1/2 CM POINT

3321 Doris Avenue, Building B, Ocean, NJ 07712

Phone (732) 531-5571

Fax (732) 531-5956

www.naeti.com

Number 740092

Expiration Date:
03/03/2016

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Building Inspector Refresher

on this 3rd day of March 2015

Exam passed on this 3rd day of March 2015 - Score - 84

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:

James A. Welts
James A. Welts, CIH, President

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Mary Anne Lerro

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Building Inspector Refresher

INCLUDING CLASSROOM INSTRUCTION

on this 5th day of April 2016

Exam passed on this 5th day of April 2016 - Score - 88

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:



James A. Welts, CIH, President

Certificate of Completion

James Madden

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

12/11/14

Course Date

N/A

Exam Date

12/11/15

Expiration Date

Not Provided

Social Security Number

ACC-1214-6-010

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Completion

James Madden

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

12/3/15

Course Date

N/A

Exam Date

12/3/16

Expiration Date

Not Provided

Social Security Number

ACC-1215-6-018

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Completion

Troy A. Ray


for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

3/19/15	N/A	3/19/16
<i>Course Date</i>	<i>Exam Date</i>	<i>Expiration Date</i>
Not Provided	ACC-0355-6-011	
<i>Social Security Number</i>	<i>Certificate Number</i>	Mark K. Schlager <i>Training Director</i>

CERTIFICATE NO 374

G&C Environmental Services, Inc. (#294)
2 Street Road, Newtown Square, Pennsylvania 19073
Telephone: (610) 993-9202 Facsimile: (610) 993-9232
Email: Training@gcenviro.com
www.GCenviro.com

This document certifies that Ananth K. Vinjamuri has successfully completed this
State of New York Department of Health Approved AHERA BUILDING INSPECTOR

REFRESHER COURSE, completed as required for asbestos accreditation under the Toxic

Substances Control Act, Title II. This course was held from 09/29/2015 to 09/29/2015.
MM DD YR MM DD YR

The examination date was 09/29/2015. This certificate expires one year from the date of
MM DD YR MM DD YR
successful completion of the examination 09/29/2016.
MM DD YR

*The official record of successful training completion is the New York State Department of
Health certificate of asbestos safety training completion (DPH 2832).*

Gail M. Conner
Training Director

Gail M. Conner

CERTIFICATE NO 375

G&C Environmental Services, Inc. (#294)
2 Street Road, Newtown Square, Pennsylvania 19073
Telephone: (610) 993-9202 Facsimile: (610) 993-9232
Email: Training@gcenviro.com
www.GCenviro.com

This document certifies that Shelton Williams has successfully completed this
State of New York Department of Health Approved AHERA BUILDING INSPECTOR

REFRESHER COURSE, completed as required for asbestos accreditation under the Toxic

Substances Control Act, Title II. This course was held from 09/29/2015 to 09/29/2015.
MM DD YR MM DD YR

The examination date was 09/29/2015. This certificate expires one year from the date of
MM DD YR MM DD YR
successful completion of the examination 09/29/2016.
MM DD YR

*The official record of successful training completion is the New York State Department of
Health certificate of asbestos safety training completion (DPH 2832).*

Gail M. Conner
Training Director

Gail M. Conner

Certificate of Completion

Paul M. Davis

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/12/15

Course Date

N/A

Exam Date

2/12/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-6-015

Certificate Number

Mark K. Schlüger
Training Director

Certificate of Training

CRITERION LABORATORIES, INC.

HEREBY CERTIFIES THAT

Paul M. Davis

HAS SUCCESSFULLY COMPLETED A 4 HOUR COURSE ENTITLED

Asbestos Building Inspector Refresher

INCLUDING CLASSROOM INSTRUCTION

on this 2nd day of February 2016

Exam passed on this 2nd day of February 2016 - Score - 92

Approved for AHERA Accreditation Under TSCA Title II

3370 Progress Drive, Suite J
Bensalem, PA 19020
(215) 244-1300 - Phone
(215) 244-4349 - Fax
www.criterionlabs.com

Course is conducted in English

DIRECTOR:



James A. Welch, CIH, President

Certificate of Completion

Bernard J. Bryson


for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/16/15	N/A	2/16/16
<i>Course Date</i>	<i>Exam Date</i>	<i>Expiration Date</i>
Not Provided	ACC-0125-6-031	
<i>Social Security Number</i>	<i>Certificate Number</i>	Mark K. Schlager <i>Training Director</i>

Certificate of Completion

Bernard J. Bryson

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/15/16

Course Date

N/A

Exam Date

2/15/17

Expiration Date

Not Provided

Social Security Number

ACC-0216-6-005

Certificate Number

Mark K. Schlager
Training Director

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:
Alexander Roman

SS#:XXX-XX-1743
Who has completed this 4-hour course and examination,
EPA Approved under TSCA Title II
AHERA / ASHARA Rule
40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.
Delaware Industrial Park • 6 Garfield Way
Newark, DE 19713-5817
(302) 737-3376 • Fax (302) 737-5764
Course Date: **September 18, 2015**
Date of Expiration: **September 18, 201**
Certification Number : **EHSBIR 150619-008**


Todd K. Zeisloff, Instructor


Neeraj K. Batta, President

Certificate of Completion

Norman Harrison

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by
ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08109
(856) 665-3449

9/2/15

Course Date

N/A

Exam Date

9/2/16

Expiration Date

Not Provided

Social Security Number

ACC-0915-6-011

Certificate Number

Mark K. Schlager
Mark K. Schlager
Training Director

EHS TRAINING INSTITUTE, INC.
A Division of BATTI, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:

Kelly Mayberry

SS#:XXX-XX-1551

Who has completed this 4-hour course and examination,

EPA Approved under TSCA Title II

AHERA / ASHARA Rule

40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.

A Division of BATTI, Inc.

Delaware Industrial Park • 6 Garfield Way

Newark, DE 19713-5817

(302) 737-3376 • Fax (302) 737-5764

Course Date: February 20, 2015

Date of Expiration: February 20, 2016

Certification Number : EHSBIR 150220-005


Todd K. Zeislott, Instructor


Neeraj K. Batta, President

EHS TRAINING INSTITUTE, INC.

A Division of BATA, Inc.

Certificate of Completion

AHERA Building Inspector

(Refresher)

Awarded To:

Kelly Mayberry

SS#:XXX-XX-1551

Who has completed this 4-hour course and examination,

EPA Approved under TSCA Title II

AHERA / ASHARA Rule

40 CFR Part 763.

EHS TRAINING INSTITUTE, INC.

A Division of BATA, Inc.

Delaware Industrial Park • 6 Garfield Way

Newark, DE 19713-5817

(302) 737-3376 • Fax (302) 737-5764

Course Date: February 18, 2016

Date of Expiration: February 18, 2017

Certification Number : EHSBIR 160218-006

Todd K. Zeisloff, Instructor

Neeraj K. Batta, President

AEROSOL MONITORING & ANALYSIS, INC.

This is to certify that
ANDREW HINE

has met the attendance requirements and successfully completed

the course entitled

3-DAY EPA AHERA INSPECTOR

For Accreditation Under TSCA Title II

05/04/2015 to 05/06/2015

Course Date

05/06/2015

Exam Date

5/6/2016

Expiration Date

STEVE SIERACKI

Principal Instructor

Steve Sieracki

A105042015-3

Certification No.

E. Rush Barnett

Course Director

E. Rush Barnett

1331 Ashton Road

P.O.Box 646

Hanover, MD 21076

P: 410-684-3327

F: 410-684-3724

www.amatraining.com

Certificate of Completion

Maryellen Leotta

for successfully completing the prescribed course of study in

Pennsylvania Asbestos Building Inspector Refresher Course

under TSCA Title II

presented by

ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, NJ 08110
(856) 665-3449

2/12/15

Course Date

N/A

Exam Date

2/12/16

Expiration Date

Not Provided

Social Security Number

ACC-0215-6-024

Certificate Number

Mark K. Schlager
Training Director

Section IV Cross Reference Table

Asbestos Hazard Emergency Response Act (AHERA) Environmental Compliance Audit Cross Reference Table

In response to the AHERA Environmental Compliance Audit a Cross Reference Table has been prepared for inclusion into the Environmental Management Plan. The purpose of this Cross Reference Table is to link the following documents to the AHERA Management Plan.

Cross Reference Table	
3 Year Reinspection Report follows this Cross Reference Table documentation.	
Subject Matter	Location of Required Documents
Designated Person	Pages 1 - 3
Annual Notification	Pages 4 - 5
6 Month Periodic Surveillance Outline of Events	Page 6
3 Year Re-inspections Outline of Events	Page 7
Asbestos Management Program (operations and maintenance)	Pages 8 - 19
Asbestos Investigation Report (AIR)	Attachment 1 Letter Dated August 4, 2006
Training (included in the Asbestos Management Program)	<p>The original records are centralized at the School District's Environmental Library. Copies are maintained on staff and are required to be maintained in the latest Reinspection Report.</p> <p>2 hour awareness training records for all Building Engineers, Custodian Assistants and maintenance personnel</p> <p>40 hour worker/supervisor training records for the OEMS A-Team and various AST tradesmen.</p>
Response Actions (monthly mailings if applicable)	The original documents are on file at the School District's Environmental Library.
	Copies of the original are mailed to the Schools Main Office for retention with the Management Plan documentation. These documents are typically kept separate from the management plan in an update binder due to the potential volume of response action reports.

SCHOOL DISTRICT OF PHILADELPHIA

ASBESTOS DESIGNATED PERSON

Gerald F Junod
Office of Capital Programs
Environmental Management & Services
440 N Broad Street, 3rd Floor
Philadelphia, PA 19130
Telephone: 215 400 6738
Fax: 215 400 4751

Drexel University- Asbestos Building Inspector Course	January 9-11, 1989 24 Hours
Drexel University- Asbestos Management Planner Course	January 12-13, 1989 16 Hours
Criterion Laboratories, Inc. - Asbestos Management Planner Course	October 11-12, 2012 16 Hours

<u>Annual Building Inspector Refreshers</u> 4 Hours Drexel University Criterion Laboratories, Inc Access Training Services, Inc.	1990 to Present
---	------------------------

<u>Annual Building Management Planner Refreshers</u> 4 Hours Drexel University Criterion Laboratories, Inc 4 Hours	1990 to 1994 2013 to Present
---	---

Environmental Manager, School District of Philadelphia

Manages the design and implementation of asbestos and lead projects for the Capital Improvement Program and other District Departments including Facilities & Operations and Information Technology. Ensures that asbestos abatement and lead remediation projects are expertly designed and executed in accordance with industry best management practice standards and regulations.

Manager, City of Philadelphia Asbestos Control Program

Served as the Asbestos Control Program Manager for the City of Philadelphia, Department of Public Health, Air Management Services, Asbestos Control Unit from August 1, 2003 through October 23, 2006.

Mid Atlantic Regional Environmental Consortium (MAREC)

Former member with attendance and participation commitments of all quarterly EPA Region III and yearly National Asbestos Regulatory Conferences sponsored by the EPA and the National Conference of State Legislators respectively as a representative for the City of Philadelphia Department of Public Health Air Management Services from 1994 through 2006.

Philadelphia Environmental Task Force

Former member of the Philadelphia Environmental Task force as a representative and point of contact for the City of Philadelphia Department of Public Health Air Management Services Asbestos Control Unit from 2002 through 2006.

Asbestos Instructor

Worked as the primary instructor for the initial and annual Asbestos Project Inspector training and licensing program as mandated by City of Philadelphia Department of Public Health Asbestos Control Regulations from August 1994 through October 2006.

Worked as a lead instructor with an Environmental Consulting Firm and approved by the US EPA for the initial and annual refresher training courses for various asbestos occupational disciplines such as the Building Inspector, Management Planner and Worker/Supervisor from 1991 through 1994.

I certify that the general, local agency responsibilities as stipulated in Section 763.84 will be met.



Gerald F. Junod

Asbestos Designated Person

Environmental Manager

Office of Environmental Management and Services

SCHOOL DISTRICT OF PHILADELPHIA

Accreditation Information Statement

All persons who inspect for Asbestos Containing Building Materials (ACBM) and who will design or carry out response actions with respect to assumed and confirmed ACBM, will be accredited by an EPA approved course and/or a State Contractors Accreditation Program under Sections 206 (c) and 206 (b) of Title II of the ACT.



**Gerald F. Junod
Asbestos Designated Person
Environmental Manager
Office of Environmental Management and Services**

SCHOOL DISTRICT OF PHILADELPHIA
OFFICE OF CAPITAL PROGRAMS
440 NORTH BROAD STREET, SUITE 373
PHILADELPHIA, PENNSYLVANIA 19130

OFFICE OF ENVIRONMENTAL MANAGEMENT AND SERVICES

PHONE (215)-400-4750

September 2015

TO: Principals
Building Administrators/Occupants
Parents/Guardians

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: Annual EPA Notification Letter


Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 C.F.R. 763.84 (c)(d) of public access to environmental records, this letter is to acknowledge the availability of your facility's Asbestos Hazard Emergency Response Act (AHERA) Management Plan.

Each member of the school staff, parents/guardians, temporary workers and/or contractors, are required to receive a copy of the Notification Letter. At the direction of the Principal, a copy is to be posted on the bulletin boards and an appropriate amount of copies are to be generated for distribution.


Note: The AHERA Three-Year Reinspection reports, in colored binders; White with Pink, Tan, Black, Red, Dark Blue, Green, Yellow and White, are Federal EPA mandated inspection documents. The School District of Philadelphia is subject to severe monetary penalties if the reports and associated paperwork are not available to the EPA and the public upon request.

It is incumbent on designated school personnel to gather and retain this data as it is delivered, in one location for future review. Acceptable locations include the Principal's Office or Main Office for the primary data. The Building Engineer should maintain any secondary or duplicate copies.

If you have any questions, please call 215-400-4750. Thank you for your cooperation.



Fran Burns
Chief Operating Officer



Francine Locke, M.S., Director
Office of Environmental Management
and Services

c: Danielle Floyd

AHERA-4
8/21/15



School District of Philadelphia
OFFICIAL NOTICE

PLEASE POST

September 2015

TO: Principals
Building Administrators
Building Engineers
Building Occupants
Parents/Guardians

FROM: Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management and Services

SUBJECT: Annual Notification Letter: Asbestos Hazard Emergency Response Act

The Federal Register published on October 30, 1987, Subpart E, in Schools: Final Rule and Notice, 763.84 (c)(d) states that each local education agency shall ensure that workers and building occupants or guardians are to be informed at least once each school year about inspections, response actions and post-response action activities including re-inspections and periodic surveillance activities. The School District as the Local Education Agency (LEA), retains such reports that are available for public inspection in the Office of the Principal or Building Administrator.

The Principal or Building Administrator is required to do the following with this notification:

- 1) Post in a Public Place or Main Office
- 2) Inform Building Occupants
- 3) Send a copy of this notification to Parents or Guardians
- 4) Insert a copy into the latest AHERA Three-Year Reinspection report (white/pink binder) in your office or facility.

Fran Burns
Chief Operating Officer

Francine Locke, M.S., Director
Office of Environmental Management
and Services

c: Danielle Floyd

AHERA-4a
8/21/15

SCHOOL DISTRICT OF PHILADELPHIA
Education Center
440 North Broad Street
Philadelphia, Pennsylvania 19130

Office of Environmental Management and Services

215-400-4750

AHERA
Six Month Surveillance
Outline of Events

- Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 CFR 763.92(b), the following procedure is to be implemented. At least once every six (6) months after a Management Plan is in effect, each Local Education Agency (LEA) shall conduct a periodic surveillance in each building that it owns or leases that contains Asbestos Containing Building Materials (ACBM) or is assumed to contain ACBM.
- The first Bi-Annual Inspection starts in the Spring (March, April, May) and again in the Fall (October, November, December) of each year. The Building Engineer/Assistant should assist the Building Inspector with appropriate access to all areas including (Crawlspace/Attics) and rooms in the facility. There is no action required of the Principal.
- The Building Inspector shall visually inspect all areas that are identified in the Management Plan as ACBM or assumed ACBM. The date of the surveillance is recorded, the inspectors name and any changes in the conditions of the materials.
- The Building Inspector shall make a copy of the inspection document and insert into the front of the latest Management Plan (AHERA Three Year Reinspection report). The original document is returned to the LEA's Environmental Library and filed.

SCHOOL DISTRICT OF PHILADELPHIA
Education Center
440 North Broad Street
Philadelphia, Pennsylvania 19130

Office of Environmental Management and Services

215-400-4750

AHERA
Three Year Reinspection
Outline of Events

- Pursuant to the Federal Environmental Protection Agency (EPA) mandate, as required by 40 CFR 763.85(b) the following procedure is to be implemented. At least once every three (3) years after a Management Plan is in effect, each Local Education Agency (LEA) shall conduct a reinspection of each building that it owns or leases that contains Asbestos Containing Building Material's (ACBM's) or is assumed to contain ACBM.
- Subsequent Three Year Re-inspections (2009, 2012, 2015, etc) shall start in the Fall (October, November, December, January). The Building Engineer/Assistant should assist the Building Inspector with appropriate access to all areas including (Crawlspaces/Attics) and rooms in the facility. There is no action required of the Principal.
- An accredited Building Inspector shall visually inspect and touch to determine friability, all areas that are identified in the Management Plan as ACBM or assumed ACBM. The date of the surveillance is recorded, the inspectors name and any changes in the conditions of the materials. The Building Inspectors state of accreditation and license number is required.
- After the inspection, the Building Inspector shall make a copy of the inspection documents and insert into the front of the latest Management Plan (AHERA Three Year Reinspection report). The original document is returned to the LEA's Environmental Library and filed.
- The Building Inspector shall return the reinspection data to the Management Planner to be assessed and determine appropriate response actions and a report issued (AHERA Three Year Reinspection report). One copy of the report is delivered to the schools Principal to be permanently retained with all previous environmental data. Another copy is retained in the LEA's Environmental Library.



School District of Philadelphia
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, PA 19130
(215) 400-4750

**School District of Philadelphia
Asbestos Management Program**

TABLE OF CONTENTS

Definitions.....	Page 9
1. Introduction.....	Page 10
2. Summary of Asbestos Management Plan	
3. Asbestos Management Plan Execution.....	Page 11
a. General Execution	
4. Summary of Program Execution	
a. Asbestos Management Plan Execution	
5. Responsibilities	
a. OEMS	
b. Asbestos Worker/Supervisor “A-TEAM”.....	Page 12
c. Asbestos Designated Person	
d. Supervisor or Project Manager (Capital, Maintenance & Facilities)	
e. Employee Capital.....	Page 13
f. Employee Maintenance	
g. Employee Facilities and Custodial	
6. Requirements.....	Page 14
a. Employee Exposure Monitoring	
b. Employee Notification	
c. Observation of Monitoring	
d. Training Program	
e. Access of Information	
f. Record Keeping	
7. AHERA O&M Plan.....	Page 15
a. Controls	
8. O&M Response Actions.....	Page 16
a. Facility Maintenance Isolation of Area	
b. Unlikely Contact with ACM/PACM	
c. Accidental Disturbance of ACM/PACM	
d. Planned Disturbance of ACM/PACM	
e. Miscellaneous ACM/PACM.....	Page 17
f. Vinyl Asbestos Floor Tile	
g. Mastic/Adhesives	
h. Woven Vibration Dampers	
i. Other Work Practices	
j. Fiber Release Episodes	
9. References and Resources.....	Page 18

DEFINITIONS / ACRONYMS

ACM/PACM:	Asbestos Containing Material/Potential Asbestos Containing Material
AHERA:	Asbestos Hazard Emergency Response Act
AIR FORM:	Asbestos Inspection Report Form
Amended Water:	Water to which a surfactant (soap) has been added
AMP:	Asbestos Management Program/Asbestos Management Plan
Asbestos Designate Person:	Individual assigned by the district to oversee asbestos related issues.
Asbestos Regulated Area:	Location that is posted as an asbestos work area in which only approved and accredited personnel are permitted to enter
AST:	Asbestos Support Team involving approved and accredited school district tradespersons personnel that are school district person
A-TEAM:	School District of Philadelphia asbestos workers
CIP:	Capital Improvement Program
Consultant:	Asbestos consulting firm hired by the District
Demolition Directive:	Memorandum – August 4, 2006 from Patrick Henwood
EPA:	Environmental Protection Agency
In House Personnel:	School District of Philadelphia asbestos workers
LEA:	Local Education Agency
O&M:	Operations and Maintenance
OEMS:	Office of Environmental Management and Services
OSHA:	Occupational Safety and Health Administration
PEL:	Permissible Exposure Limit
PSD or SDP:	Philadelphia School District/School District of Philadelphia
PSIT:	Philadelphia School Improvement Team
STEL:	Short Term Exposure Limit

1. Introduction

The School District of Philadelphia, Asbestos Policy Statement:

“The School District of Philadelphia is dedicated to providing a safe and healthful work environment for its employees, students, faculty, contractors and visitors. In recognition of the potential health problems associated with asbestos, the School District of Philadelphia is committed to a comprehensive asbestos control program. This program is implemented and maintained through the School District of Philadelphia's Office of Environmental Management and Services (OEMS).”

OEMS has the responsibility of establishing procedures for asbestos abatement, asbestos inspection, air monitoring, renovation and demolition activities within all School District of Philadelphia owned or leased facilities.

These procedures are developed to ensure that:

- (1) People are not exposed to significant levels of asbestos fibers
- (2) Asbestos waste is handled and disposed of properly
- (3) Members of the School District of Philadelphia community have access to the Office of Environmental Management and Services for information, assistance, guidance, and interpretation regarding asbestos related matters.
- (4) Members of the School District of Philadelphia community have access to the Asbestos Management Plans as required and outlined in the US EPA AHERA regulations including annual written notification to all parents.
- (5) Compliance with all applicable Federal, State and Local Asbestos Regulations

Requirements outlined in this manual are mandatory in nature where the word “SHALL” is used and are advisory in nature where the word “SHOULD” is used.

2. Summary of Asbestos Management Program

The School District of Philadelphia's Asbestos Management Program was established to meet the requirements of Federal, State, and Local Regulations.

These regulations include, but are not limited to:

- US Environmental Protection Agency Asbestos Hazard Emergency Response Act (US EPA AHERA) and National Emissions Standard for Hazardous Air Pollutants subpart M, Part 61 (NESHAP);
- US Department of Labor, Occupational Safety and Health Administration (OSHA) General Industry Standard (29 CFR 1910.1001) and the OSHA Asbestos Standard for the Construction Industry (29 CFR 1926.1101);
- The Commonwealth of Pennsylvania, Department of Labor and Industry, Asbestos Occupations, Accreditation and Certification Act;
- The City of Philadelphia, Department of Public Health, Asbestos Control Regulations.

3. Asbestos Management Program Execution

a) General Execution

The Office of Environmental Management and Services (OEMS) develops, implements and manages safety and health programs for the School District of Philadelphia faculty, staff and students and assists with ensuring that all contractors comply with Federal, State and Local Environmental Regulations. The OEMS provides the oversight of School District of Philadelphia employees (Asbestos A-Team), environmental consultants, and asbestos abatement contractors for all projects within the School District of Philadelphia concerning Asbestos Containing Materials.

The control of safety and health hazards at the School District of Philadelphia is primarily through the implementation of engineering, work practice and administrative controls. Personal Protective Equipment (PPE) is used to supplement these controls or whenever the controls are not feasible or are in the process of being implemented. PPE is also recommended whenever exposures to chemical, physical or biological agents can be prevented or reduced by its use.

This written program establishes the procedures necessary to:

- 1) meet established standards and federal regulations for occupational exposure to asbestos fibers;
- 2) meet the requirements of the City of Philadelphia Asbestos Control Regulations which encompasses the disturbance and/or abatement of asbestos containing building materials;
- 3) provide the necessary health and safety protection to the School District of Philadelphia staff, faculty, students, contractors and visitors.

This program is strengthened by input and cooperation with the Philadelphia Federation of Teachers (PFT), Health and Welfare Fund.

4. Summary of Program Execution

a) Asbestos Management Program Execution

The Asbestos Management Program is administered by the Office of Environmental Management and Services (OEMS). OEMS provides the following services primarily through professional consultants:

- (1) exposure monitoring services;
- (2) building inspection/surveys (bulk sampling) for the identification of asbestos containing materials;
- (3) asbestos project design services;
- (4) asbestos abatement project and air monitoring services;
- (5) emergency response to fiber release episodes;
- (6) education/information;
- (7) medical monitoring;
- (8) training for School District of Philadelphia personnel

5. Responsibilities

a) Office of Environmental Management and Services

OEMS is responsible for performing the following functions:

- (1) Developing and administering of the Asbestos Management Program.
- (2) Providing asbestos-related services to all School District of Philadelphia departments.
- (3) Conducting required training of the Asbestos Management Program and working jointly with departments to schedule training.
- (4) Identifying and posting areas where labeling/signage are required.
- (5) Medical Monitoring of OEMS "A-TEAM" and other departments "AST" Asbestos Program staff.

- (6) Certification and training as required for OEMS "A-TEAM" and other departments "AST" Asbestos program staff.
- (7) Record keeping as outlined in Section 3.5 and all records as by required by US EPA AHERA regulations.

b) Asbestos Worker/Supervisor - "A-TEAM"

- (1) OEMS shall ensure that all "A-TEAM" workers/supervisors adhere to the following requirements:
 - a) Attend an initial Worker/Supervisor Asbestos Course;
 - b) Maintain the annual re-certification per EPA AHERA requirements and Commonwealth of Pennsylvania Asbestos Occupations, Accreditation and Certifications Act;
 - c) Undergo an annual Asbestos Medical Evaluation;
 - d) Undergo an annual Respirator Medical Clearance;
 - e) Undergo an annual Respirator Fit Testing.

c) Asbestos Designated Person

The Asbestos Designated Person is responsible for:

- (1) Assuring the health and safety of employees, students and visitors in the School District of Philadelphia facilities under his/her control.
- (2) Being kept informed of all areas under his or her jurisdiction where potential asbestos exposures exist and initiating protection programs that adhere to the Asbestos Management Program requirements of this manual.
- (3) Assuring that Asbestos Management Program requirements are adhered to by principal investigators, project managers, supervisors, or division heads, and School District of Philadelphia personnel under their supervision.
- (4) Ensuring that all employees within the Asbestos Management Program comply with (OSHA 1910.1001 (j) (7) (iv)) and the US EPA AHERA regulations by attending the required training.
- (5) Ensure the posting of:
 - a) Warning labels/signage
 - b) Commonwealth of Pennsylvania Asbestos Abatement and Demolition/Renovation Notification form
 - c) Asbestos Inspection Reports (AIR) form (where required)
 - d) Ensuring that Construction Projects follow the Demolition Directive procedures as outlined in the August 4, 2006 letter.

d) Supervisor or Project Manager (Capital, Maintenance and Facilities)

Each person in charge of a project, maintenance/repair, renovation/demolition, or other activity from the Departments of Capital, Maintenance, and/or Facilities, where asbestos containing material may be present is responsible for:

Identifying, with the assistance of OEMS, asbestos containing building materials prior to any disturbance of these materials. Various Federal (EPA and OSHA) and Local (City of Philadelphia Asbestos Control Regulations) require Asbestos Inspections prior to renovation/demolition activities. This shall be accomplished by always following the Asbestos Management Program Procedures as follows:

- (1) Ensure that the requirements of the Asbestos Management Program Procedures are followed by all personnel, trades, and contractors who are involved with the project;

- (2) Review of the required Asbestos Inspection Report (AIR) form (Attachment 1) and AHERA Management Plan documents prior to activities that may disturb any Asbestos Containing Materials;
- (3) Perform all project related duties as outlined in the Project Management Responsibilities;
- (4) Keep the department chairperson or director informed on any actions proposed or taken regarding the Asbestos Management Plan;
- (5) Ensuring that Construction Projects follow the Demolition Directive procedure outlined in the August 4, 2006 letter.

e) Employee – Capital

School District of Philadelphia Capital employees and/or consultants shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of the projects they are performing or managing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work order permit (a.k.a PSIT Service Request Form) and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed.
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode upon discovery of visible damage to asbestos containing materials.
- (3) Ensuring that Construction Projects follow the Demolition Directive procedures as outlined in the August 4, 2006 letter.

The types of projects represented as part of the Capital Improvement Program are as follows:

- (1) Complete Renovation of an existing building that addresses all facility component concerns and educational program needs;
- (2) Major Renovation of an existing building addressing significant facility component and educational improvements;
- (3) Addition to an existing building (either as an attachment or stand-alone structure) to accommodate needed program space;
- (4) Conversion of an existing facility to accommodate a change in educational program;
- (5) Facility Component Improvement of specific facility needs (i.e. electrical or HVAC system upgrades, ADA improvements, life safety improvements, exterior renovations, etc.)

f) Employee – Maintenance

School District of Philadelphia Maintenance employees shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of their duties or work they are performing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work order permit and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed.
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode or upon discovery of visible damage to asbestos containing materials.
- (3) All employees involved in maintenance activities shall attend required Asbestos Awareness training program within 60 days of employment.

g) Employee – Facilities & Custodial

School District of Philadelphia Facilities and Custodial employees shall:

- (1) Ensure that no suspect or asbestos containing building materials are disturbed in the course of their duties or work they are performing. This shall be accomplished by notifying their supervisor and OEMS by issuance of a work permit and verifying that the materials which may be disturbed are non-asbestos containing. If this information is not available or verification has not been made, these materials should not be disturbed;
- (2) Immediately notify OEMS and their supervisor in the event of a potential fiber release episode or upon discovery of visible damage to asbestos containing materials.
- (3) All employees involved in Facilities and Custodial activities shall attend required Asbestos Awareness training program within 60 days of employment.

6. Requirements

a) Employee Exposure Monitoring

When information indicates that an employee's exposure to asbestos fibers may equal or exceed an 8-hour time-weighted average of 0.1 f/cc * (per OSHA 1910.1001 & 1926.1101), OEMS shall develop and implement an asbestos exposure monitoring program. The sampling strategy shall be designed to identify employees by work task (job classification) that is exposed to asbestos fibers that exceed an 8-hour time-weighted average of 0.1 f/cc.

b) Employee Notification

OEMS shall notify in writing, each employee exposed to asbestos fibers at or above an 8-hour time weighted average of 0.1 f/cc.

c) Observation and Monitoring

OEMS shall provide employees or their representatives with an opportunity to observe any exposure measurements conducted.

d) Training Program

OEMS shall institute a training program which meets the requirements of AHERA for all employees who perform maintenance operations in a facility/school which contains asbestos containing materials or presumed asbestos containing materials and 1910.1001 (j), and the Commonwealth of Pennsylvania Department of Labor and Industry and the City of Philadelphia Asbestos Control Regulations. The affected departments shall ensure employee participation in this program. The OEMS "A-TEAM" and other departments "AST" Asbestos Program staff training shall be conducted annually for each employee as required by all Federal, State and Local for each asbestos discipline.

All Asbestos Awareness training as required by AHERA shall be performed within 60 days of employment and shall include:

- Health effects of asbestos
- Locations of ACM and PACM in the building/facility
- Recognition of CM and PACM damage and deterioration
- Requirements of the OSHA 1910.1001 standard relating to maintenance
- Proper response to fiber release episodes
- Procedure to be followed to isolate areas affected by fiber release

e) Access to Information

OEMS shall make available to affected employees or their representative's copies of the Occupational Safety and Health Administration (OSHA) General Industry Standard Part 1910.1001 and the department shall post a copy in the workplace.

f) Record Keeping

OEMS shall maintain an accurate record of all employee exposure measurements. OEMS and/or the School District of Philadelphia Human Resources Department shall maintain records of employee medical monitoring program. OEMS shall maintain all employee training records. All records shall be provided upon request to employees, former employees, representatives designated by the individual employee.

7. AHERA OPERATIONS AND MAINTENANCE PLAN

a) CONTROLS

i. Work Order System

Minimizing disruption of ACM/PACM during maintenance and renovation activities is the primary goal and task encountered by OEMS. Operations and maintenance employees and contractors should be warned to avoid conducting any maintenance work which may disturb ACM/PACM. Initiating a work order system, where all work orders or requests are channeled through the Office of Environmental Management and Services (OEMS), will be the method used to control and minimize disruption of ACM/PACM.

Any work performed by in-house personnel or contractors that could or will impact ACM/PACM shall be coordinated by OEMS. A completed Asbestos Inspection Report Form (Attachment 1) shall be issued to in-house personnel and/or all contractors whose work could impact ACM/PACM. This form should accompany each contract issued to an outside contractor and posted on the jobsite.

All work order requests for maintenance and renovation activities in areas where ACM/PACM is suspected or known to be present are to be submitted to OEMS prior to proceeding with work. OEMS is responsible for reviewing asbestos survey records for information about the presence of ACM/PACM in the area where the work is to be performed. OEMS should physically inspect the area to ensure existing records reflect actual conditions. If no asbestos is present, a work order is not necessary and the planned actions can proceed. If ACM/PACM is found to be present in the area, OEMS will sign the work order application and obtain an approved and accredited asbestos contractor or assign OEMS "A-TEAM" to abate the ACM/PACM.

ii. Regulated Areas

The owner will identify and regulate all areas where airborne concentrations of ACM/PACM exceed the Permissible Exposure Limit (PEL)* (Per OSHA determined to be 0.1 f/cc) and/or short term exposure limit (STEL) (Per OSHA determined to be 0.1 f/cc), or there is reasonable possibility that the (PEL) and/or (STEL) may be exceeded. All ACM/PACM removal activities involving thermal system insulation ACM/PACM (Class I), surfacing ACM/PACM (Class I), and miscellaneous ACM/PACM such as floor tile, roofing, and siding mastic, etc. (Class II), and repair and maintenance operations where thermal system insulation and surfacing ACM/PACM is likely to be disturbed (Class III) will be performed in accordance with federal, state, and local regulations. All asbestos abatement work and activities will be designed and managed as asbestos regulated areas. These areas will be demarcated and labeled.

iii. Warning Signs

Warning signs shall be displayed at all approaches to each asbestos regulated area. The asbestos abatement contractor will provide OSHA warning signs in all regulated areas during removal, repair, and other maintenance activities. OEMS will provide AIRs to all contractors who must inform all employees and supervisors working in locations contiguous to asbestos regulated areas of the potential hazards and work practices required.

iv. Warning Labels

Warning labels and/or signage shall be affixed to all raw materials, mixtures, scrap, waste, debris, and other products containing asbestos fibers, or to their containers. Generally, the asbestos abatement contractor or OEMS A-Team personnel will provide all warning labels for ACM/PACM containment.

8. O & M RESPONSE ACTIONS

The Asbestos Management Program general O&M procedures are outlined in this section. Additional requirements specific to asbestos abatement activities are included in the Project Design documents for all Asbestos Abatement Work. Regular cleaning, inspection, and reporting of ACM/PACM deterioration or other problems must be diligently practiced by all employees including custodial and maintenance personnel.

a) Facility Maintenance Isolation of Area Responsibilities

Maintenance personnel are often required to work in areas where ACM/PACM may potentially be disturbed. Most maintenance activities are conducted by in-house staff, outside contractors, or a combination.

Emergency fiber release episodes, such as pipe fitting or valve breaks, emergency boiler work, or mechanical equipment repair will be responded to by OEMS A-Team personnel or asbestos abatement contractor personnel. The owner's maintenance staff will: (1) isolate the emergency fiber release area; (2) post warning signs to prevent unauthorized access, and (3) notify their supervisor and OEMS. OEMS will ensure that the fiber release area remains isolated and is properly cleaned by and approved and accredited abatement contractor or by OEMS A-TEAM personnel.

b) Unlikely Contact with ACM/PACM

Maintenance activities or repairs which can be performed without contacting or disturbing the ACM/PACM require little more than normal care and good workmanship. For example, valves which are either uncovered or covered with non-asbestos insulation can be packed or repaired without disturbing asbestos insulation on nearby pipes. The major precaution is to ensure that maintenance and custodial personnel are familiar with procedures such as isolating the area, posting warning signs, and notifying OEMS in the event of any accidental ACM/PACM disturbance.

c) Accidental Disturbance of ACM/PACM

Maintenance and facilities personnel shall notify OEMS any time a fiber release is suspected. If friable ACM/PACM becomes airborne in the building,

d) Planned Disturbance of ACM/PACM

Maintenance activities that may impact ACM/PACM include access to a valve, flange, duct, or related system component.

Where asbestos-containing insulation must be removed to maintain or repair the thermal system, the ACM/PACM will imminently be disturbed. ACM/PACM removal work shall be conducted by OEMS A-Team personnel or an approved and accredited asbestos abatement contractor.

If friable ACM/PACM becomes airborne in the building, maintenance and facilities personnel shall secure the area and contact OEMS. OEMS shall respond accordingly.

e) Miscellaneous ACM/PACM

Miscellaneous types of ACM/PACM may include vinyl asbestos floor tiles, mastics/adhesives and woven vibration dampers. Disturbance of these materials should be avoided. Routine maintenance activities involving these materials should not pose a problem if handled properly. Questions on the proper removal and disposal of miscellaneous ACM/PACM should be directed to OEMS. OEMS will contact an approved and accredited asbestos abatement contractor or utilize OEMS A-TEAM personnel to assist with miscellaneous ACM/PACM clean-up activities.

f) Vinyl Asbestos Floor Tile

Asbestos-containing floor tiles in good condition are considered non-friable unless they are crushed, drilled, sawed, sanded or disturbed by any activity that breaks up the material. Routine maintenance of these materials should employ the use of non-abrasive buffers and wet cleaning technique. Broken or loose floor tiles should be removed and disposed of as asbestos waste by OEMS. Remaining debris should be vacuumed with a HEPA vacuum and the area wet mopped using amended water.

g) Mastics/Adhesives

Mastics and adhesives containing asbestos in good condition are considered non-friable and do not pose a potential health concern unless crushed, drilled, sawed, sanded, or otherwise abraded. Questions on the proper removal should be directed to OEMS.

h) Woven Vibration Dampers

Woven vibration dampers in good condition are considered non-friable and do not pose a potential health concern unless cut, crushed, drilled, sawed, sanded, or otherwise abraded. Questions on the proper removal should be directed to OEMS.

i) Other Work Practices

Any special work not included in this section should be addressed to OEMS for review prior to the initiation of work that may involve the disturbance of ACM/PACM.

j) Fiber Release Episodes

Facilities and maintenance staff should report to OEMS the presence of asbestos debris, water or physical damage to ACM/PACM, or any other evidence of possible fiber release. OEMS should have the OEMS A-Team personnel or an approved and accredited abatement contractor respond to the site to clean up debris and make repairs as soon as possible. OEMS will also contact a consultant to conduct air monitoring and prepare a report and submit at project completion to OEMS for each episode. OEMS will forward the reports for each site location AHERA Management Plan accordingly.

9. REFERENCES and RESOURCES

Applicable regulations for asbestos projects impacted by renovation, demolition, and maintenance activities.

- **Philadelphia Air Management Services – Asbestos Control Unit**
<http://www.phila.gov/health/units/ams/Asbestos/asbestos.html>
- **Pennsylvania Asbestos Occupations, Accreditation and Certification Act**
<http://www.dli.state.pa.us/landi/cwp/view.asp?a=185&q=56262&landiNav=>
- **United States Environmental Protection Agency Asbestos Home Page**
<http://www.epa.gov/asbestos/>
- **Occupational Safety and Health Administration (OSHA) Asbestos Home**
<http://www.osha.gov/SLTC/asbestos>