



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

May 26, 2017

Dear Sayre High School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 18 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Six water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Sayre High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1100-01-DW-031	Cafeteria - Walnut St. Side	5/17/2017	4.8	BA
1100-01-DW-033	Cafeteria - Middle of Cafeteria	5/17/2017	9.4	BA
1100-01-KC-041	Kitchen Island - Walnut St. Side	5/17/2017	1.0	BA
1100-01-KC-043	Kitchen Island - Stove Side	5/17/2017	0.88	BA
1100-01-DW-060	Outside Girls' Gym - Left	5/17/2017	0.51	BA
1100-01-DW-061	Outside Girls' Gym - Right	12/29/2016	1.4	BA
1100-01-DW-070	Outside Boys' Bathroom & Boys' Gym	5/17/2017	3.8	BA
1100-01-CF-073	Nurse's Office - Main	5/17/2017	2.6	BA
1100-01-KC-092	Room 115 - Special Needs	5/17/2017	1.8	BA
1100-02-DW-124	Outside Room 231 - Right	12/29/2016	40.5	AA
1100-01-IM-143	Kitchen	5/17/2017	0.41	BA
1100-02-DW-147	Across From Room 203 - Right	5/17/2017	0.60	BA
1100-01-DW-155	Girls' Gym	5/17/2017	32.1	AA
1100-00-DW-159	Girls' Locker Room	12/29/2016	51.0	AA
1100-01-HS-203	Across From Room 103	5/17/2017	0.054	BA
1100-01-KC-220	Room 109 - Special Needs	5/17/2017	3.5	BA
1100-01-KC-222	Room 125 - Left	5/17/2017	0.41	BA
1100-02-CF-223N	Room 227 - Health Suite - Left	5/17/2017	108	AA
1100-02-CF-224N	Room 227 - Health Suite - Center	5/17/2017	31.5	AA
1100-02-CF-225N	Room 227 - Health Suite - Right	5/17/2017	17.2	AA
1100-02-CF-226N	Room 227 - Health Suite - Back Wall Sink	5/17/2017	9.8	BA
1100-02-HS-227	Next to Room 204	5/17/2017	0.074	BA
1100-01-HS-228	Outside Room 102 - Left	5/17/2017	0.074	BA
1100-01-CF-251N	Room 125 - Right	5/17/2017	1.0	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

May 26, 2017

Dear Sayre High School Pool Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your location, 6 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Two water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Sayre High School Pool

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1510-01-WC-001	Girls' Locker Room	5/17/2017	1.5	BA
1510-01-WC-002	Boys' Locker Room	5/17/2017	0.91	BA
1510-01-WC-003	Pool Area - North Side	5/17/2017	64.0	AA
1510-01-WC-004	Pool Area - South Side	5/17/2017	5,180	AA
1510-02-WC-005	Outside Girls' Bathroom	5/17/2017	2.3	BA
1510-02-WC-006	Outside Boys' Bathroom	5/17/2017	0.74	BA
1510-02-KC-019	Kitchen	5/17/2017	1.8	BA
1510-02-HS-020N	Near Top of Stairs	5/17/2017	0.11	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb