



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division  
Office of Environmental Management & Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

April 3, 2017

Dear Martha Washington Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 29 of the water outlets passed this stronger water safety threshold and the water is safe to drink. One water outlet was found to have results above our stronger water safety threshold and was immediately shut off. We are currently developing an action plan to repair or permanently remove it. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

If you wish to view the detailed results from your school you may visit the District's website at [www.philasd.org/waterresults](http://www.philasd.org/waterresults) to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS  
Environmental Director

School Name: **Martha Washington Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1420-03-DW-002	Across from Room 313 - right (adjacent to DW-101)	3/22/2017	1.1	BA
1420-03-HS-008	Outside Room 308	3/22/2017	0.054	BA
1420-03-DW-014	Outside Room 302	3/22/2017	1.5	BA
1420-02-DW-018	Outside Room 202	3/22/2017	1.4	BA
1420-02-HS-022	Outside Room 207 - left	3/22/2017	0.054	BA
1420-02-DW-024	Outside Room 211	3/22/2017	3.7	BA
1420-01-DW-033	Outside Room 111 - right	3/22/2017	3.1	BA
1420-01-HS-042	Outside Room 107 - Day Care Area	3/22/2017	0.054	BA
1420-01-CF-045	Nurse's Office	3/22/2017	3.7	BA
1420-01-DW-047	Room 103 - After School Room	3/22/2017	44.7	AA
1420-01-DW-050	Outside Room 102 - right	3/22/2017	1.7	BA
1420-01-DW-051	Room 102 - Kindergarten	3/22/2017	2.5	BA
1420-01-DW-053	Room 101 - Kindergarten	3/22/2017	0.39	BA
1420-00-DW-060	Outside Girl's Room - left	3/22/2017	1.5	BA
1420-00-DW-062	Outside Girl's Room	3/22/2017	2.9	BA
1420-00-DW-064	Outside Girl's Room	3/22/2017	2.0	BA
1420-00-DW-065	Outside Girl's Room - right	3/22/2017	1.8	BA
1420-00-DW-073	Outside Boy's Room - left trough - left	3/22/2017	3.6	BA
1420-00-DW-075	Outside Boy's Room - left trough - right	3/22/2017	2.9	BA
1420-00-DW-076	Outside Boy's Room - right trough - left	3/22/2017	3.3	BA
1420-00-DW-078	Outside Boy's Room - right trough - right	3/22/2017	2.1	BA
1420-00-KC-079	Small Café - left	3/22/2017	1.5	BA
1420-00-KC-080	Small Café - middle	3/22/2017	0.92	BA
1420-00-KC-081	Small Café - right	3/22/2017	0.77	BA
1420-00-DW-088	Outside Room G-2 - Left	3/22/2017	4.4	BA
1420-00-DW-089	Outside Room G-2 - Right	3/22/2017	2.6	BA
1420-00-WC-096	Library in Element 2 - Left (companion to 107N)	3/22/2017	0.054	BA
1420-01-DW-097	Room 108 - Daycare	3/22/2017	6.1	BA
1420-03-DW-101	Across from Room 313 - Left (adjacent to DW-002)	3/22/2017	8.0	BA
1420-00-WC-107N	Library in Element 2 - Right (companion to 096)	3/22/2017	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb