



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

April 6, 2017

Dear Taggart Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, all of the water outlets passed this stronger water safety threshold and the water is safe to drink. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Taggart Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2690-00-DW-003	Room 107 - kindergarten	3/17/2017	1.1	BA
2690-00-CF-005	Nurses Office - Room 108	3/17/2017	4.8	BA
2690-00-DW-008	Hall outside of Room 108 - right	1/4/2017	7.0	BA
2690-00-DW-021	Multi-purpse room - right side	3/17/2017	1.0	BA
2690-00-KC-026	Kitchen - room 101	3/17/2017	1.9	BA
2690-01-DW-033	Steps near office	3/17/2017	1.3	BA
2690-02-HS-035	Outside of Room 307	3/17/2017	0.074	BA
2690-03-HS-040	Outside of Room 407	3/17/2017	0.074	BA
2690-01-WC-041	Room 200	3/17/2017	8.2	BA
2690-00-DW-043	Element 2 - Multi-purpose room	3/17/2017	0.25	BA
2690-00-KC-045	Kitchen off Multi-purpose room - by entrance	3/17/2017	3.6	BA
2690-00-KC-046	Kitchen off Multi-purpose room - large sink	3/17/2017	8.2	BA
2690-01-WC-051	Room 208 - pre-Kindergarten	3/17/2017	2.8	BA
2690-02-KC-054	Dining Room across from 308	3/17/2017	2.8	BA
2690-01-HS-055	Outside Room 203	3/17/2017	0.074	BA
2690-02-WC-056	Outside Room 303	1/4/2017	1.7	BA
2690-03-DW-057	Outside Room 403	1/4/2017	2.2	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb