



THE SCHOOL DISTRICT OF PHILADELPHIA  
Operations Division  
Office of Environmental Management & Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

January 19, 2017

Dear Gideon Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 9 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Two water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, we have begun installing hydration stations in schools across the District, and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

If you wish to view the detailed results from your school you may visit the District's website at [www.philasd.org/waterresults](http://www.philasd.org/waterresults) to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS  
Environmental Director

School Name: Gideon Elementary School

| Outlet ID #     | Outlet Location  | Sample Collection Date | Test Result (ppb) | Test Results |
|-----------------|--|------------------------|-------------------|--------------|
| 4530-01-DW-009  | Outside Bathroom - Left                                    | 1/12/2017              | 5.9               | BA           |
| 4530-01-DW-010  | Outside Bathroom - Right                                   | 1/12/2017              | 5.4               | BA           |
| 4530-01-DW-017  | Inside Room 103, Head-Start Room (room not currently used) | 1/12/2017              | 58.9              | AA           |
| 4530-01-KC-022  | Teacher's Dining Room - single lever faucet                | 1/12/2017              | 3.6               | BA           |
| 4530-01-CF-029  | Front Room of Nurse's Office                               | 1/12/2017              | 2.1               | BA           |
| 4530-01-HS-039  | In hallway, outside Girl's Bathroom                        | 1/12/2017              | 0.054             | BA           |
| 4530-02-HS-048  | In hallway, across from Room 207                           | 1/12/2017              | 0.054             | BA           |
| 4530-03-WC-065  | Outside Room 308   | 1/12/2017              | 3.3               | BA           |
| 4530-03-HS-074  | In hallway, outside Men's and Women's bathroom             | 1/12/2017              | 0.054             | BA           |
| 4530-03-KC-079  | Room 316 A, Kitchen  | 1/12/2017              | 2.2               | BA           |
| 4530-01-DW-086N | Room 104, kindergarten                                     | 1/12/2017              | 12.8              | AA           |

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb