



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

May 4, 2017

Dear Penn Treaty School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 17 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Four water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Penn Treaty High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5110-00-DW-001	Outside Room 004	4/19/2017	0.074	BA
5110-01-DW-002	Outside Rooms 104 & 105 - Left	4/18/2017	1.0	BA
5110-01-HS-004	Outside Room 107	4/18/2017	0.054	BA
5110-01-KC-005	Room 108 - Kitchenette	4/19/2017	0.63	BA
5110-02-HS-010	Outside Room 207 - Left	4/18/2017	0.054	BA
5110-02-DW-013	Outside Room 209	4/18/2017	37.1	AA
5110-02-DW-015	Across from Room 214	4/18/2017	0.90	BA
5110-03-DW-019	Outside Room 314	4/18/2017	2.3	BA
5110-03-DW-021	Across from Room 319	12/30/2016	19.5	AA
5110-03-DW-022	Across from Room 301	4/18/2017	7.3	BA
5110-04-DW-023	Outside Room 405	4/18/2017	0.68	BA
5110-04-HS-024	Outside Room 409 - Left	4/18/2017	0.088	BA
5110-04-KC-029	Kitchen - Back Wall - Left	4/18/2017	0.78	BA
5110-04-KC-031	Kitchen - Back Wall	4/18/2017	0.078	BA
5110-04-KC-033	Kitchen - Back Wall	4/18/2017	0.83	BA
5110-04-KC-035	Kitchen - Back Wall - Right	4/18/2017	0.53	BA
5110-01-CF-066	Room 107 - Special Education	4/18/2017	3.4	BA
5110-02-CF-100	Room 205 - Nurse's Office	4/18/2017	1.3	BA
5110-04-CF-117	Dietician's Office in Kitchen	4/18/2017	14.9	AA
5110-04-IM-141	Kitchen	4/18/2017	0.19	BA
5110-04-DW-142N	Hallway between Cafeteria & Room 414	12/30/2016	13.3	AA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb