



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

November 11, 2016

Dear Dunbar School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 15 ppb, which is below the national EPA measurement of 20 ppb.

At your school, all of the water outlets passed this stronger water safety threshold and the water is safe to drink. In addition, we have begun installing hydration stations in schools across the District. So far we have installed these stations in over 90 schools and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Dunbar Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5250-00-DW-005	Outside physical education office	10/21/2016	1.2	BA
5250-00-DW-013	Outside boys room - left	10/21/2016	0.93	BA
5250-00-DW-015	Outside boys room - middle	10/21/2016	1.7	BA
5250-00-DW-016	Outside boys room - right	10/21/2016	0.49	BA
5250-01-DW-021	Across from Room 108	10/21/2016	7.3	BA
5250-01-DW-023	Room 107	10/21/2016	7.5	BA
5250-01-HS-026	Outside Room 103	10/21/2016	<0.054	BA
5250-02-WC-036	Across from Room 208	10/21/2016	0.30	BA
5250-02-DW-040	Room 207	10/21/2016	7.2	BA
5250-03-WC-042	Across from Room 308	10/21/2016	0.40	BA
5250-03-DW-049	Across from IMC - remaining outlet on the right	10/21/2016	10	BA
5250-03-HS-050	Across from IMC - right of DW-049	10/21/2016	<0.054	BA
5250-04-DW-068	Room 401 - girls side roof top horiculture	10/21/2016	1.1	BA
5250-02-HS-069N	Outside Room 203	10/21/2016	<0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb