



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

January 3, 2017

Dear Emlen School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, all of the water outlets passed this stronger water safety threshold and the water is safe to drink. In addition, we have begun installing hydration stations in schools across the District. So far we have installed these stations in over 90 schools and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Emlen Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6220-00-DW-007	Outside Boy's Room - center	12/20/2016	2.6	BA
6220-00-DW-008	Outside Boy's Room - right	12/20/2016	2.2	BA
6220-01-HS-014	Outside Food Services (Portable)	12/20/2016	0.074	BA
6220-00-DW-026	Outside Girl's Room - immediately left of 027	12/20/2016	5.2	BA
6220-00-DW-027	Outside Girl's Room - immediately left of 028	12/20/2016	2.0	BA
6220-00-DW-028	Outside Girl's Room - furthest right	12/20/2016	2.4	BA
6220-01-WC-032	Room 107 - classroom	12/20/2016	1.9	BA
6220-01-HS-034	Outside Room 105 - daycare room	12/20/2016	0.074	BA
6220-01-KC-035	Room 106	12/20/2016	1.2	BA
6220-01-WC-039	Inside of Main Office	12/20/2016	1.3	BA
6220-01-WC-041	Room 109 - Kindergarten	12/20/2016	1.2	BA
6220-01-CF-043	Nurse's Office	12/20/2016	6.6	BA
6220-01-CF-044	Nurse's Exam Room	12/20/2016	3.1	BA
6220-01-WC-045	Outside Nurse's Office; near daycare room	12/20/2016	0.43	BA
6220-01-CF-049	Room 101 - Head Start	12/20/2016	5.8	BA
6220-02-WC-057	Outside Room 204	12/20/2016	0.40	BA
6220-02-CF-059	Teacher's Lounge - between Rooms 204 & 205	12/20/2016	3.6	BA
6220-02-HS-060	Outside Room 206	12/20/2016	0.054	BA
6220-03-HS-065	Outside Room 306	12/20/2016	0.054	BA
6220-03-WC-068	Outside Room 304	12/20/2016	0.60	BA
6220-01-CF-076N	Room 103 - Head Start	12/20/2016	0.57	BA
6220-01-KC-077N	Room 102	12/20/2016	1.2	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb