



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

March 13, 2017

Dear Pennell Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 18 of the water outlets passed this stronger water safety threshold and the water is safe to drink. One water outlet was found to have results above our stronger water safety threshold and was immediately shut off. We are currently developing an action plan to repair or permanently remove it. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Pennell Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6340-00-KC-001	Kitchen - Satellite	3/1/2017	2.1	BA
6340-00-DW-002	Outside Girl's Room - Left	3/1/2017	0.082	BA
6340-00-DW-003	Outside Girl's Room	3/1/2017	0.52	BA
6340-00-DW-004	Outside Girl's Room	3/1/2017	0.34	BA
6340-00-DW-005	Outside Girl's Room	3/1/2017	0.33	BA
6340-00-DW-006	Outside Girl's Room - Right	3/1/2017	0.61	BA
6340-00-DW-007	Outside Boy's Room - Left	3/1/2017	0.94	BA
6340-00-DW-008	Outside Boy's Room	3/1/2017	0.74	BA
6340-00-DW-009	Outside Boy's Room	3/1/2017	0.61	BA
6340-00-DW-010	Outside Boy's Room	3/1/2017	0.77	BA
6340-00-DW-011	Outside Boy's Room - Right	3/1/2017	0.70	BA
6340-01-HS-012	Outside Room 105	3/1/2017	0.054	BA
6340-01-WC-013	Outside Room 103	3/1/2017	0.27	BA
6340-02-HS-014	Outside Room 203	3/1/2017	0.054	BA
6340-02-WC-015	Outside Room 206	3/1/2017	0.21	BA
6340-03-HS-016	Outside Room 306	3/1/2017	0.054	BA
6340-03-WC-017	Outside Room 303	3/1/2017	1.2	BA
6340-01-WC-019	Portable - Room 1 - Head Start - Right Classroom	3/1/2017	0.50	BA
6340-01-CF-062	Room 107 - Kindergarten	3/1/2017	23.2	AA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb