



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

February 17, 2017

Dear Lawton Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 30 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Two water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Lawton Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7330-011-KC-007	Kitchen - large basin	2/3/2017	6.8	BA
7330-01-DW-008	Gymnasium	2/3/2017	9.8	BA
7330-01-HS-024	Outside Bathrooms	2/3/2017	0.074	BA
7330-01-WC-033	Outside Main Office	2/3/2017	1.1	BA
7330-01-WC-038	Room 104	2/3/2017	0.91	BA
7330-01-CF-039	Nurse's office - front room	2/3/2017	4.9	BA
7330-01-CF-040	Nurse's office - back room	2/3/2017	6.0	BA
7330-01-WC-044	Room 101	2/3/2017	1.5	BA
7330-01-WC-047	Room 102	2/3/2017	11.3	AA
7330-02-DW-049	Room 201	2/3/2017	55.0	AA
7330-02-DW-057	Room 205	2/3/2017	8.7	BA
7330-02-DW-059	Room 206	2/3/2017	4.4	BA
7330-02-HS-071	Outside IMC	2/3/2017	0.12	BA
7330-01-KC-091N	Kitchen - left	2/3/2017	1.2	BA
7330-01-KC-092N	Kitchen - middle	2/3/2017	0.63	BA
7330-01-KC-093N	Kitchen - right	2/3/2017	1.4	BA
7330-01-KC-094N	Teacher's lounge	2/3/2017	7.0	BA
	<u>portable building</u>			
7330-01-DW-095N	Classroom 108	2/3/2017	0.054	BA
7330-01-DW-097N	Classroom 111	2/3/2017	0.12	BA
7330-01-DW-098N	Classroom 112	2/3/2017	0.75	BA
7330-01-DW-099N	Classroom 113	2/3/2017	0.11	BA
7330-01-DW-100N	Classroom 114	2/3/2017	0.38	BA
7330-01-DW-102N	Classroom 117	2/3/2017	0.1	BA
7330-01-DW-103N	Classroom 119	2/3/2017	0.67	BA
7330-01-DW-105N	Classroom 123	2/3/2017	0.074	BA
7330-01-WC-106N	Outside Room 121 - left	2/3/2017	0.074	BA
7330-01-WC-107N	Outside Room 121 - right	2/3/2017	0.26	BA
7330-02-DW-108N	Classroom 207	2/3/2017	0.098	BA
7330-02-DW-110N	Classroom 211	2/3/2017	0.074	BA
7330-02-DW-117N	Classroom 222	2/3/2017	1.5	BA
7330-02-WC-120N	Outside Room 217 - left	2/3/2017	0.074	BA
7330-02-WC-121N	Outside Room 217 - right	2/3/2017	0.074	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb