



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

May 26, 2017

Dear Northeast High School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 68 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Six water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, at your school and others, we have installed hydration stations which we hope that you are using. By the end of this year, all District schools will have hydration stations.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Northeast High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8020-00-WC-001	Room 019 - Industrial Arts Wing	5/10/2017	0.22	BA
8020-00-WC-008	Outside Room 34 - SPARC	5/10/2017	0.75	BA
8020-00-DW-009	Cafeteria	5/10/2017	1.8	BA
8020-00-DW-010	Cafeteria	5/10/2017	1.7	BA
8020-00-KC-012	Kitchen - Double Sink Along Back Wall	5/10/2017	0.90	BA
8020-00-KC-014	Kitchen - Triple Sink Along Back Wall - Left	5/10/2017	0.81	BA
8020-00-KC-016	Kitchen - Triple Sink Along Back Wall - Right	5/10/2017	4.4	BA
8020-00-KC-018	Kitchen - Sink In Prep Table	5/10/2017	8.2	BA
8020-00-KC-020	Kitchen - Back Corner Sink	5/10/2017	1.8	BA
8020-00-KC-022	Kitchen - Prep Table - Left	5/10/2017	0.80	BA
8020-00-KC-024	Kitchen - Prep Table - Right	5/10/2017	0.31	BA
8020-00-IM-025	Kitchen	5/10/2017	0.25	BA
8020-00-KC-028	Faculty Lounge	5/10/2017	1.2	BA
8020-00-DW-029	Cafeteria - Near Serving Area - Left	12/28/2016	1.6	BA
8020-00-HS-030	Cafeteria - Near Serving Area - Right	5/10/2017	0.054	BA
8020-00-DW-031	Cafeteria - Left	5/10/2017	4.2	BA
8020-00-DW-032	Cafeteria - Right	5/10/2017	1.6	BA
8020-00-DW-037	Outside Room 2 - Left	12/28/2016	3.5	BA
8020-00-DW-038	Outside Room 2 - Right	5/10/2017	2.7	BA
8020-00-DW-039	Outside Room 5 - Left	5/10/2017	3.9	BA
8020-00-DW-040	Outside Room 5 - Right	12/28/2016	4.7	BA
8020-01-DW-043	Outside Room 116 - Left (Flush Sample)	12/28/2016	13.3	AA
8020-01-DW-044	Outside Room 116 - Right	12/28/2016	11.9	AA
8020-01-DW-045	Outside Room 130 - Left	5/10/2017	3.8	BA
8020-01-DW-046	Outside Room 130 - Right	5/10/2017	1.9	BA
8020-01-KC-048	Room 132 - Child Development	5/10/2017	3.4	BA
8020-01-HS-050	Outside Main Office - Left	5/10/2017	0.054	BA
8020-01-WC-052	Outside Rooms 152/156	5/10/2017	3.3	BA
8020-01-DW-054	Outside Room 162A - Left	5/10/2017	2.0	BA
8020-01-DW-055	Outside Room 162A - Right	5/10/2017	1.1	BA
8020-01-DW-062	Girls' Locker Room - Left	12/28/2016	50.1	AA
8020-01-DW-066	Room 179 - Gym 4	5/10/2017	2.0	BA
8020-01-DW-067	Across From Room 111 - Left	5/10/2017	7.2	BA
8020-01-DW-068	Across From Room 111 - Right	5/10/2017	3.0	BA
8020-01-DW-070	Across From Room 117/Boys' Room - Left	5/10/2017	5.4	BA
8020-01-DW-071	Across From Room 117/Boys' Room - Right	5/10/2017	2.5	BA
8020-01-DW-072	Outside Room 123 - Left	5/10/2017	5.0	BA
8020-01-DW-073	Outside Room 123 - Right	5/10/2017	5.1	BA
8020-01-DW-074	Outside Room 125 - Left	12/28/2016	9.4	BA
8020-01-DW-076	Outside Room 143 - Left	5/10/2017	3.1	BA
8020-01-DW-077	Outside Room 143 - Right	5/10/2017	2.2	BA
8020-02-DW-078	Outside Room 231 - Left	5/10/2017	3.2	BA
8020-02-DW-079	Outside Room 231 - Right	5/10/2017	2.0	BA
8020-02-DW-080	Outside Room 223 - Left	5/10/2017	3.8	BA
8020-02-DW-081	Outside Room 223 - Right	5/10/2017	4.2	BA
8020-02-DW-082	Outside Room 219 & Boys' Bathroom - Left	5/10/2017	3.3	BA
8020-02-DW-083	Outside Room 219 & Boys' Bathroom - Right	12/28/2016	2.6	BA
8020-02-HS-086	Outside Room 201 & Storage Room - Left	12/28/2016	0.054	BA
8020-02-HS-087	Outside Room 201 & Storage Room - Right	5/10/2017	0.054	BA
8020-02-DW-088	Outside Room 204 & Girls' Bathroom - Left	5/10/2017	5.1	BA
8020-02-DW-089	Outside Room 204 & Girls' Bathroom - Right	5/10/2017	2.4	BA
8020-02-DW-090	Outside Rooms 218 & 222 - Left	12/28/2016	2.6	BA
8020-02-DW-091	Outside Rooms 218 & 222 - Right	12/28/2016	2.7	BA
8020-02-KC-092	Room 224A - Library	5/10/2017	11.0	AA
8020-02-DW-093	Outside Room 230 - Left	5/10/2017	3.9	BA
8020-02-DW-094	Outside Room 230 - Right	5/10/2017	2.6	BA

School Name: Northeast High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8020-01-KC-106	Outside Room 158 - Life Skills	5/10/2017	2.2	BA
8020-01-KC-108	Outside Room 160 - Life Skills	5/10/2017	3.1	BA
8020-00-KC-109	Main Kitchen Island Near Range	5/10/2017	1.6	BA
8020-00-DW-111	Room 26 - School Police Office - Near Cafeteria - Left	5/10/2017	2.3	BA
8020-00-DW-112	Room 26 - School Police Office - Near Cafeteria - Right	5/10/2017	1.3	BA
8020-01-DW-127	Across From Room 105 - Left	5/10/2017	3.6	BA
8020-01-DW-128	Across From Room 105 - Right	5/10/2017	62.4	AA
8020-01-DW-131	Room 173 - Weight Room	5/10/2017	2.0	BA
8020-01-DW-132	Outside Room 175 - Dance Studio	5/10/2017	90.3	AA
8020-01-CF-225	Room 145 - Nurse's Suite - Exam Room D	5/10/2017	9.1	BA
8020-01-CF-226	Room 145 - Nurse's Suite - Office Area	5/10/2017	2.1	BA
8020-01-CF-227	Room 145 - Nurse's Suite - Exam Room C	5/10/2017	4.5	BA
8020-01-CF-228	Room 145 - Nurse's Suite - Exam Room B	5/10/2017	0.95	BA
8020-01-CF-229	Room 145 - Nurse's Suite - Exam Room A	5/10/2017	2.7	BA
8020-01-KC-270	Room 141	5/10/2017	0.57	BA
8020-01-KC-272	Room 143 - Alumni Office	5/10/2017	0.50	BA
8020-01-DW-273	Room 154 - Gym - Near Room 154C	5/10/2017	2.0	BA
8020-01-DW-274	Room 154 - Gym - Near Room 162	5/10/2017	0.89	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

May 26, 2017

Dear Northeast High School Field House Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, 4 of the water outlets passed this stronger water safety threshold and the water is safe to drink. One water outlet was found to have a result above our stronger water safety threshold and was immediately shut off. We are currently developing an action plan to repair or permanently remove it. In addition, we have begun installing hydration stations in schools across the District. So far, we have installed these stations in over 90 schools and by the end of the year, we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

School Name: Northeast High School Field House

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8029-01-DW-003	Visitors' Locker Room	5/10/2017	7.1	BA
8029-01-DW-005	Girls' Locker Room	5/10/2017	24.7	AA
8029-01-DW-008	Soccer Locker Room	5/10/2017	6.0	BA
8029-02-WC-010	Office	5/10/2017	0.21	BA
8029-02-KC-011	Office - Kitchen Counter Sink	5/10/2017	8.2	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb