



THE SCHOOL DISTRICT OF PHILADELPHIA  
Operations Division  
Office of Environmental Management & Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

January 19, 2017

Dear Forrest Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb.

At your school, all of the water outlets passed this stronger water safety threshold and the water is safe to drink. In addition, we have begun installing hydration stations in schools across the District, and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

If you wish to view the detailed results from your school you may visit the District's website at [www.philasd.org/waterresults](http://www.philasd.org/waterresults) to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS  
Environmental Director

School Name: **Forrest Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8250-00-WC-001	Outside girl's room - left	1/10/2017	1.5	BA
8250-00-WC-002	Outside girl's room - right	1/10/2017	0.36	BA
8250-00-DW-003	Inside Room B-1	1/10/2017	3.1	BA
8250-00-WC-008	Outside Boy's Room; Across from B-3	1/10/2017	1.1	BA
8250-01-WC-009	Between Boy's Room and Room 107	1/10/2017	3.0	BA
8250-01-HS-010	Between Girl's Room and Room 104	1/10/2017	0.054	BA
8250-01-WC-011	Room 103	1/10/2017	2.2	BA
8250-01-WC-013	Teacher's Lounge, Room 213	1/10/2017	0.25	BA
8250-02-HS-016	Between Girl's Room and Room 204	1/10/2017	0.054	BA
8250-02-WC-017	Between Boy's Room and Room 207	1/10/2017	0.80	BA
8250-03-WC-018	Between Boy's Room and Room 307	1/10/2017	0.70	BA
8250-03-HS-019	Between Girl's Room and Room 304	1/10/2017	0.054	BA
8250-01-DW-020	Within Modular Building - near bathroom	1/10/2017	1.6	BA
8025-02-CF-055	Nurse's Office	1/10/2017	2.4	BA
8250-01-WC-070N	In PEC Bldg - all purpose room - left	1/10/2017	0.057	BA
8250-01-WC-071N	In PEC Bldg - all purpose room - right	1/10/2017	0.13	BA
8250-01-HS-072N	In PEC Bldg - outside bathroom - left	1/10/2017	0.054	BA
8250-01-WC-074N	In PEC Bldg - between P9 & P11 - left	1/10/2017	0.082	BA
8250-01-WC-075N	In PEC Bldg - between P9 & P11 - right	1/10/2017	0.090	BA
8250-01-WC-076N	In PEC Bldg - Room P1	1/10/2017	0.11	BA
8250-01-WC-077N	In PEC Bldg - Room P2	1/10/2017	0.16	BA
8250-01-WC-078N	In PEC Bldg - Room P3	1/10/2017	0.36	BA
8250-01-WC-079N	In PEC Bldg - Room P4	1/10/2017	0.18	BA
8250-01-WC-080N	In PEC Bldg - Room P5	1/10/2017	0.061	BA
8250-01-KC-081N	In PEC Bldg - Kitchen left	1/10/2017	0.62	BA
8250-01-KC-082N	In PEC Bldg - Kitchen right	1/10/2017	8.2	BA
8250-01-KC-083N	In PEC Bldg - Teacher's Lounge	1/10/2017	0.37	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb