



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division  
Office of Environmental Management & Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

August 1, 2017

Dear Penn Alexander School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb<sup>1</sup>.

At your school, all of the water outlets passed this stronger water safety threshold and the water is safe to drink. In addition, we have begun installing hydration stations in schools across the District and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

If you wish to view the detailed results from your school you may visit the District's website at [www.philasd.org/waterresults](http://www.philasd.org/waterresults) to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS  
Environmental Director

---

<sup>1</sup> This letter and the accompanying table have been revised to reflect the more stringent 10 ppb criteria for lead that has been adopted by the School District of Philadelphia. The previous letter was based upon a 15 ppb criteria for lead.

School Name: Penn Alexander School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1280-00-WC-001	Cafeteria, Room B01 – Left Side	10/28/2016	0.054	BA
1280-00-WC-002	Cafeteria, Room B01 – Right Side	10/28/2016	0.054	BA
1280-00-WC-003	Outside Library Room B23 – Left Side	10/28/2016	0.29	BA
1280-00-WC-004	Outside Library Room B23 – Right Side	10/28/2016	1.2	BA
1280-01-WC-005	Main Office Outside Room 125 – Floor 1R	10/28/2016	0.55	BA
1280-01-WC-006	Gym, Room 100 – Left Side (at Boys Restroom)	10/28/2016	0.054	BA
1280-01-WC-007	Gym, Room 100 – Right Side (at Girls Restroom)	10/28/2016	0.054	BA
1280-01-WC-008	Between Restrooms across from Room 109	10/28/2016	0.054	BA
1280-01-WC-009	Between Restrooms across from Room 118	10/28/2016	0.054	BA
1280-01-WC-010	Next to Room 135 at Elevator – Left Side – Floor 1R	10/28/2016	0.057	BA
1280-01-WC-011	Next to Room 135 at Elevator – Right Side – Floor 1R	10/28/2016	0.12	BA
1280-02-WC-012	Between Restrooms across from Room 209	10/28/2016	0.14	BA
1280-02-WC-013	Between Restrooms across from Room 218	10/28/2016	0.18	BA
1280-02-WC-014	Next to Room 233 at elevator – Left Side – Floor 2R	10/28/2016	0.68	BA
1280-02-WC-015	Next to Room 233 at elevator – Right Side – Floor 2R	10/28/2016	0.82	BA
1280-03-WC-016	Between Restrooms at Room 309	10/28/2016	0.31	BA
1280-03-WC-017	Between Restrooms at Room 318	10/28/2016	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb