



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

August 1, 2017

Dear Overbrook High School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb¹.

At your school, 17 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Twelve water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, we have begun installing hydration stations in schools across the District and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

¹ This letter and the accompanying table have been revised to reflect the more stringent 10 ppb criteria for lead that has been adopted by the School District of Philadelphia. The previous letter was based upon a 15 ppb criteria for lead.

School Name: Overbrook High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4020-00-DW-009	Locker Room above Gymnasium 4	8/18/2016	21.2	AA
4020-01-DW-024	Outside "B" Cafeteria Site Map Room 114 - Left	8/18/2016	10.8	AA
4020-01-DW-025	Outside "B" Cafeteria Site Map Room 114 - 2nd from left	8/18/2016	6.7	BA
4020-01-DW-026	Outside "B" Cafeteria Site Map Room 114 - 3rd from left	8/18/2016	18.9	AA
4020-01-DW-028	Outside "B" Cafeteria Site Map Room 114 - 2nd from right	8/18/2016	34.8	AA
4020-01-DW-029	Outside "B" Cafeteria Site Map Room 114 - Right	8/18/2016	87.0	AA
4020-01-DW-056	Outside Room 100	8/18/2016	7.7	BA
4020-01-DW-057	Outside Room 100 -	8/18/2016	7.5	BA
4020-01-DW-064	Outside Men's Room - Across from Room 105	8/18/2016	11.4	AA
4020-02-DW-081	Outside Room 217 - Left	8/18/2016	7.8	BA
4020-02-DW-082	Outside Room 217 - Right	8/18/2016	7.9	BA
4020-02-DW-095	Outside Main Office - Left	8/18/2016	11.6	AA
4020-02-DW-096	Outside Main Office - Right	8/18/2016	9.4	BA
4020-03-DW-101	Outside Room 309 - Left	8/18/2016	14.2	AA
4020-03-DW-102	Outside Room 309 - Right	8/18/2016	14.3	AA
4020-03-DW-111	Outside Room 318 - Left	8/18/2016	16.3	AA
4020-03-DW-112	Outside Room 318 - Right	8/18/2016	4.3	BA
4020-03-DW-114	Outside Room 326 - Right	8/18/2016	6.3	BA
4020-01-DW-015	Outside of cafeteria - next to Room 112A - left	8/18/2016	6.3	BA
4020-01-DW-016	Outside of cafeteria - next to Room 112A -right	8/18/2016	9.8	BA
4020-00-DW-167	Inside Girl's Locker Room - Site Map Room 001A	8/18/2016	8.8	BA
4020-00-DW-171	Boy's Locker Room - Gym #2 - Site Map Room 010A	8/18/2016	11.2	AA
4020-01-DW-175	Inside Girls Gymnasium - Site Room Map 014A	8/18/2016	5.7	BA
4020-01-DW-177	Inside Boys Gymnasium - site Room Map 013A	8/18/2016	2.4	BA
4020-01-DW-178	Hallway outside of Boys Gymnasium - Site Map Rm 013A	8/18/2016	6.7	BA
4020-01-DW-181	Outside of Boys Gymnasium - Near Exit to Oxford Avenue	8/18/2016	9.3	BA
4020-00-WC-190	Adjacent to Kitchen (Child Care)	8/18/2016	0.63	BA
4020-00-WC-191	South Classroom - 004 Site Map - Child Care	8/18/2016	0.85	BA
4020-00-DW-212	Bldg Engineer Office Area - companion to conventional sink	8/18/2016	33.6	AA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb