



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

August 1, 2017

Dear Wright Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb¹.

At your school, 20 of the water outlets passed this stronger water safety threshold and the water is safe to drink. One water outlet was found to have results above our stronger water safety threshold and was immediately shut off. We are currently developing an action plan to repair or permanently remove it. In addition, we have begun installing hydration stations in schools across the District and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

¹ This letter and the accompanying table have been revised to reflect the more stringent 10 ppb criteria for lead that has been adopted by the School District of Philadelphia. The previous letter was based upon a 15 ppb criteria for lead.

School Name: Wright Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4470-01-WC-006	In Café-Auditorium - near Room 104A	10/27/2016	1.3	BA
4470-01-WC-007	In Café-Auditorium - near Room 101B	10/27/2016	1.3	BA
4470-01-WC-011	Cooler outside Womens Room	10/27/2016	0.42	BA
4470-01-DW-033	Corner of Gym near Boys Room	10/27/2016	1.3	BA
4470-01-DW-034	Opposite Corner of 033	10/27/2016	0.39	BA
4470-01-WC-037	Cooler across from Art Room	10/27/2016	1.7	BA
4470-01-WC-039	Across from Room 122	10/27/2016	0.71	BA
4470-01-WC-040	Outside of Room 122	10/27/2016	0.95	BA
4470-01-WC-052	Outside of Room 114	10/27/2016	0.98	BA
4470-02-DW-059	Room 224	10/27/2016	9.9	BA
4470-02-DW-061	Room 223	10/27/2016	5.3	BA
4470-02-WC-065	Across from Rm 221	10/27/2016	0.54	BA
4470-02-DW-070	Room 219	10/27/2016	8.6	BA
4470-02-DW-072	Room 220	10/27/2016	11.9	AA
4470-02-WC-080	Across from Room 216	10/27/2016	0.57	BA
4470-02-DW-081	Room 216	10/27/2016	4.8	BA
4470-02-WC-089	Across from Room 209	10/27/2016	2.2	BA
4470-02-DW-103	Room 207	10/27/2016	9.9	BA
4470-02-DW-109	Room 205	10/27/2016	5.6	BA
4470-02-DW-116	Room 203	10/27/2016	3.6	BA
4470-01-DW-123	Room 114	10/27/2016	2.6	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb