



THE SCHOOL DISTRICT OF PHILADELPHIA
Operations Division
Office of Environmental Management & Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

August 1, 2017

Dear Cramp Elementary School Family,

To guarantee that students have access to safe drinking water at school, from 2000 to 2010, The School District of Philadelphia (District) conducted a water testing program at schools throughout the District. Nearly 30,000 drinking water outlets were tested and all tested outlets that remain in service produced results that were below the U.S. Environmental Protection Agency's (EPA) action level for lead in water of 20 parts per billion (ppb) and were safe for drinking.

In response to recent public health concerns about lead in water nationally, the District began retesting drinking outlets in your child's school. Our mission remains to ensure the health and safety of all students and staff and because of this we have instituted a stronger water safety threshold of 10 ppb, which is below the national EPA measurement of 20 ppb¹.

At your school, 17 of the water outlets passed this stronger water safety threshold and the water is safe to drink. Fourteen water outlets were found to have results above our stronger water safety threshold and were immediately shut off. We are currently developing an action plan to repair or permanently remove them. In addition, we have begun installing hydration stations in schools across the District and by the end of the year we will have hydration stations in every District school.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing.

Additionally, PDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

If you wish to view the detailed results from your school you may visit the District's website at www.philasd.org/waterresults to learn more.

This re-testing is one part of the District's Drinking Water Program, also available on our website. A key focus is to provide students with healthy hydration – safe, accessible and appealing drinking water in every school.

Sincerely,

Francine Locke, MS
Environmental Director

¹ This letter and the accompanying table have been revised to reflect the more stringent 10 ppb criteria for lead that has been adopted by the School District of Philadelphia. The previous letter was based upon a 15 ppb criteria for lead.

School Name: Cramp Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5470-01-DW-003	Room 110	9/1/2016	10.0	AA
5470-01-DW-006	Room 108	9/1/2016	111	AA
5470-01-DW-009	Room 106	9/1/2016	43.5	AA
5470-01-WC-018	Main Office	8/19/2016	1.7	BA
5470-01-WC-019	Cafeteria	8/19/2016	2.9	BA
5470-01-WC-024	Kitchen - Next to Hand Sink	8/19/2016	4.9	BA
5470-01-DW-037	Gym	8/19/2016	5.0	BA
5470-01-DW-046	Room 13B Classroom	8/19/2016	4.3	BA
5470-01-DW-050	Room 109	9/1/2016	92.9	AA
5470-01-DW-054	Room 111	9/1/2016	14.8	AA
5470-01-DW-058	Room 113	8/19/2016	11.5	AA
5470-02-DW-066	Room 211	8/19/2016	5.8	BA
5470-02-DW-068	Room 209	8/19/2016	1.3	BA
5470-02-DW-070	Room 207	8/19/2016	13.6	AA
5470-02-DW-072	Room 205	9/1/2016	9.8	BA
5470-02-DW-074	Room 201	9/1/2016	13.5	AA
5470-02-DW-077	Room 200	8/19/2016	0.90	BA
5470-02-DW-080	Room 204	8/19/2016	1.7	BA
5470-02-DW-082	Room 206	8/19/2016	10.8	AA
5470-02-DW-084	Room 208	9/1/2016	13.5	AA
5470-02-DW-086	Room 210	8/19/2016	0.64	BA
5470-03-DW-096	Room 311	8/19/2016	2.3	BA
5470-03-DW-098	Room 309	9/1/2016	8.9	BA
5470-03-DW-100	Room 307	8/19/2016	2.1	BA
5470-03-DW-102	Room 305	8/19/2016	5.4	BA
5470-03-DW-104	Room 301	9/1/2016	13.1	AA
5470-03-DW-106	Room 300	8/19/2016	3.5	BA
5470-03-DW-108	Room 304	8/19/2016	12.1	AA
5470-03-DW-110	Room 306	9/1/2016	15.5	AA
5470-03-DW-112	Room 308	8/19/2016	12.5	AA
5470-03-DW-114	Room 310	8/19/2016	9.3	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb