

THE SCHOOL DISTRICT OF PHILADELPHIA
Office of Capital Programs
440 North Broad Street, 3rd Floor – Suite 371
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

Addendum No. 3

Subject: Motivation High School – Major Renovations
SDP Contract Nos. B-014C, B-015C, B-016C, B-017C of 2017/18

Location: Motivation High School
5900 Baltimore Avenue
Philadelphia, Pennsylvania 19143

This Addendum, dated 27th of March, 2018, shall modify and become part of the Contract Documents for the work of this project. Any items not mentioned herein, or affected by, shall be performed strictly in accordance with the original documents.

The following items, clarifications and/or revisions are to be included in the Contract Documents:

GENERAL

1. Bid Proposals will be received at:
The School District of Philadelphia
Office of Capital Programs
440 N. Broad Street
Third Floor – Suite 371
Philadelphia, PA 19130-4015
until 2:00 p.m. on **APRIL 3, 2018**, at which time, in the Conference Room, or other designated location, all proposals received will be opened and read aloud at 2:00 p.m.
2. The Post-Bid Conference, originally scheduled for Friday, March 30, 2018 at 10:00 AM per DOCUMENT 00 0050 INVITATION TO BID, and postponed to Monday, April 2, 2018 at 10:00 AM per ADDENDUM 1, shall be held on **APRIL 4, 2018 AT 10:00 AM**. Attendance by low bidders for each prime contract is required.
3. The following is a correction to a response to a bidder question issued in Addendum 2. Additions shown in **bold**, deletions shown with a ~~strikethrough~~.
Q: Drawing E121A: Who provides control wiring for chair lifts & folding partitions?
A: ~~Electrical contractor~~ **GENERAL CONTRACTOR** shall provide control wiring for chair lifts and partitions.
4. The following drawing update was issued in Addendum 2:
Drawing: A901. ADD General Note 1). Paint all Fin Tube Radiator covers to match unit ventilator cover. Secure all loose Fin Tube covers. Provide new covers where missing/damaged beyond repair first using components salvaged from other locations, then new. Provide new at ten locations to be verified in field with SDP.
The following clarification applies to this drawing update:
Painting of the fin tube radiators by the general contractor. Securing of loose covers by mechanical contractor. New covers by mechanical contractor.

5. The following drawing update was issued in Addendum 2:
Drawings: M111-B, M112-B & M113-B. ADD Note: Fin-Tube Radiation Repair Note: 1. Secure all Fin-tube radiator loose covers. Paint all covers (match finish of new UV). Provide new covers where missing/damaged beyond repair first using components salvaged from other locations, then new per architect approval. Provide new FTR covers at a minimum of ten locations to be verified in field with SDP.

The following clarification applies to this drawing update:

Painting of the fin tube radiators by the general contractor. Securing of loose covers by mechanical contractor. New covers by mechanical contractor.

6. The following specification update was issued in Addendum 2:
Section: 01 1300 Time of Completion, Milestones, Phasing or Sequencing Requirements
Revisions: Section 1.2, B; REVISE to read 'NOTE: WORK AT THE SITE WILL NOT BE PERMITTED UNTIL OCTOBER 1, 2018.'

The following clarification applies to this specification update:

Only PHASE 1 will be permitted to commence work on site on October 1, 2018. All other phases shall follow the phasing plan as documented.

End of Addendum 3