



1 THIRD FLOOR PLAN - FIRE PROTECTION  
SCALE: 1/8" = 1'-0"

- NOTES:
1. REFER TO DRAWING FP000 FOR GENERAL NOTES.
  2. REFER TO DRAWING FP000 FOR SPRINKLER CRITERIA SCHEDULE.
  3. SPRINKLER SYSTEM SHALL DRAIN TO JANITOR CLOSET ON THIS FLOOR.
  4. PROVIDE INSPECTOR'S TEST STATION AS REQUIRED BY CODE.
  5. REFER TO ARCHITECT'S REFLECTED CEILING PLAN FOR CEILING TYPES AND HEIGHTS.
  6. ALL PIPE SIZES NOT SHOWN SHOULD BE 1".