



1 FIRST FLOOR PLAN - FIRE PROTECTION
SCALE: 1/8" = 1'-0"

- SPRINKLER HEAD LEGEND**
- RECESSED PENDENT HEAD (LIGHT HAZARD). PROVIDE DRY TYPE HEAD IN DESIGNATED AREAS.
 - RECESSED PENDENT HEAD (ORDINARY HAZARD)
 - UPRIGHT OR EXPOSED PENDENT HEAD (LIGHT AND ORDINARY COVERAGE)

- NOTES:**
1. REFER TO DRAWING FP000 FOR GENERAL NOTES.
 2. REFER TO DRAWING FP000 FOR SPRINKLER CRITERIA SCHEDULE.
 3. SPRINKLER SYSTEM SHALL DRAIN TO JANITOR CLOSET ON THIS FLOOR.
 4. PROVIDE INSPECTOR'S TEST STATION AS REQUIRED BY CODE.
 5. REFER TO ARCHITECT'S REFLECTED CEILING PLAN FOR CEILING TYPES AND HEIGHTS.
 6. ALL PIPE SIZES NOT SHOWN SHOULD BE 1".