



- NOTES
1. REFER TO DWG. E001 FOR INCOMING PRIMARY SERVICE.
 2. REFER TO DWGS. E500, E501 AND E502 FOR PANEL SCHEDULES.
 3. REFER TO DWG. E000 FOR SYMBOLS LIST.
 4. REFER TO DWG. E301 FOR EMERGENCY LIGHTING PANEL, WIRING DIAGRAMS AND SCHEDULES.
 5. REFER TO DWG. E300 FOR SINGLE LINE DIAGRAM.
 6. PROVIDE A SAFETY SWITCH, NEMA TYPE 3R FOR ALL HVAC MOTORS SIZED PER NEC - SUPPLIED WITH MECHANICAL WORK, INSTALLED AND WIRED UNDER ELECTRICAL WORK.

WORKING HARDER FOR CHILDREN AND FAMILIES

SEAL

SCHOOL & LOCATION
Commodore John Barry Elementary School
5900 Race Street, Philadelphia PA 19139

PROJECT TITLE
NEW CONSTRUCTION

DRAWING TITLE
ROOF PLAN POWER

APPROVED BY

SCHOOL DISTRICT OF PHILADELPHIA
THE SCHOOL REFORM COMMISSION

DEPARTMENT OF DESIGN AND CONSTRUCTION SERVICES

JAN, 2006
PHILADELPHIA, PA 19106
(215) 400-0730 FAX (215) 400-0731

CONTRACTOR TO VERIFY ALL CONDITIONS AND DIMENSIONS AT SITE

NO.	DATE	REVISION
1		
2		
3		
4		
5		
6		
7		
8		
9		

SPEC NO.
B-840C of
2005/06

DATE
12/29/06

SCALE
1/8"=1'-0"

LOCATION NO.
120

DRAWN BY
CDM

TYPE NO.
-

CHECKED BY
FILE NO.
00

DRAWING NO.

E105