


C1	METALUX COLUMBIA	2G-332A-277 EB8	277	3	32	T-8	RECESSED
----	---------------------	--------------------	-----	---	----	-----	----------

2' x 4' UNIT WITH PRISMATIC ACRYLIC
LEN, GASKETED WET LABEL.

NOTES

1. REFER TO DWGS. E500, E501 AND E502 FOR PANEL SCHEDULES.
2. REFER TO DWG. E000 FOR SYMBOL LIST AND FIXTURE SCHEDULE.
3. REFER TO DWG. E300 FOR SINGLE LINE DIAGRAM.
4. REFER TO DWG. E301 FOR EMERGENCY LIGHTING PANEL, WIRING DIAGRAMS AND SCHEDULES.
5. REFER TO REFLECTED CEILING PLANS FOR FINAL LOCATION OF LIGHTING FIXTURES.
6. REFER TO ARCHITECTURAL DRAWINGS FOR MOUNTING HEIGHT OF LIGHTING FIXTURE TYPE.
7. OCCUPANCY SENSOR LOCATED IN EACH CLASSROOM TO CONTROL LIGHTING FIXTURE TYPE A.

1 FIRST FLOOR PLAN LIGHTING
1/8"=1'-0"



SEAL



SCHOOL & LOCATION
PROJECT
DRAWING TITLE
APPROVED BY
DATE

SCHOOL DISTRICT OF PHILADELPHIA
THE SCHOOL REFORM COMMISSION
DEPARTMENT OF DESIGN AND CONSTRUCTION SERVICES
1000 MARKET STREET
PHILADELPHIA, PA 19103
(215) 400-7700 FAX (215) 400-7701

CONTRACTOR TO VERIFY ALL CONDITIONS AND DIMENSIONS AT SITE

NO.	DATE	REVISION
1	12/29/06	1
2	12/29/06	2
3		
4		
5		
6		
7		
8		
9		

SPEC NO.
B-840C of
2006/06
SCALE
1/8"=1'-0"
DRAWN BY
CDM
CHECKED BY
FILE NO.

DRAWING NO.
E201