


1 FOURTH FLOOR PIPING PLAN  
1/8"=1'-0"

#### MECHANICAL NOTES:

1. FOLLOW MANUFACTURER'S RECOMMENDATION FOR PIPING INSTALLATION TO THE UNITS.
2. SEE DRAWINGS M301 AND M302 PIPING RISER DIAGRAM.
3. SEE DRAWING M402 FOR PIPING DETAILS.
4. ALL EXTERIOR PIPING SHALL BE ELECTRIC HEAT TRACED.
5. PROVIDE FIRE PROOFING SYSTEM FOR PIPES THROUGH SHAFT WALL.



SEAL



SCHOOL & LOCATION	Commodore John Barry Elementary School 5900 Race Street, Philadelphia PA 19139
PROJECT TITLE	NEW CONSTRUCTION
DRAWING TITLE	FOURTH FLOOR PIPING PLAN
APPROVED BY	

SCHOOL DISTRICT OF PHILADELPHIA THE SCHOOL REFORM COMMISSION	DEPARTMENT OF DESIGN AND CONSTRUCTION SERVICES
1415 SPRING STREET PHILADELPHIA, PA 19106 (215) 400-8730 FAX (215) 400-4731	CONTRACTOR TO VERIFY ALL CONDITIONS AND DIMENSIONS AT SITE

NO.	DATE	REVISION
1	10/17/07	ADDENDUM No. 1
2		
3		
4		
5		
6		
7		
8		
9		

SPEC. NO. B-840C of 2005/06	DATE 12/29/06
SCALE 1/8"=1'-0"	LOCATION NO. 120
DRAWN BY WVC	TYPE NO. -
CHECKED BY MMT	FILE NO. -

DRAWING NO.  
**M204**