



1 PRIMARY AIR UNIT (PAU-1) — AIR FLOW DIAGRAM 1
NOT TO SCALE

CVU UNITS DUCTWORK	
CFM RANGE	DUCT SIZE
40–100	6"ø
101–180	8"x6"
181–310	12"x6"
311–470	16"x6"




WORKING HARDER FOR
CHILDREN AND FAMILIES


SEAL




TJ BARNET & ASSOCIATES
ARCHITECTS
10 West Hubbard Street Chicago, Illinois 60610
T 312.432.0900 F 312.432.0901




THE SHILOH PARTNERSHIP
ARCHITECTS
200 CHESTNUT STREET PHILADELPHIA, PENNSYLVANIA 19103
215.751.9201 www.shilohpartnership.com



Wiedmann - Zelig Group, LLC
191 N. Queen Avenue
Philadelphia, PA 19123
(215) 421-2344 • (215) 421-2347
www.wiedmann-zelig.com



CSA CENTRAL, INC.
1231 Ritten Drive, Suite 200, King of Prussia, PA 19151
(610) 427-2700, FAX (610) 427-2710



E&M ENGINEERING, INC.
235 PALMONT AVE. STE. #201 HENRICON VALLEY, PA 15089
(412) 467-4500 • FAX (412) 467-0514 www.eandmgrp.com

SCHOOL & LOCATION
Commodore John Barry Elementary School
5900 Race Street, Philadelphia PA 19139

PROJECT TITLE
NEW CONSTRUCTION

DRAWING TITLE
AIR FLOW DIAGRAM 1

APPROVED BY

SCHOOL DISTRICT OF PHILADELPHIA
THE SCHOOL REFORM COMMISSION

DEPARTMENT OF DESIGN AND CONSTRUCTION SERVICES

JAN 18 2004
PHILADELPHIA PA 19106
(215) 400-4730 FAX (215) 400-4731

CONTRACTOR TO VERIFY ALL CONDITIONS AND DIMENSIONS AT SITE

9	8	7	6	5	4	3	2	1
							07/25/07	07/17/07
							ADDENDUM No. 2	ADDENDUM No. 1
							DATE	REVISION

SPEC. NO.
B-840C of
2005/06

SCALE
NONE

DRAWN BY
KHL

CHECKED BY
MMT

DATE
12/29/06

LOCATION NO.
120

TYPE NO.
-

FILE NO.
-

DRAWING NO.
M303