




MECHANICAL NOTES:

- SEE ARCHITECTURAL DRAWINGS FOR DOOR SCHEDULE AND UNDERCUT DOOR INFORMATION.
- SEE ARCHITECTURAL DRAWINGS FOR REFLECTED CEILING PLAN AND EXACT LOCATION OF ALL CEILING MOUNTED DIFFUSERS, REGISTERS AND GRILLES.
- SEE DRAWINGS M301 AND M302 FOR CLASSROOM VENTILATION UNITS (CVU) PIPING CONNECTION DETAILS.
- LOCATE TRANSFER AIR GRILLES $TG-24 \times 8$ AT 1'-0" ABOVE FINISHED FLOOR. SEE TG DETAIL ON DRAWING M406.
- ALL WALL OPENINGS SHALL BE PROVIDED WITH $TG-24 \times 16$ TRANSFER AIR GRILLES AND ARE LOCATED ABOVE THE CEILING. SEE TG DETAIL ON DRAWING M406.
- PROVIDE $TG-24 \times 8$ TRANSFER AIR GRILLES FOR TOILET ROOMS WHERE SHOWN. LOCATE TRANSFER AIR GRILLES AT 9'-0" ABOVE FINISHED FLOOR. SEE TG DETAIL ON DRAWING M406.

1 SECOND FLOOR HVAC PLAN
1/8"=1'-0"



SCHOOL & LOCATION	Commodore John Barry Elementary School 5900 Race Street, Philadelphia PA 19139
PROJECT TITLE	NEW CONSTRUCTION
DRAWING TITLE	SECOND FLOOR HVAC PLAN
APPROVED BY	

SCHOOL DISTRICT OF PHILADELPHIA THE SCHOOL REFORM COMMISSION	DEPARTMENT OF DESIGN AND CONSTRUCTION SERVICES
1400 ARCH STREET PHILADELPHIA, PA 19106 (215) 400-7730 FAX (215) 400-4731	

NO.	DATE	REVISION
1	10/29/07	ADDENDUM No. 2

SPEC NO. B-840C of 2005/06	DATE 12/29/06
SCALE 1/8"=1'-0"	LOCATION NO. 120
DRAWN BY KHL	TYPE NO. -
CHECKED BY MMT	FILE NO. -

DRAWING NO.
M102