MATCHLINE
SEE DWG. H-12 FOR CONTINUATION

SEE DWG. H-12
FOR CONTINUATION

UV-1

1" HWS&R, 1 1/4" CHWS&R
BEHIND CASEWORK TO UV-1

10'-0" A.F.F., TYP

9'-4" A.F.F.

G.W.B. SOFFIT @ 8'-0" A.F.F.

6"D NICHE FOR CONVECTOR
(BELOW WINDOW)

CONV-1

CONV-1 ON 3RD FLOOR
(PIPED FROM 2ND FLOOR CEILING)

CORRIDOR
300C

LEARNING SUPPORT
322

SECOND GRADE
323

SECOND GRADE
324

SECOND GRADE
325

STAIRWAY
003

FOR STAIR DETAIL PLANS/SECTIONS/
ELEVATIONS SEE DWGS A4.1 - A4.4 (TYP)

(ELECTRIC)
UH

DN

1'-7"

5"#SLV45°L
(x 4)

2" CHWS&R DN

1 1/2" HWS&R DN

3/4" CONDENSATE DN

1" HWS&R, 1 1/4" CHWS&R
BEHIND CASEWORK TO UV-1

P-LAM. COUNTER W/
SHELVING BELOW, BY MECH. CONTR., TYP.

UNIT VENTILATOR

UV-1

2" CHWS & R DN

1 1/2" HWS & R DN

3/4" CONDENSATE DN

1" HWS&R, 1 1/4" CHWS&R
BEHIND CASEWORK TO UV-1

CONV-1 ON 3RD FLOOR
(PIPED FROM 2ND FLOOR CEILING)

CONVECTOR LOCATED
HERE AS PER ASK-23.1

3'-9 1/2"

3'-3 3/4"

HSLV-11

HSLV-12

HSLV-13

HSLV-14

9

10

10.6

11

11.6

12

C.6

D

E

G

HVAC PIPING NOTES

1. ALL DRAINS ARE 3/4" UNLESS NOTED OTHERWISE
2. ALL VENTS ARE 1/2" UNLESS NOTED OTHERWISE
3. PIPE ELEVATIONS ARE TAKEN FROM 3RD FLOOR FIN. FL.

AS-BUILT
REVISED
BRINJAC, KAN... ASSOCIATES, INC.
DATE 3/24/98 3/19/97
BY KWO

TRACEY MECHANICAL, INC.
401 CITY LINE AVE.
SUITE 212
BALA CYNWYD, PA. 19004

JOB NAME: 6TH AND DUNCANNON

TITLE: PARTIAL 3RD FLOOR
HVAC PIPING

DATE: 10/11/96
SCALE: 3/8"-1'-0"
DRAWN: L.W.

DRAWING NO. H-14

NO.	REVISION	DATE	BY

\CAD\DWG\MVH-14 Fri Sep 19 14:03:39 1997