



THE SCHOOL DISTRICT OF PHILADELPHIA

BOARD OF EDUCATION
Office of Capital Programs
440 North Broad Street, 3rd Floor – Suite 371
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

Addendum No. 1

Subject: Bid B-036 C of 2017/18 for General Contractor Services on Coal Storage & Wall Repairs, November 6, 2018 at 2:00PM

Location: Beeber High School

This Addendum, dated October 30, 2018, shall modify and become part of the Contract Documents. Any items not mentioned herein, or affected by, shall remain strictly in accordance with the original document.

Questions and Answers

1. Question:

On detail 1/S4.0 the extent of repairs is shown as 50 feet. It appears that the deficiencies in the wall continue much farther than 50 feet from end corner. Please advise on the total length of repairs from start to end.

Answer:

The length of repairs from start to end shall be increased from 50 feet to a total extent of 100 feet of wall length.

Additional Items to be Included in Construction Bid:

- i. Two (2) additional columns, not previously included in the construction drawing set, shall be included for repair according to the requirements depicted in detail 11/S3.0 of the published documents. These columns are located immediately south and east of grid line F roughly intersecting with grid lines 8 and 11 adjacent to the areas noted in the documents included for repair. The spall repairs shall occur over the lowest 4'-0" of the column height above the floor slab in the basement space.
- ii. Section 01 1300 TIME OF COMPLETION is modified as follows
 - Substantial Completion NO LATER THAN AUGUST 1, 2019
 - Final Completion NO LATER THAN SEPTEMBER 30, 2019

End of Addendum #1