



THE SCHOOL DISTRICT OF  
PHILADELPHIA

**Operations Division**

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

**December 19, 2018**

Dear **Adaire Elementary School** Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **October 30, 2018**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

There were **11** outlets tested at your school. Of those outlets, **all** outlets produced water that was below the action level of 10 ppb.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: [www.philasd.org/waterresults](http://www.philasd.org/waterresults).

Sincerely,

Francine Locke, MS  
Environmental Director



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
 440 North Broad Street  
 Philadelphia, Pennsylvania 19130  
 215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Action Limit
10/30/2018	1	1	WF	Outside men's rm in lobby	6.2	0.3	1.0	BA
10/30/2018	1	2	HS	Outside RM 101	<1.0	0.3	1.0	BA
10/30/2018	1	3	FT	Inside Nurse office next to fridge	4.7	0.3	1.0	BA
10/30/2018	1	4	FT	Nurse RM next to bookcase	3.5	0.3	1.0	BA
10/30/2018	1	5	HS	Outside boys RM across from RM 104	<1.0	0.3	1.0	BA
10/30/2018	1	6	WF	Inside RM 109 next to brown double doors	1.8	0.3	1.0	BA
10/30/2018	1	7	WF	In Gym	4.2	0.3	1.0	BA
10/30/2018	2	8	WF	Outside RM 216B left fountain	<1.0	0.3	1.0	BA
10/30/2018	2	9	WF	Outside RM 216B. Right bubbler	<1.0	0.3	1.0	BA
10/30/2018	2	10	HS	Across from RM 208 next to girls RM	<1.0	0.3	1.0	BA
10/30/2018	2	11	WF	Between RM 201 and 203	<1.0	0.3	1.0	BA

**Notes:**

AA = Above Action limit of 10 ppb  
 BA = Below Action limit of 10 ppb  
 MDL = Method Detection Limit  
 PQL = Practical Quantitation Limit  
 J = Result estimated below the PQL  
 < = not detected above PQL  
 ppb = parts per billion

**Outlet Types:**

WF=Water Fountain/Bubbler  
 HS=Hydration Station/Bottle Filling Station  
 FT=Faucet/Tap  
 FP - Food Prep/Pot-Filler/Kitchen Kettle  
 IM - Ice-Maker