



THE SCHOOL DISTRICT OF  
PHILADELPHIA

**Operations Division**

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

**December 19, 2018**

Dear **Kensington Health & Sciences** Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **November 1<sup>st</sup> and 14<sup>th</sup>, 2018**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

There were **24** outlets tested at your school. Of those outlets, **20** outlets produced water that was below the action level of 10 ppb. **Four (4)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

An action plan is being developed to determine the best way to address the outlet(s) that was shut-off (if applicable to your school), including replacing the outlet with a new hydration station or, if the outlet is not needed because another outlet is available nearby, the outlet may be permanently removed from the school. Once a decision is made, the Maintenance Department will perform the new installation or remove the existing outlet.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: [www.philasd.org/waterresults](http://www.philasd.org/waterresults).

Sincerely,

Francine Locke, MS  
Environmental Director



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Action Limit
11/1/2018	2	1	FT	Food service Kitchen sink	<1.0	0.3	1.0	BA
11/1/2018	2	2	HS	Across Hall from RM 216	<1.0	0.3	1.0	BA
11/1/2018	1	3	WF	Fountain on sink in RM 101 next to restroom	<1.0	0.3	1.0	BA
11/14/2018	1	4	WF	Fountain on sink in RM 110	<1.0	0.3	1.0	BA
11/1/2018	1	5	WF	Fountain on sink in RM 102 next to restroom	<1.0	0.3	1.0	BA
11/14/2018	1	6	WF	Fountain on sink in RM 106	<1.0	0.3	1.0	BA
11/1/2018	1	7	FT	Inside Nurse Rm 114 next to restroom	<1.0	0.3	1.0	BA
11/1/2018	1	8	HS	Next to Janitor RM 111	<1.0	0.3	1.0	BA
11/1/2018	1	9	HS	Next to mechanical Rm 117	<1.0	0.3	1.0	BA
11/1/2018	1	10	IM	Inside storage RM 120A	<1.0	0.3	1.0	BA
11/14/2018	1	11	FT	Sink in Nurse's suite RM 114	<1.0	0.3	1.0	BA
11/14/2018	1	12	WF	Fountain on sink in RM 110	1.5	0.3	1.0	BA
11/14/2018	1	13	WF	Fountain on sink in RM 106	<1.0	0.3	1.0	BA
11/14/2018	1	14	WF	Fountain on sink in RM 104	<1.0	0.3	1.0	BA
11/14/2018	1	15	WF	Fountain on sink in RM 104	4.5	0.3	1.0	BA
11/14/2018	2	16	FT	Sink near mechanical closet in RM 216	33.1	0.3	1.0	AA
11/14/2018	2	17	FT	Sink on same wall as mechanical closet RM 216	2.9	0.3	1.0	BA
11/14/2018	2	18	FT	Large Faucet in First spit sink in RM 216	41.7	0.3	1.0	AA
11/14/2018	2	19	FT	Large Faucet in second spit sink in RM 216	<1.0	0.3	1.0	BA
11/14/2018	2	20	FT	Smaller faucet at second spit sink in RM 216	<1.0	0.3	1.0	BA
11/14/2018	2	21	FT	Third spit sink large faucet in RM 216	2.2	0.3	1.0	BA
11/14/2018	2	22	FT	Smaller faucet in third spit sink room 216	2.2	0.3	1.0	BA
11/14/2018	2	23	FT	Fourth spit sink large faucet in RM 216	375.2	0.3	1.0	AA
11/14/2018	2	24	FT	Sink in RM 214	186.9	0.3	1.0	AA

**Notes:**

AA = Above Action limit of 10 ppb  
BA = Below Action limit of 10 ppb  
MDL = Method Detection Limit  
PQL = Practical Quantitation Limit  
J = Result estimated below the PQL  
< = not detected above PQL  
ppb = parts per billion

**Outlet Types:**

WF=Water Fountain/Bubbler  
HS=Hydration Station/Bottle Filling Station  
FT=Faucet/Tap  
FP - Food Prep/Pot-Filler/Kitchen Kettle  
IM - Ice-Maker