



THE SCHOOL DISTRICT OF  
PHILADELPHIA

**Operations Division**

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

**January 16, 2019**

Dear **Kensington High School** Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **October 23, 2018 and November 1<sup>st</sup> and 2<sup>nd</sup>, and December 20<sup>th</sup> 2018**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

There were **19** outlets tested at your school. **All** outlets produced water that was below the action level of 10 ppb.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: [www.philasd.org/waterresults](http://www.philasd.org/waterresults).

Sincerely,

Francine Locke, MS  
Environmental Director



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Action Limit
10/23/2018	0	1	WF	In cafeteria closer to auditorium	1.8	0.3	1.0	BA
10/23/2018	0	2	WF	Left, in double group in cafeteria	2.5	0.3	1.0	BA
10/23/2018	0	3	WF	Right, in double group in cafeteria	<1.0	0.3	1.0	BA
10/23/2018	0	4	WF	Left, in double group across from auditorium	<1.0	0.3	1.0	BA
10/23/2018	0	5	WF	Right, in double group across from auditorium	<1.0	0.3	1.0	BA
10/23/2018	0	6	FT	Left double sink faucet in cafeteria kitchen	7.2	0.3	1.0	BA
10/23/2018	0	7	FT	Right double sink faucet in cafeteria kitchen	2.1	0.3	1.0	BA
10/23/2018	1	8	WF	Outside RM 109	3.6	0.3	1.0	BA
11/2/2018	1	9	HS	Outside room 115	<1.0	0.3	1.0	BA
10/23/2018	1	10	WF	Outside Principal's Office	<1.0	0.3	1.0	BA
10/23/2018	2	11	WF	Between RMs 223 and 221	1.1	0.3	1.0	BA
10/23/2018	2	12	HS	Outside RM 219	<1.0	0.3	1.0	BA
10/23/2018	2	13	WF	Outside RM 215	<1.0	0.3	1.0	BA
12/20/2018	2	14	WF	Outside RM 209	4.2	0.3	1.0	BA
10/23/2018	3	15	WF	Outside RM 309	<1.0	0.3	1.0	BA
10/23/2018	3	16	HS	Outside RM 319	<1.0	0.3	1.0	BA
10/23/2018	3	17	WF	Outside RM 323	<1.0	0.3	1.0	BA
10/23/2018	2	18	FT	Sink in RM 201 Nurse's office	1.9	0.3	1.0	BA
11/1/2018	0	19	IM	Inside kitchen to right	<1.0	0.3	1.0	BA

**Notes:**

AA = Above Action limit of 10 ppb  
 BA = Below Action limit of 10 ppb  
 MDL = Method Detection Limit  
 PQL = Practical Quantitation Limit  
 J = Result estimated below the PQL  
 < = not detected above PQL  
 ppb = parts per billion

**Outlet Types:**

WF=Water Fountain/Bubbler  
 HS=Hydration Station/Bottle Filling Station  
 FT=Faucet/Tap  
 FP - Food Prep/Pot-Filler/Kitchen Kettle  
 IM - Ice-Maker