



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

April 29, 2019

Dear **AMY @ James Martin Community**,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **April 12, 2019**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were 12 outlets tested at your school. All outlets produced water that was below the action level of 10 ppb.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Francine Locke, MS
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
 440 North Broad Street
 Philadelphia, Pennsylvania 19130
 215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL	PQL	Action Limits
04/12/2019	3	1	HS	Next to 314	<1.0	0.3	1.0	BA
04/12/2019	3	2	WF	Across from 308	<1.0	0.3	1.0	BA
04/12/2019	2	3	WF	Outside RM 308	<1.0	0.3	1.0	BA
04/12/2019	2	4	HS	Outside RM 214	<1.0	0.3	1.0	BA
04/12/2019	1	5	HS	Outside Nurse office	<1.0	0.3	1.0	BA
04/12/2019	1	6	FT	Inside Nurse Office	1.3	0.3	1.0	BA
04/12/2019	1	7	FT	Inside Nurse Bathroom	3.6	0.3	1.0	BA
04/12/2019	1	8	WF	Inside RM 107	<1.0	0.3	1.0	BA
04/12/2019	1	9	HS	Across from RM 108	<1.0	0.3	1.0	BA
04/12/2019	1	10	FT	Inside RM 109	<1.0	0.3	1.0	BA
04/12/2019	0	11	FT	In Caf behind food line	<1.0	0.3	1.0	BA
04/12/2019	0	12	WF	By exit in basement (only fountain in basement)	2.6	0.3	1.0	BA

Notes:

AA = Above Action limit of 10 ppb
 BA = Below Action limit of 10 ppb
 MDL = Method Detection Limit
 PQL = Practical Quantitation Limit
 J = Result estimated below the PQL
 < = not detected above PQL
 ppb = parts per billion

Outlet Types:

WF=Water Fountain/Bubbler
 HS=Hydration Station/Bottle Filling Station
 FT=Faucet/Tap
 FP - Food Prep/Pot-Filler/Kitchen Kettle
 IM - Ice-Maker