



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division
Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

April 29, 2019

Dear **Anderson Elementary School** Community,

As a part of the School District of Philadelphia’s effort to provide students and staff with safe, accessible and appealing drinking water, **17** water outlets at your school were initially tested for lead on **January 3, 2019**. Of those outlets, **14** outlets produced water that was below the action level of 10 ppb. **Three (3)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those five water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
1/3/2019	1	8	FT	Sink inside Nurse Bathroom	12.1	0.3	1.0	Replaced faucet and retested.
2/15/2019	1	8	FT	Sink inside Nurse Bathroom	6.2	0.3	1.0	Returned to service.
1/3/2019	1	11	FT	Inside RM 102	12.3	0.3	1.0	Replaced faucet and retested.
2/15/2019	1	11	FT	Inside RM 102	3,307 (559 ¹)	0.3	1.0	Permanently removed faucet.
1/3/2019	1	16	FT	Inside Bathroom inside RM 105	15.6	0.3	1.0	Made handwash sink. Will apply sign.

Notes:

AA = Above Action limit of 10 ppb
BA = Below Action limit of 10 ppb
MDL = Method Detection Limit
PQL = Practical Quantitation Limit
J = Result estimated below the PQL
< = not detected above PQL
ppb = parts per billion

Outlet Types:

WF=Water Fountain/Bubbler
HS=Hydration Station/Bottle Filling Station
FT=Faucet/Tap
FP - Food Prep/Pot-Filler/Kitchen Kettle
IM - Ice-Maker

¹Indicates a follow-up flush sample result. Standard protocol when retesting AA outlets is to collect a follow-up flush sample.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District’s website. If you wish to review the results from your school and for more information, you may visit the District’s website at:

www.philasd.org/waterresults.



THE SCHOOL DISTRICT OF
PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

Sincerely,

Francine Locke, MS
Environmental Director