



City of Philadelphia - Department of Public Health  
Air Management Services, 2nd Fl. Asbestos Control Unit  
321 University Ave. Philadelphia, PA 19104

Office Use Only

Date Received L&I:

Date Received AMS:

Date Inspected

Inspector No.

# Asbestos Inspection Report

1. Name of Building / Property: \_\_\_\_\_ Address \_\_\_\_\_

2. Name of Building / Property Owner: \_\_\_\_\_ Address \_\_\_\_\_ Phone No. \_\_\_\_\_

3. Name of Philadelphia Certified Investigator: \_\_\_\_\_ Certification No. \_\_\_\_\_ Contact Information / Email / Phone No. \_\_\_\_\_

L&I Commercial Activity No. (Former Business Privilege License No.) \_\_\_\_\_ Business Tax ID No. \_\_\_\_\_

4. Name of Philadelphia Licensed Laboratory: \_\_\_\_\_ License No. \_\_\_\_\_ Phone No. \_\_\_\_\_

5. Scope of Work: (Insert or attach a complete description of the portion of the subject property inspected and the anticipated work that will result in the disturbance of the identified Asbestos Containing Materials (ACMs) (e.g. demolition, asbestos abatement, and / or renovation activities.)

6.  Property has been declared to be in imminent danger (ID) of failure or collapse by the City of Philadelphia Department of Licenses & Inspections. Attached is a copy of the L&I Notice of Violation declaring the property I.D. **\*\*Note: INVESTIGATOR MUST BE ON SITE DURING DEMOLITION!**

7. (ACMs) identified?  Yes (List Below)  No (explain)

8. Suspected ACM's sampled?  Yes (attached are copies of the laboratory chain of custody and bulk sample results.)  No (Why?)

9. List all identified ACM's located in the planned renovation/demolition areas. Damaged ACM must be listed and then repaired or removed prior to renovation. You (Investigator) must label all ACM that may be left in the work area. (Attached are add'tl sheets)

Location	Description	Type (Code 1)	Amount		Condition (Code 2)	Action (Code 3)
			Square	Linear		

**Code 1**

FRI - Friable  
NF1 - Non-Friable, Cat. 1  
NF2 - Non-Friable, Cat. 2

**Code 2**

DD - Deteriorated or Delaminated  
ND - Non-Damaged

**Code 3**

REM - Removal necessary prior to Demo/Reno  
NRN - No removal necessary, label ACM  
REP - Repair & Label ACM, removal not necessary

10. I hereby certify that the foregoing statements are true and the information contained in this report is true. This certification is made subject to the penalties set forth in 18 PA. C.S. S4904 relating to unsworn falsification to authorities. Furthermore I certify that the inspection, sampling, and labeling requirements of section X of the Asbestos Control Regulation (ACR) have been met. The building owner has been notified of the ACR requirements and given a copy of this report. If the inspection has revealed ACM which will be disturbed by the proposed work or if it has revealed ACM in bad condition, the building owner has been notified to remove or repair the ACM in accordance with the ACR prior to renovation or demolition activity.

11. Signature of Certified Asbestos Investigator: Brian Joseph Date: \_\_\_\_\_ Signature of Building Owner: \_\_\_\_\_ Date: \_\_\_\_\_

<i>F</i> <i>l</i> <i>o</i> <i>o</i> <i>r</i>	Space #	On Site Room Name	Material Description	Type (Code1)	Confirmed/Assumed/ NAD/ Non Suspect ACM	Amount of Material	SF LF EA	Condition (Code2)	Action (Code 3)	Comments/Description/Notes *Abatement must be coordinated with the Construction Project Management Team if material will be impacted
1		Main Entrance Lobby (Chestnut Street)	Pipe Saddle Insulation	FRI	Confirmed	16	LF	ND	NRN	* Coordination required if material will be impacted
1		Room 110	Pipe Saddle Insulation	FRI	Confirmed	8	LF	ND	NRN	* Coordination required if material will be impacted
1		Room 110 Closet	Pipe Saddle Insulation	FRI	Confirmed	2	LF	ND	NRN	* Coordination required if material will be impacted
1		Room 111	Pipe Saddle Insulation	FRI	Confirmed	8	LF	ND	NRN	* Coordination required if material will be impacted
1		Room 112	Pipe Saddle Insulation	FRI	Confirmed	8	LF	ND	NRN	* Coordination required if material will be impacted
1		Room 113 A/B	Pipe Saddle Insulation	FRI	Confirmed	8	LF	ND	NRN	* Coordination required if material will be impacted
2	S22	Stairwell near Student Restrooms and Elevator	Plaster Ceiling	x	NAD	300	SF	x	x	
2	S22	Stairwell near Student Restrooms and Elevator	Concrete Block Wall	x	Non Suspect ACM	888	SF	x	x	
2	S22	Stairwell near Student Restrooms and Elevator	Floor Tile VAT 9" x 9"	NF1	Confirmed	108	SF	ND	NRN	
2	S22	Stairwell near Student Restrooms and Elevator	Floor Tile VAT 9" x 9"	NF1	Confirmed	5	SF	ND	NRN	
2	S22	Stairwell near Student Restrooms and Elevator	Floor Tile VAT 12" x 12"	NF1	Assumed	8	SF	ND	NRN	
2	S22	Stairwell near Student Restrooms and Elevator	Cement Floor	x	Non Suspect ACM	180	SF	x	x	
2	H30	Hallway near Girl's Restroom to Stairwell	Ceiling Tile 2' x 2'	x	NAD	54	SF	x	x	
2	H30	Hallway near Girl's Restroom to Stairwell	Concrete Block Wall	x	Non Suspect ACM	162	SF	x	x	
2	H30	Hallway near Girl's Restroom to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	54	SF	ND	NRN	
2	H30	Hallway near Girl's Restroom to Stairwell	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
2	201E	Girl's Restroom	Plaster Ceiling	x	NAD	180	SF	x	x	
2	201E	Girl's Restroom	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
2	201E	Girl's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	180	SF	x	x	
2	201D	Boy's Restroom	Plaster Ceiling	x	NAD	180	SF	x	x	
2	201D	Boy's Restroom	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
2	201D	Boy's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	180	SF	x	x	
2	201D	Boy's Restroom	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
2	201C	Staff and Handicap Restroom next to Boy's	Plaster Ceiling	x	NAD	35	SF	x	x	Pipe Chase Access in Room
2	201C	Staff and Handicap Restroom next to Boy's	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	Pipe Chase Access in Room
2	201C	Staff and Handicap Restroom next to Boy's	Ceramic Tile Floors	x	Non Suspect ACM	35	SF	x	x	Pipe Chase Access in Room
2	201B	Staff Restroom across from Teacher's Office	Plaster Ceiling	x	NAD	35	SF	x	x	Pipe Chase Access in Room
2	201B	Staff Restroom across from Teacher's Office	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	Pipe Chase Access in Room
2	201B	Staff Restroom across from Teacher's Office	Ceramic Tile Floors	x	Non Suspect ACM	35	SF	x	x	Pipe Chase Access in Room
2	201B	Staff Restroom across from Teacher's Office	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
2	PC201	Pipe Chase in Staff Restroom across from	Fiberglass Pipe Insulation	x	Non Suspect ACM	20	LF	x	x	
2	PC201	Pipe Chase in Staff Restroom across from	Pipe Fitting Insulation	x	NAD	5	EA	x	x	
2	PC201	Pipe Chase in Staff Restroom across from	Concrete Ceiling	x	Non Suspect ACM	40	SF	x	x	
2	PC201	Pipe Chase in Staff Restroom across from	Concrete Block Wall	x	Non Suspect ACM	400	SF	x	x	
2	PC201	Pipe Chase in Staff Restroom across from	Cement Floor	x	Non Suspect ACM	40	SF	x	x	
2	H27	Hallway from Staff and Handicap Restroom to	Ceiling Tile 2' x 2'	x	NAD	392	SF	x	x	
2	H27	Hallway from Staff and Handicap Restroom to	Concrete Block Wall	x	Non Suspect ACM	700	SF	x	x	
2	H27	Hallway from Staff and Handicap Restroom to	Floor Tile VAT 9" x 9"	NF1	Confirmed	392	SF	ND	NRN	
2	207	Classroom 207	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
2	207	Classroom 207	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
2	207	Classroom 207	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
2	207	Classroom 207	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	207	Classroom 207	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	207A	Classroom 207 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	207A	Classroom 207 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	207A	Classroom 207 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	206	Classroom 206	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
2	206	Classroom 206	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
2	206	Classroom 206	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
2	206	Classroom 206	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	206	Classroom 206	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	206	Classroom 206	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	206A	Classroom 206 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	206A	Classroom 206 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	206A	Classroom 206 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	H29	Hallway near Classroom 206 to Stairwell	Ceiling Tile 2' x 2'	x	NAD	200	SF	x	x	
2	H29	Hallway near Classroom 206 to Stairwell	Concrete Block Wall	x	Non Suspect ACM	540	SF	x	x	
2	H29	Hallway near Classroom 206 to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	200	SF	ND	NRN	
2	H29	Hallway near Classroom 206 to Stairwell	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
2	S21	Stairwell near Classroom 206	Plaster Ceiling	x	NAD	260	SF	x	x	

2	S21	Stairwell near Classroom 206	Concrete Block Wall	x	Non Suspect ACM	864	SF	x	x	
2	S21	Stairwell near Classroom 206	Floor Tile VAT 9" x 9"	NF1	Confirmed	90	SF	ND	NRN	
2	S21	Stairwell near Classroom 206	Cement Floor	x	Non Suspect ACM	170	SF	x	x	
2	204	Classroom 204	Ceiling Tile 2' x 2'	x	NAD	324	SF	x	x	
2	204	Classroom 204	Concrete Ceiling	x	Non Suspect ACM	516	SF	x	x	
2	204	Classroom 204	Concrete Block Wall	x	Non Suspect ACM	580	SF	x	x	
2	204	Classroom 204	Sheetrock Wall	x	Non Suspect ACM	580	SF	x	x	
2	204	Classroom 204	Floor Tile VAT 12" x 12"	NF1	Assumed	840	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	H26A	Hallway to Classrooms 203, 204, and 205	Ceiling Tile 2' x 2'	x	NAD	156	SF	x	x	
2	H26A	Hallway to Classrooms 203, 204, and 205	Concrete Ceiling	x	Non Suspect ACM	36	SF	x	x	
2	H26A	Hallway to Classrooms 203, 204, and 205	Sheetrock Wall	x	Non Suspect ACM	518	SF	x	x	
2	H26A	Hallway to Classrooms 203, 204, and 205	Floor Tile VAT 12" x 12"	NF1	Assumed	192	SF	ND	NRN	
2	205	Classroom 205	Ceiling Tile 2' x 2'	x	NAD	404	SF	x	x	
2	205	Classroom 205	Concrete Ceiling	x	Non Suspect ACM	514	SF	x	x	
2	205	Classroom 205	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
2	205	Classroom 205	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	205	Classroom 205	Sheetrock Wall	x	Non Suspect ACM	380	SF	x	x	
2	205	Classroom 205	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	205	Classroom 205	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	205A	Classroom 205 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	205A	Classroom 205 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	205A	Classroom 205 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	203	Classroom 203	Ceiling Tile 2' x 2'	x	NAD	522	SF	x	x	
2	203	Classroom 203	Concrete Ceiling	x	Non Suspect ACM	396	SF	x	x	
2	203	Classroom 203	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
2	203	Classroom 203	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	203	Classroom 203	Sheetrock Wall	x	Non Suspect ACM	340	SF	x	x	
2	203	Classroom 203	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	203	Classroom 203	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	203A	Classroom 203 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	203A	Classroom 203 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	203A	Classroom 203 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	H26AB	Closet in Hallway to Classrooms 203, 204, and 205	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	H26AB	Closet in Hallway to Classrooms 203, 204, and 205	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	H26AB	Closet in Hallway to Classrooms 203, 204, and 205	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	202	Classroom 202	Ceiling Tile 2' x 2'	x	NAD	420	SF	x	x	
2	202	Classroom 202	Concrete Ceiling	x	Non Suspect ACM	498	SF	x	x	
2	202	Classroom 202	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
2	202	Classroom 202	Sheetrock Wall	x	Non Suspect ACM	560	SF	x	x	
2	202	Classroom 202	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	202A	Classroom 202 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	202A	Classroom 202 Closet	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
2	202A	Classroom 202 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	201	Teacher's General Office Room	Ceiling Tile 2' x 2'	x	NAD	240	SF	x	x	
2	201	Teacher's General Office Room	Concrete Block Wall	x	Non Suspect ACM	512	SF	x	x	
2	201	Teacher's General Office Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	240	SF	ND	NRN	
2	201A	Computer Server Room	Pipe Fitting Insulation	x	NAD	1	EA	x	x	
2	201A	Computer Server Room	Fiberglass Pipe Insulation	x	Non Suspect ACM	13	LF	x	x	
2	201A	Computer Server Room	Concrete Ceiling	x	Non Suspect ACM	112	SF	x	x	
2	201A	Computer Server Room	Concrete Block Wall	x	Non Suspect ACM	552	SF	x	x	
2	201A	Computer Server Room	Cement Floor	x	Non Suspect ACM	112	SF	x	x	
2	200	Library	Ceiling Tile 2' x 2'	x	NAD	3880	SF	x	x	
2	200	Library	Concrete Block Wall	x	Non Suspect ACM	2740	SF	x	x	
2	200	Library	Carpet	x	Non Suspect ACM	3880	SF	x	x	
2	200C	Library Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	200C	Library Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	200C	Library Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	200B	Library Office	Ceiling Tile 2' x 2'	x	NAD	220	SF	x	x	
2	200B	Library Office	Concrete Block Wall	x	Non Suspect ACM	540	SF	x	x	
2	200B	Library Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	220	SF	ND	NRN	
2	200B	Library Office	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	H20	Hallway to Library Entrance from Main Hallway	Ceiling Tile 2' x 2'	x	NAD	168	SF	x	x	
2	H20	Hallway to Library Entrance from Main Hallway	Concrete Block Wall	x	Non Suspect ACM	360	SF	x	x	
2	H20	Hallway to Library Entrance from Main Hallway	Floor Tile VAT 9" x 9"	NF1	Confirmed	168	SF	ND	NRN	
2	208	Room 208 Speech Therapist Office	Ceiling Tile 2' x 2'	x	NAD	322	SF	x	x	
2	208	Room 208 Speech Therapist Office	Concrete Block Wall	x	Non Suspect ACM	740	SF	x	x	
2	208A	Room 208 Speech Therapist Office	Floor Tile VAT 12" x 12"	NF1	Assumed	350	SF	ND	NRN	
2	208A	Room 208A General Office Space next to	Ceiling Tile 2' x 2'	x	NAD	210	SF	x	x	

2	208A	Room 208A General Office Space next to	Concrete Block Wall	x	Non Suspect ACM	580	SF	x	x	
2	208	Room 208A General Office Space next to	Floor Tile VAT 9" x 9"	NF1	Confirmed	210	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	216	Teacher Work Area	Pipe Fitting Insulation	x	NAD	1	EA	x	x	
2	216	Teacher Work Area	Fiberglass Pipe Insulation	x	Non Suspect ACM	9	LF	x	x	
2	216	Teacher Work Area	Ceiling Tile 2' x 2'	x	NAD	350	SF	x	x	
2	216	Teacher Work Area	Concrete Block Wall	x	Non Suspect ACM	702	SF	x	x	
2	216	Teacher Work Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	350	SF	ND	NRN	
2	200A	Teacher Lounge	Ceiling Tile 2' x 2'	x	NAD	418	SF	x	x	
2	200A	Teacher Lounge	Concrete Block Wall	x	Non Suspect ACM	820	SF	x	x	
2	200A	Teacher Lounge	Floor Tile VAT 9" x 9"	NF1	Confirmed	418	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	200A	Teacher Lounge	Sink Undercoat Mastic	NF2	Assumed	7	SF	ND	NRN	
2	209A	Book Closet next to Classroom 209	Pipe Fitting Insulation	x	NAD	4	EA	x	x	
2	209A	Book Closet next to Classroom 209	Fiberglass Pipe Insulation	x	Non Suspect ACM	35	LF	x	x	
2	209A	Book Closet next to Classroom 209	Concrete Ceiling	x	Non Suspect ACM	660	SF	x	x	
2	209A	Book Closet next to Classroom 209	Concrete Block Wall	x	Non Suspect ACM	1248	SF	x	x	
2	209A	Book Closet next to Classroom 209	Floor Tile VAT 9" x 9"	NF1	Confirmed	660	SF	ND	NRN	
2	209	Classroom 209	Ceiling Tile 2' x 2'	x	NAD	672	SF	x	x	
2	209	Classroom 209	Concrete Block Wall	x	Non Suspect ACM	1040	SF	x	x	
2	209	Classroom 209	Floor Tile VAT 9" x 9"	NF1	Confirmed	632	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	209	Classroom 209	Floor Tile VAT 12" x 12"	NF1	Assumed	40	SF	ND	NRN	
2	209	Classroom 209	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	209C	Classroom 209 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	209C	Classroom 209 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	209C	Classroom 209 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	209B	Custodial Closet next to Classroom 209	Fiberglass Pipe Insulation	x	Non Suspect ACM	12	LF	x	x	
2	209B	Custodial Closet next to Classroom 209	Concrete Ceiling	x	Non Suspect ACM	72	SF	x	x	
2	209B	Custodial Closet next to Classroom 209	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
2	209B	Custodial Closet next to Classroom 209	Cement Floor	x	Non Suspect ACM	72	SF	x	x	
2	210	Classroom 210	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
2	210	Classroom 210	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
2	210	Classroom 210	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
2	210	Classroom 210	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	210	Classroom 210	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	210	Classroom 210	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	210A	Classroom 210 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	210A	Classroom 210 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	210A	Classroom 210 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	211	Classroom 211	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
2	211	Classroom 211	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
2	211	Classroom 211	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
2	211	Classroom 211	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
2	211	Classroom 211	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	211	Classroom 211	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	211A	Classroom 211 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	211A	Classroom 211 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	211A	Classroom 211 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	H28	Hallway near Classroom 211 to Stairwell	Ceiling Tile 2' x 2'	x	NAD	200	SF	x	x	
2	H28	Hallway near Classroom 211 to Stairwell	Concrete Block Wall	x	Non Suspect ACM	500	SF	x	x	
2	H28	Hallway near Classroom 211 to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	200	SF	ND	NRN	
2	H28	Hallway near Classroom 211 to Stairwell	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
2	S24	Stairwell near Classroom 211	Plaster Ceiling	x	NAD	230	SF	x	x	
2	S24	Stairwell near Classroom 211	Concrete Block Wall	x	Non Suspect ACM	792	SF	x	x	
2	S24	Stairwell near Classroom 211	Floor Tile VAT 12" x 12"	NF1	Assumed	90	SF	ND	NRN	
2	S24	Stairwell near Classroom 211	Cement Floor	x	Non Suspect ACM	140	SF	x	x	
2	H26	Hallway from Classrooms 206 to 211	Ceiling Tile 2' x 2'	x	NAD	2080	SF	x	x	
2	H26	Hallway from Classrooms 206 to 211	Concrete Block Wall	x	Non Suspect ACM	4360	SF	x	x	
2	H26	Hallway from Classrooms 206 to 211	Floor Tile VAT 9" x 9"	NF1	Confirmed	2080	SF	ND	NRN	
2	212	Classroom 212	Ceiling Tile 2' x 2'	x	NAD	228	SF	x	x	
2	212	Classroom 212	Concrete Ceiling	x	Non Suspect ACM	582	SF	x	x	
2	212	Classroom 212	Concrete Block Wall	x	Non Suspect ACM	300	SF	x	x	
2	212	Classroom 212	Sheetrock Wall	x	Non Suspect ACM	600	SF	x	x	
2	212	Classroom 212	Floor Tile VAT 12" x 12"	NF1	Assumed	810	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	213	Classroom 213	Ceiling Tile 2' x 2'	x	NAD	386	SF	x	x	
2	213	Classroom 213	Concrete Ceiling	x	Non Suspect ACM	532	SF	x	x	
2	213	Classroom 213	Concrete Block Wall	x	Non Suspect ACM	633	SF	x	x	
2	213	Classroom 213	Partition Room Dividers	x	Non Suspect ACM	317	SF	x	x	
2	213	Classroom 213	Sheetrock Wall	x	Non Suspect ACM	380	SF	x	x	
2	213	Classroom 213	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	

2	213	Classroom 213	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	213A	Classroom 213 Closet	Fiberglass Pipe Insulation	x	Non Suspect ACM	4	LF	x	x	
2	213A	Classroom 213 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	213A	Classroom 213 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	213A	Classroom 213 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	215	Classroom 215	Ceiling Tile 2' x 2'	x	NAD	488	SF	x	x	
2	215	Classroom 215	Concrete Ceiling	x	Non Suspect ACM	430	SF	x	x	
2	215	Classroom 215	Concrete Block Wall	x	Non Suspect ACM	633	SF	x	x	
2	215	Classroom 215	Partition Room Dividers	x	Non Suspect ACM	317	SF	x	x	
2	215	Classroom 215	Sheetrock Wall	x	Non Suspect ACM	340	SF	x	x	
2	215	Classroom 215	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
2	215	Classroom 215	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	215A	Classroom 215 Closet	Fiberglass Pipe Insulation	x	Non Suspect ACM	4	LF	x	x	
2	215A	Classroom 215 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	215A	Classroom 215 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	215A	Classroom 215 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
2	H26B	Hallway to Classrooms 212, 213, and 215	Ceiling Tile 2' x 2'	x	NAD	88	SF	x	x	
2	H26B	Hallway to Classrooms 212, 213, and 215	Concrete Ceiling	x	Non Suspect ACM	142	SF	x	x	
2	H26B	Hallway to Classrooms 212, 213, and 215	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
2	H26B	Hallway to Classrooms 212, 213, and 215	Sheetrock Wall	x	Non Suspect ACM	564	SF	x	x	
2	H26B	Hallway to Classrooms 212, 213, and 215	Floor Tile VAT 12" x 12"	NF1	Assumed	230	SF	ND	NRN	
2	H26CL	Closet in Hallway to Classrooms 212, 213, and 215	Concrete Ceiling	x	Non Suspect ACM	12	SF	x	x	Added Space. No Access; Not Inspected.
2	H26CL	Closet in Hallway to Classrooms 212, 213, and 215	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
2	H26CL	Closet in Hallway to Classrooms 212, 213, and 215	Floor Tile VAT 9" x 9"	NF1	Confirmed	12	SF	ND	NRN	
2	214	Classroom 214	Ceiling Tile 2' x 2'	x	NAD	379	SF	x	x	
2	214	Classroom 214	Concrete Ceiling	x	Non Suspect ACM	471	SF	x	x	
2	214	Classroom 214	Concrete Block Wall	x	Non Suspect ACM	590	SF	x	x	
2	214	Classroom 214	Sheetrock Wall	x	Non Suspect ACM	590	SF	x	x	
2	214	Classroom 214	Floor Tile VAT 12" x 12"	NF1	Assumed	850	SF	ND	REM	30 SF at CUV - Non-Friable Removal
2	214A	Classroom 214 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
2	214A	Classroom 214 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
2	214A	Classroom 214 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	S32	Stairwell near Student Restrooms and Elevator	Ceiling Tile 2' x 2'	x	NAD	300	SF	x	x	
3	S32	Stairwell near Student Restrooms and Elevator	Concrete Block Wall	x	Non Suspect ACM	888	SF	x	x	
3	S32	Stairwell near Student Restrooms and Elevator	Floor Tile VAT 9" x 9"	NF1	Confirmed	108	SF	ND	NRN	
3	S32	Stairwell near Student Restrooms and Elevator	Cement Floor	x	Non Suspect ACM	192	SF	x	x	
3	H41	Hallway near Student Restrooms to Stairwell	Ceiling Tile 2' x 2'	x	NAD	54	SF	x	x	
3	H41	Hallway near Student Restrooms to Stairwell	Concrete Block Wall	x	Non Suspect ACM	240	SF	x	x	
3	H41	Hallway near Student Restrooms to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	54	SF	ND	NRN	
3	H41	Hallway near Student Restrooms to Stairwell	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
3	300E	Girl's Restroom	Plaster Ceiling	x	NAD	180	SF	x	x	
3	300E	Girl's Restroom	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
3	300E	Girl's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	180	SF	x	x	
3	300D	Boy's Restroom	Plaster Ceiling	x	NAD	180	SF	x	x	
3	300D	Boy's Restroom	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
3	300D	Boy's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	180	SF	x	x	
3	300D	Boy's Restroom	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
3	300C	Staff and Handicap Restroom	Plaster Ceiling	x	NAD	35	SF	x	x	
3	300C	Staff and Handicap Restroom	Concrete Block Wall	x	Non Suspect ACM	216	SF	x	x	
3	300C	Staff and Handicap Restroom	Ceramic Tile Floors	x	Non Suspect ACM	35	SF	x	x	
3	300C	Staff and Handicap Restroom	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
3	H38	Hallway from Staff/Handicap Restroom to	Ceiling Tile 2' x 2'	x	NAD	392	SF	x	x	
3	H38	Hallway from Staff/Handicap Restroom to	Concrete Block Wall	x	Non Suspect ACM	448	SF	x	x	
3	H38	Hallway from Staff/Handicap Restroom to	Floor Tile VAT 9" x 9"	NF1	Confirmed	392	SF	ND	NRN	
3	300B	Staff Restroom across from Classroom 300	Plaster Ceiling	x	NAD	55	SF	x	x	
3	300B	Staff Restroom across from Classroom 300	Concrete Block Wall	x	Non Suspect ACM	256	SF	x	x	
3	300B	Staff Restroom across from Classroom 300	Ceramic Tile Floors	x	Non Suspect ACM	55	SF	x	x	
3	306	Classroom 306	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
3	306	Classroom 306	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
3	306	Classroom 306	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
3	306	Classroom 306	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
3	306	Classroom 306	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	306	Classroom 306	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	306A	Classroom 306 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	306A	Classroom 306 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	306A	Classroom 306 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	305	Classroom 305	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
3	305	Classroom 305	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	

3	305	Classroom 305	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
3	305	Classroom 305	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
3	305	Classroom 305	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	305	Classroom 305	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	305A	Classroom 305 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	305A	Classroom 305 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	305A	Classroom 305 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	H40	Hallway near Classroom 305 to Stairwell	Ceiling Tile 2' x 2'	x	NAD	200	SF	x	x	
3	H40	Hallway near Classroom 305 to Stairwell	Concrete Block Wall	x	Non Suspect ACM	540	SF	x	x	
3	H40	Hallway near Classroom 305 to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	200	SF	ND	NRN	
3	H40	Hallway near Classroom 305 to Stairwell	Convector Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
3	S31	Stairwell near Classroom 305	Ceiling Tile 2' x 2'	x	NAD	207	SF	x	x	
3	S31	Stairwell near Classroom 305	Concrete Block Wall	x	Non Suspect ACM	512	SF	x	x	
3	S31	Stairwell near Classroom 305	Floor Tile VAT 9" x 9"	NF1	Confirmed	72	SF	ND	NRN	
3	S31	Stairwell near Classroom 305	Cement Floor	x	Non Suspect ACM	135	SF	x	x	
3	304	Classroom 304	Ceiling Tile 2' x 2'	x	NAD	324	SF	x	x	
3	304	Classroom 304	Concrete Ceiling	x	Non Suspect ACM	516	SF	x	x	
3	304	Classroom 304	Concrete Block Wall	x	Non Suspect ACM	580	SF	x	x	
3	304	Classroom 304	Sheetrock Wall	x	Non Suspect ACM	580	SF	x	x	
3	304	Classroom 304	Floor Tile VAT 12" x 12"	NF1	Assumed	840	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	304A	Classroom 304 Closet	Ceiling Tile 2' x 2'	x	NAD	8	SF	x	x	
3	304A	Classroom 304 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	304A	Classroom 304 Closet	Floor Tile VAT 12" x 12"	NF1	Assumed	8	SF	ND	NRN	
3	H39A	Hallway to Classrooms 301, 303, and 304	Ceiling Tile 2' x 2'	x	NAD	156	SF	x	x	
3	H39A	Hallway to Classrooms 301, 303, and 304	Concrete Ceiling	x	Non Suspect ACM	36	SF	x	x	
3	H39A	Hallway to Classrooms 301, 303, and 304	Sheetrock Wall	x	Non Suspect ACM	518	SF	x	x	
3	H39A	Hallway to Classrooms 301, 303, and 304	Floor Tile VAT 12" x 12"	NF1	Assumed	192	SF	ND	NRN	
3	H39AB	Closet in Hallway to Classrooms 301, 303, and 304	not accessible	x	x	x	x	x	x	Added Space. No Access; Not Inspected
3	303	Classroom 303	Ceiling Tile 2' x 2'	x	NAD	404	SF	x	x	
3	303	Classroom 303	Concrete Ceiling	x	Non Suspect ACM	514	SF	x	x	
3	303	Classroom 303	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
3	303	Classroom 303	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
3	303	Classroom 303	Sheetrock Wall	x	Non Suspect ACM	380	SF	x	x	
3	303	Classroom 303	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	303	Classroom 303	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	303A	Classroom 303 Closet	Concrete Ceiling	x	Non Suspect ACM	8	SF	x	x	
3	303A	Classroom 303 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	303A	Classroom 303 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	8	SF	ND	NRN	
3	301	Classroom 301	Ceiling Tile 2' x 2'	x	NAD	522	SF	x	x	
3	301	Classroom 301	Concrete Ceiling	x	Non Suspect ACM	396	SF	x	x	
3	301	Classroom 301	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
3	301	Classroom 301	Partition Room Dividers	x	Non Suspect ACM	300	SF	x	x	
3	301	Classroom 301	Sheetrock Wall	x	Non Suspect ACM	340	SF	x	x	
3	301	Classroom 301	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	301	Classroom 301	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	301A	Classroom 301 Closet	Concrete Ceiling	x	Non Suspect ACM	6	SF	x	x	
3	301A	Classroom 301 Closet	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
3	301A	Classroom 301 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	6	SF	ND	NRN	
3	302	Classroom 302	Ceiling Tile 2' x 2'	x	NAD	420	SF	x	x	
3	302	Classroom 302	Concrete Ceiling	x	Non Suspect ACM	498	SF	x	x	
3	302	Classroom 302	Concrete Block Wall	x	Non Suspect ACM	610	SF	x	x	
3	302	Classroom 302	Sheetrock Wall	x	Non Suspect ACM	560	SF	x	x	
3	302	Classroom 302	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	302A	Classroom 302 Closet	Concrete Ceiling	x	Non Suspect ACM	6	SF	x	x	
3	302A	Classroom 302 Closet	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
3	302A	Classroom 302 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	6	SF	ND	NRN	
3	300	Classroom 300	Ceiling Tile 2' x 2'	x	NAD	1680	SF	x	x	
3	300	Classroom 300	Concrete Block Wall	x	Non Suspect ACM	1720	SF	x	x	
3	300	Classroom 300	Floor Tile VAT 18" x 18"	NF1	Assumed	1680	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	300A	Classroom 300 Storage Area	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
3	300A	Classroom 300 Storage Area	Concrete Block Wall	x	Non Suspect ACM	396	SF	x	x	
3	300A	Classroom 300 Storage Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
3	307	ESOL Office	Ceiling Tile 2' x 2'	x	NAD	483	SF	x	x	
3	307	ESOL Office	Concrete Block Wall	x	Non Suspect ACM	880	SF	x	x	
3	307	ESOL Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	483	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	307A	Storage Area next to the ESOL Office	Concrete Ceiling	x	Non Suspect ACM	525	SF	x	x	
3	307A	Storage Area next to the ESOL Office	Concrete Block Wall	x	Non Suspect ACM	1104	SF	x	x	
3	307A	Storage Area next to the ESOL Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	525	SF	ND	NRN	

3	308A	Storage Area next to Counselor's Office	Concrete Ceiling	x	Non Suspect ACM	525	SF	x	x	
3	308A	Storage Area next to Counselor's Office	Concrete Block Wall	x	Non Suspect ACM	1104	SF	x	x	
3	308A	Storage Area next to Counselor's Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	525	SF	ND	NRN	
3	308	Counselor's Office 308	Ceiling Tile 2' x 2'	x	NAD	483	SF	x	x	
3	308	Counselor's Office 308	Concrete Block Wall	x	Non Suspect ACM	880	SF	x	x	
3	308	Counselor's Office 308	Floor Tile VAT 9" x 9"	NF1	Confirmed	443	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	308	Counselor's Office 308	Floor Tile VAT 12" x 12"	NF1	Assumed	40	SF	ND	NRN	
3	309	Classroom 309	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
3	309	Classroom 309	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
3	309	Classroom 309	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
3	309	Classroom 309	Sheetrock Wall	x	Non Suspect ACM	250	SF	x	x	
3	309	Classroom 309	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	309A	Classroom 309 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	309A	Classroom 309 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	309A	Classroom 309 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	310	Classroom 310	Ceiling Tile 2' x 2'	x	NAD	438	SF	x	x	
3	310	Classroom 310	Concrete Ceiling	x	Non Suspect ACM	552	SF	x	x	
3	310	Classroom 310	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
3	310	Classroom 310	Sheetrock Wall	x	Non Suspect ACM	250	SF	x	x	
3	310	Classroom 310	Floor Tile VAT 12" x 12"	NF1	Assumed	990	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	310A	Classroom 310 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	310A	Classroom 310 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	310A	Classroom 310 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	H42	Hallway near Classroom 310 to Stairwell	Ceiling Tile 2' x 2'	x	NAD	200	SF	x	x	
3	H42	Hallway near Classroom 310 to Stairwell	Concrete Block Wall	x	Non Suspect ACM	540	SF	x	x	
3	H42	Hallway near Classroom 310 to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	200	SF	ND	NRN	
3	H42	Hallway near Classroom 310 to Stairwell	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
3	S34	Stairwell near Classroom 310	Ceiling Tile 2' x 2'	x	NAD	230	SF	x	x	
3	S34	Stairwell near Classroom 310	Concrete Block Wall	x	Non Suspect ACM	792	SF	x	x	
3	S34	Stairwell near Classroom 310	Floor Tile VAT 12" x 12"	NF1	Assumed	80	SF	ND	NRN	
3	S34	Stairwell near Classroom 310	Cement Floor	x	Non Suspect ACM	150	SF	x	x	
3	312	Classroom 312	Ceiling Tile 2' x 2'	x	NAD	228	SF	x	x	
3	312	Classroom 312	Concrete Ceiling	x	Non Suspect ACM	582	SF	x	x	
3	312	Classroom 312	Concrete Block Wall	x	Non Suspect ACM	300	SF	x	x	
3	312	Classroom 312	Sheetrock Wall	x	Non Suspect ACM	600	SF	x	x	
3	312	Classroom 312	Floor Tile VAT 12" x 12"	NF1	Assumed	810	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	311	Classroom 311	Ceiling Tile 2' x 2'	x	NAD	386	SF	x	x	
3	311	Classroom 311	Concrete Ceiling	x	Non Suspect ACM	532	SF	x	x	
3	311	Classroom 311	Concrete Block Wall	x	Non Suspect ACM	633	SF	x	x	
3	311	Classroom 311	Partition Room Dividers	x	Non Suspect ACM	317	SF	x	x	
3	311	Classroom 311	Sheetrock Wall	x	Non Suspect ACM	380	SF	x	x	
3	311	Classroom 311	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	311	Classroom 311	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	311A	Classroom 311 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	311A	Classroom 311 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	311A	Classroom 311 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	313	Classroom 313	Ceiling Tile 2' x 2'	x	NAD	488	SF	x	x	
3	313	Classroom 313	Concrete Ceiling	x	Non Suspect ACM	430	SF	x	x	
3	313	Classroom 313	Concrete Block Wall	x	Non Suspect ACM	633	SF	x	x	
3	313	Classroom 313	Partition Room Dividers	x	Non Suspect ACM	317	SF	x	x	
3	313	Classroom 313	Sheetrock Wall	x	Non Suspect ACM	340	SF	x	x	
3	313	Classroom 313	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
3	313	Classroom 313	Floor Tile VAT 12" x 12"	NF1	Assumed	918	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	313A	Classroom 313 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	313A	Classroom 313 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	313A	Classroom 313 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	H39B	Hallway to Classrooms 311, 312, and 313	Ceiling Tile 2' x 2'	x	NAD	88	SF	x	x	
3	H39B	Hallway to Classrooms 311, 312, and 313	Concrete Ceiling	x	Non Suspect ACM	142	SF	x	x	
3	H39B	Hallway to Classrooms 311, 312, and 313	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
3	H39B	Hallway to Classrooms 311, 312, and 313	Sheetrock Wall	x	Non Suspect ACM	564	SF	x	x	
3	H39B	Hallway to Classrooms 311, 312, and 313	Floor Tile VAT 12" x 12"	NF1	Assumed	230	SF	ND	NRN	
3	H39BB	Closet in Hallway to Classrooms 311, 312, and 313	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	H39BB	Closet in Hallway to Classrooms 311, 312, and 313	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	H39BB	Closet in Hallway to Classrooms 311, 312, and 313	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	314	Classroom 314	Ceiling Tile 2' x 2'	x	NAD	379	SF	x	x	
3	314	Classroom 314	Concrete Ceiling	x	Non Suspect ACM	471	SF	x	x	
3	314	Classroom 314	Concrete Block Wall	x	Non Suspect ACM	590	SF	x	x	
3	314	Classroom 314	Sheetrock Wall	x	Non Suspect ACM	590	SF	x	x	

3	314	Classroom 314	Floor Tile VAT 12" x 12"	NF1	Assumed	850	SF	ND	REM	30 SF at CUV - Non-Friable Removal
3	314A	Classroom 314 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
3	314A	Classroom 314 Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
3	314A	Classroom 314 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
3	315	Classroom 315 Computer Lab	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
3	315	Classroom 315 Computer Lab	Fiberglass Pipe Insulation	x	Non Suspect ACM	2	LF	x	x	
3	315	Classroom 315 Computer Lab	Ceiling Tile 2' x 2'	x	NAD	1782	SF	x	x	
3	315	Classroom 315 Computer Lab	Sink Undercoat Mastic	NF2	Assumed	6	SF	ND	NRN	
3	315	Classroom 315 Computer Lab	Concrete Block Wall	x	Non Suspect ACM	1740	SF	x	x	
3	315	Classroom 315 Computer Lab	Sheetrock Wall	x	Non Suspect ACM	30	SF	x	x	
3	315	Classroom 315 Computer Lab	Floor Tile VAT 9" x 9"	NF1	Confirmed	1782	SF	ND	REM	60 SF Total - 30 SF at each CUV - Non-Friable Removal
3	315A	Classroom 315 Storage Room	not accessible	x	x	x	x	x	x	No Access; Pad Locked.
3	315B	Custodial Closet next to Classroom 315	Concrete Ceiling	x	Non Suspect ACM	50	SF	x	x	
3	315B	Custodial Closet next to Classroom 315	Concrete Block Wall	x	Non Suspect ACM	360	SF	x	x	
3	315B	Custodial Closet next to Classroom 315	Cement Floor	x	Non Suspect ACM	50	SF	x	x	
3	316	Classroom 316	Ceiling Tile 2' x 2'	x	NAD	1782	SF	x	x	
3	316	Classroom 316	Concrete Block Wall	x	Non Suspect ACM	1740	SF	x	x	
3	316	Classroom 316	Floor Tile VAT 12" x 12"	NF1	Assumed	1782	SF	ND	REM	60 SF Total - 30 SF at each CUV - Non-Friable Removal
3	316A	Classroom 316 Storage Room near Entrance	Ceiling Tile 2' x 2'	x	NAD	160	SF	x	x	
3	316A	Classroom 316 Storage Room near Entrance	Concrete Block Wall	x	Non Suspect ACM	468	SF	x	x	
3	316A	Classroom 316 Storage Room near Entrance	Floor Tile VAT 9" x 9"	NF1	Confirmed	160	SF	ND	NRN	
3	316B	Classroom 316 Storage Room	Ceiling Tile 2' x 2'	x	NAD	100	SF	x	x	
3	316B	Classroom 316 Storage Room	Concrete Block Wall	x	Non Suspect ACM	360	SF	x	x	
3	316B	Classroom 316 Storage Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	100	SF	ND	NRN	
3	H39	Hallway from Classrooms 305 to 310	Ceiling Tile 2' x 2'	x	NAD	2080	SF	x	x	
3	H39	Hallway from Classrooms 305 to 310	Concrete Block Wall	x	Non Suspect ACM	4360	SF	x	x	
3	H39	Hallway from Classrooms 305 to 310	Floor Tile VAT 9" x 9"	NF1	Confirmed	2044	SF	ND	NRN	
3	H39	Hallway from Classrooms 305 to 310	Floor Tile VAT 12" x 12"	NF1	Assumed	36	SF	ND	NRN	
3	H39	Hallway from Classrooms 305 to 310	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
AT	A	Attic	None Present	x	x	x	x	x	x	None Present
BS	8	Boiler Room	Pipe Fitting Insulation	x	NAD	75	EA	x	x	
BS	8	Boiler Room	Fiberglass Pipe Insulation	x	Non Suspect ACM	750	LF	x	x	
BS	8	Boiler Room	Vibration Damper Cloth	x	NAD	x	x	x	x	
BS	8	Boiler Room	Concrete Ceiling	x	Non Suspect ACM	2450	SF	x	x	
BS	8	Boiler Room	Concrete Block Wall	x	Non Suspect ACM	2940	SF	x	x	
BS	8	Boiler Room	Cement Floor	x	Non Suspect ACM	2450	SF	x	x	
BS	8A	Electrical Room in Boiler Room	Concrete Ceiling	x	Non Suspect ACM	450	SF	x	x	
BS	8A	Electrical Room in Boiler Room	Concrete Block Wall	x	Non Suspect ACM	1260	SF	x	x	
BS	8A	Electrical Room in Boiler Room	Cement Floor	x	Non Suspect ACM	450	SF	x	x	
BS	7D	Building Engineer's Office	Ceiling Tile 2' x 2'	x	NAD	70	SF	x	x	
BS	7D	Building Engineer's Office	Concrete Block Wall	x	Non Suspect ACM	306	SF	x	x	
BS	7D	Building Engineer's Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	70	SF	ND	NRN	
BS	7F	Building Engineer's Office Restroom	Plaster Ceiling	x	NAD	45	SF	x	x	
BS	7F	Building Engineer's Office Restroom	Concrete Block Wall	x	Non Suspect ACM	252	SF	x	x	
BS	7F	Building Engineer's Office Restroom	Ceramic Tile Floors	x	Non Suspect ACM	45	SF	x	x	
BS	7C	Men's Restroom next to Building Engineer's	Plaster Ceiling	x	NAD	144	SF	x	x	
BS	7C	Men's Restroom next to Building Engineer's	Concrete Block Wall	x	Non Suspect ACM	450	SF	x	x	
BS	7C	Men's Restroom next to Building Engineer's	Ceramic Tile Floors	x	Non Suspect ACM	144	SF	x	x	
BS	7C	Men's Restroom next to Building Engineer's	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
BS	7B	Custodial Closet between Men's and Women's	Pipe Fitting Insulation	x	NAD	12	EA	x	x	
BS	7B	Custodial Closet between Men's and Women's	Fiberglass Pipe Insulation	x	Non Suspect ACM	35	LF	x	x	
BS	7B	Custodial Closet between Men's and Women's	Concrete Ceiling	x	Non Suspect ACM	72	SF	x	x	
BS	7B	Custodial Closet between Men's and Women's	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
BS	7B	Custodial Closet between Men's and Women's	Cement Floor	x	Non Suspect ACM	72	SF	x	x	
BS	7A	Women's Restroom near Building Engineer's	Plaster Ceiling	x	NAD	176	SF	x	x	
BS	7A	Women's Restroom near Building Engineer's	Concrete Block Wall	x	Non Suspect ACM	486	SF	x	x	
BS	7A	Women's Restroom near Building Engineer's	Ceramic Tile Floors	x	Non Suspect ACM	176	SF	x	x	
BS	7A	Women's Restroom near Building Engineer's	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
BS	2D	Home and School Office	Ceiling Tile 2' x 2'	x	NAD	128	SF	x	x	
BS	2D	Home and School Office	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
BS	2D	Home and School Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	128	SF	ND	NRN	
BS	H09	Hallway from Home and School Office to	Ceiling Tile 2' x 2'	x	NAD	140	SF	x	x	
BS	H09	Hallway from Home and School Office to	Concrete Block Wall	x	Non Suspect ACM	324	SF	x	x	
BS	H09	Hallway from Home and School Office to	Brick Wall	x	Non Suspect ACM	378	SF	x	x	
BS	H09	Hallway from Home and School Office to	Floor Tile VAT 9" x 9"	NF1	Confirmed	64	SF	ND	NRN	
BS	H09	Hallway from Home and School Office to	Ceramic Tile Floors	x	Non Suspect ACM	76	SF	x	x	
BS	2E	Storage Room across from Home and School	Ceiling Tile 2' x 2'	x	NAD	48	SF	x	x	
BS	2E	Storage Room across from Home and School	Concrete Block Wall	x	Non Suspect ACM	252	SF	x	x	



BS	2E	Storage Room across from Home and School	Cement Floor	x	Non Suspect ACM	48	SF	x	x	
BS	1E	Storage Room near Music Room Office	Pipe Fitting Insulation	x	NAD	40	EA	x	x	
BS	1E	Storage Room near Music Room Office	Fiberglass Pipe Insulation	x	Non Suspect ACM	170	LF	x	x	
BS	1E	Storage Room near Music Room Office	Concrete Ceiling	x	Non Suspect ACM	600	SF	x	x	
BS	1E	Storage Room near Music Room Office	Concrete Block Wall	x	Non Suspect ACM	900	SF	x	x	
BS	1E	Storage Room near Music Room Office	Cement Floor	x	Non Suspect ACM	600	SF	x	x	
BS	1A	Music Area Lobby	Ceiling Tile 2' x 2'	x	NAD	392	SF	x	x	
BS	1A	Music Area Lobby	Plaster Ceiling	x	NAD	72	SF	x	x	
BS	1A	Music Area Lobby	Concrete Block Wall	x	Non Suspect ACM	960	SF	x	x	
BS	1A	Music Area Lobby	Floor Tile VAT 9" x 9"	NF1	Confirmed	436	SF	ND	NRN	
BS	1A	Music Area Lobby	Floor Tile VAT 12" x 12"	NF1	Assumed	28	SF	ND	NRN	
BS	1B	Music Room Office	Ceiling Tile 2' x 2'	x	NAD	180	SF	x	x	
BS	1B	Music Room Office	Concrete Block Wall	x	Non Suspect ACM	324	SF	x	x	
BS	1B	Music Room Office	Concrete Wall	x	Non Suspect ACM	108	SF	x	x	
BS	1B	Music Room Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	180	SF	ND	NRN	
BS	1C	Music Instrument Storage Room	Ceiling Tile 2' x 2'	x	NAD	64	SF	x	x	
BS	1C	Music Instrument Storage Room	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
BS	1C	Music Instrument Storage Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	64	SF	ND	NRN	
BS	1D	Storage Room next to Art Room	Pipe Fitting Insulation	x	NAD	7	EA	x	x	
BS	1D	Storage Room next to Art Room	Fiberglass Pipe Insulation	x	Non Suspect ACM	35	LF	x	x	
BS	1D	Storage Room next to Art Room	Concrete Ceiling	x	Non Suspect ACM	64	SF	x	x	
BS	1D	Storage Room next to Art Room	Concrete Block Wall	x	Non Suspect ACM	448	SF	x	x	
BS	1D	Storage Room next to Art Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	64	SF	ND	NRN	
BS	1	Art Room	Ceiling Tile 2' x 2'	x	NAD	1014	SF	x	x	
BS	1	Art Room	Concrete Block Wall	x	Non Suspect ACM	585	SF	x	x	
BS	1	Art Room	Concrete Wall	x	Non Suspect ACM	585	SF	x	x	
BS	1	Art Room	Floor Tile VAT 12" x 12"	NF1	Assumed	1014	SF	ND	NRN	
BS	1	Art Room	Sink Undercoat Mastic	NF2	Assumed	16	SF	ND	NRN	
BS	1F	Art Room Closet	Concrete Ceiling	x	Non Suspect ACM	12	SF	x	x	
BS	1F	Art Room Closet	Concrete Block Wall	x	Non Suspect ACM	84	SF	x	x	
BS	1F	Art Room Closet	Concrete Wall	x	Non Suspect ACM	42	SF	x	x	
BS	1F	Art Room Closet	Floor Tile VAT 12" x 12"	NF1	Assumed	12	SF	ND	NRN	
BS	H08	Hallway from Art Room to Music Room Office	Ceiling Tile 2' x 2'	x	NAD	84	SF	x	x	
BS	H08	Hallway from Art Room to Music Room Office	Concrete Block Wall	x	Non Suspect ACM	224	SF	x	x	
BS	H08	Hallway from Art Room to Music Room Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	84	SF	ND	NRN	
BS	S05	Lower Level Stairwell near Art Room and Stage	Ceiling Tile 2' x 2'	x	NAD	162	SF	x	x	
BS	S05	Lower Level Stairwell near Art Room and Stage	Brick Wall	x	Non Suspect ACM	882	SF	x	x	
BS	S05	Lower Level Stairwell near Art Room and Stage	Ceramic Tile Floors	x	Non Suspect ACM	594	SF	x	x	
BS	H01	Hallway near Auditorium to Cafeteria and	Ceiling Tile 2' x 2'	x	NAD	884	SF	x	x	
BS	H01	Hallway near Auditorium to Cafeteria and	Brick Wall	x	Non Suspect ACM	1080	SF	x	x	
BS	H01	Hallway near Auditorium to Cafeteria and	Ceramic Tile Floors	x	Non Suspect ACM	884	SF	x	x	
BS	S1	Stairwell near Cafeteria	Plaster Ceiling	x	NAD	242	SF	x	x	
BS	S1	Stairwell near Cafeteria	Concrete Wall	x	Non Suspect ACM	726	SF	x	x	
BS	S1	Stairwell near Cafeteria	Floor Tile VAT 12" x 12"	NF1	Assumed	242	SF	ND	NRN	
BS	H07	Hallway between Cafeteria and Auditorium to	Ceiling Tile 2' x 2'	x	NAD	136	SF	x	x	
BS	H07	Hallway between Cafeteria and Auditorium to	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
BS	H07	Hallway between Cafeteria and Auditorium to	Concrete Wall	x	Non Suspect ACM	300	SF	x	x	
BS	H07	Hallway between Cafeteria and Auditorium to	Floor Tile VAT 9" x 9"	NF1	Confirmed	136	SF	ND	NRN	
BS	H07	Hallway between Cafeteria and Auditorium to	Convactor Insulation	FRI	Assumed	8	SF	ND	NRN	* Coordination required if material will be impacted
BS	3	Cafeteria	Concrete Ceiling	x	Non Suspect ACM	2042	SF	x	x	
BS	3	Cafeteria	Ceiling Tile 2' x 2'	x	NAD	690	SF	x	x	
BS	3	Cafeteria	Sheetrock Ceiling	x	NAD	780	SF	x	x	
BS	3	Cafeteria	Concrete Wall	x	Non Suspect ACM	1680	SF	x	x	
BS	3	Cafeteria	Vinyl Sheeting Floor	x	Non Suspect ACM	2432	SF	x	x	
BS	2C	Auditorium	Plaster Ceiling	x	NAD	1400	SF	x	x	
BS	2C	Auditorium	Concrete Ceiling	x	Non Suspect ACM	800	SF	x	x	
BS	2C	Auditorium	Wood Panel Walls	x	Non Suspect ACM	1134	SF	x	x	
BS	2C	Auditorium	Carpet	x	Non Suspect ACM	829	SF	x	x	
BS	2C	Auditorium	Cement Floor	x	Non Suspect ACM	1250	SF	x	x	
BS	2 STAGE	Auditorium Stage	Concrete Ceiling	x	Non Suspect ACM	1071	SF	x	x	
BS	2 STAGE	Auditorium Stage	Concrete Wall	x	Non Suspect ACM	882	SF	x	x	
BS	2 STAGE	Auditorium Stage	Wood Floor	x	Non Suspect ACM	1071	SF	x	x	
BS	2 STAGE	Auditorium Stage	Stage Light Wiring Insulation	FRI	Confirmed	1230	LF	ND	NRN	
BS	2A	Stage Right Area	Concrete Ceiling	x	Non Suspect ACM	525	SF	x	x	
BS	2A	Stage Right Area	Concrete Block Wall	x	Non Suspect ACM	550	SF	x	x	
BS	2A	Stage Right Area	Concrete Wall	x	Non Suspect ACM	165	SF	x	x	
BS	2A	Stage Right Area	Sheetrock Wall	x	Non Suspect ACM	432	SF	x	x	
BS	2A	Stage Right Area	Wood Floor	x	Non Suspect ACM	525	SF	x	x	

BS	2B	Stage Left Area	Pipe Fitting Insulation	x	NAD	3	EA	x	x	
BS	2B	Stage Left Area	Fiberglass Pipe Insulation	x	Non Suspect ACM	35	LF	x	x	
BS	2B	Stage Left Area	Concrete Ceiling	x	Non Suspect ACM	525	SF	x	x	
BS	2B	Stage Left Area	Concrete Block Wall	x	Non Suspect ACM	550	SF	x	x	
BS	2B	Stage Left Area	Concrete Wall	x	Non Suspect ACM	165	SF	x	x	
BS	2B	Stage Left Area	Sheetrock Wall	x	Non Suspect ACM	196	SF	x	x	
BS	2B	Stage Left Area	Wood Floor	x	Non Suspect ACM	525	SF	x	x	
BS	4	Kitchen	Plaster Ceiling	x	NAD	720	SF	x	x	
BS	4	Kitchen	Concrete Block Wall	x	Non Suspect ACM	1008	SF	x	x	
BS	4	Kitchen	Ceramic Tile Floors	x	Non Suspect ACM	720	SF	x	x	
BS	4A	Kitchen Wash Area with Sinks	Plaster Ceiling	x	NAD	160	SF	x	x	
BS	4A	Kitchen Wash Area with Sinks	Concrete Block Wall	x	Non Suspect ACM	504	SF	x	x	
BS	4A	Kitchen Wash Area with Sinks	Ceramic Tile Floors	x	Non Suspect ACM	160	SF	x	x	
BS	4C	Storage Closet in Kitchen	Plaster Ceiling	x	NAD	48	SF	x	x	
BS	4C	Storage Closet in Kitchen	Concrete Block Wall	x	Non Suspect ACM	252	SF	x	x	
BS	4C	Storage Closet in Kitchen	Floor Tile VAT 9" x 9"	NF1	Confirmed	48	SF	ND	NRN	
BS	Elevator	Elevator	Metal Ceiling	x	Non Suspect ACM	20	SF	x	x	
BS	Elevator	Elevator	Metal Walls	x	Non Suspect ACM	144	SF	x	x	
BS	Elevator	Elevator	Floor Tile VAT 12" x 12"	NF1	Assumed	20	SF	ND	NRN	
BS	H03	Hallway from Hallway near Elevator to Stairwell	Ceiling Tile 2' x 2'	x	NAD	48	SF	x	x	
BS	H03	Hallway from Hallway near Elevator to Stairwell	Concrete Block Wall	x	Non Suspect ACM	144	SF	x	x	
BS	H03	Hallway from Hallway near Elevator to Stairwell	Concrete Wall	x	Non Suspect ACM	72	SF	x	x	
BS	H03	Hallway from Hallway near Elevator to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	48	SF	ND	NRN	
BS	H03	Hallway from Hallway near Elevator to Stairwell	Convactor Insulation	FRI	Assumed	6	SF	ND	NRN	* Coordination required if material will be impacted
BS	S03	Stairwell near Elevator and Kitchen	Plaster Ceiling	x	NAD	288	SF	x	x	
BS	S03	Stairwell near Elevator and Kitchen	Concrete Block Wall	x	Non Suspect ACM	162	SF	x	x	
BS	S03	Stairwell near Elevator and Kitchen	Concrete Wall	x	Non Suspect ACM	486	SF	x	x	
BS	S03	Stairwell near Elevator and Kitchen	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
BS	S03	Stairwell near Elevator and Kitchen	Floor Tile VAT 9" x 9"	NF1	Confirmed	54	SF	ND	NRN	
BS	4B	Kitchen Personnel Room	Ceiling Tile 2' x 2'	x	NAD	56	SF	x	x	
BS	4B	Kitchen Personnel Room	Concrete Block Wall	x	Non Suspect ACM	270	SF	x	x	
BS	4B	Kitchen Personnel Room	Ceramic Tile Floors	x	Non Suspect ACM	56	SF	x	x	
BS	4BB	Kitchen Personnel Room Restroom	Plaster Ceiling	x	NAD	30	SF	x	x	
BS	4BB	Kitchen Personnel Room Restroom	Concrete Block Wall	x	Non Suspect ACM	198	SF	x	x	
BS	4BB	Kitchen Personnel Room Restroom	Ceramic Tile Floors	x	Non Suspect ACM	30	SF	x	x	
BS	H04	Hallway from Elevator to Kitchen Personnel	Ceiling Tile 2' x 2'	x	NAD	288	SF	x	x	
BS	H04	Hallway from Elevator to Kitchen Personnel	Concrete Block Wall	x	Non Suspect ACM	486	SF	x	x	
BS	H04	Hallway from Elevator to Kitchen Personnel	Concrete Wall	x	Non Suspect ACM	162	SF	x	x	
BS	H04	Hallway from Elevator to Kitchen Personnel	Floor Tile VAT 9" x 9"	NF1	Confirmed	165	SF	ND	NRN	
BS	H04	Hallway from Elevator to Kitchen Personnel	Floor Tile VAT 9" x 9"	NF1	Confirmed	108	SF	ND	NRN	
BS	H04	Hallway from Elevator to Kitchen Personnel	Floor Tile VAT 12" x 12"	NF1	Assumed	15	SF	ND	NRN	
BS	H05	Hallway along Boy's and Girl's Restrooms	Ceiling Tile 2' x 2'	x	NAD	300	SF	x	x	
BS	H05	Hallway along Boy's and Girl's Restrooms	Concrete Block Wall	x	Non Suspect ACM	540	SF	x	x	
BS	H05	Hallway along Boy's and Girl's Restrooms	Concrete Wall	x	Non Suspect ACM	90	SF	x	x	
BS	H05	Hallway along Boy's and Girl's Restrooms	Floor Tile VAT 9" x 9"	NF1	Confirmed	174	SF	ND	NRN	
BS	H05	Hallway along Boy's and Girl's Restrooms	Floor Tile VAT 9" x 9"	NF1	Confirmed	126	SF	ND	NRN	
BS	4D	Boy's Restroom	Plaster Ceiling	x	NAD	228	SF	x	x	
BS	4D	Boy's Restroom	Concrete Block Wall	x	Non Suspect ACM	496	SF	x	x	
BS	4D	Boy's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	228	SF	x	x	
BS	4D	Boy's Restroom	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
BS	4E	Girl's Restroom	Plaster Ceiling	x	NAD	260	SF	x	x	
BS	4E	Girl's Restroom	Concrete Block Wall	x	Non Suspect ACM	594	SF	x	x	
BS	4E	Girl's Restroom	Ceramic Tile Floors	x	Non Suspect ACM	260	SF	x	x	
BS	4E	Girl's Restroom	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
BS	6A	Storage Room near Girl's Restroom	Fiberglass Ceiling Tile 2' x 4'	x	Non Suspect ACM	320	SF	x	x	
BS	6A	Storage Room near Girl's Restroom	Concrete Block Wall	x	Non Suspect ACM	648	SF	x	x	
BS	6A	Storage Room near Girl's Restroom	Floor Tile VAT 12" x 12"	NF1	Assumed	320	SF	ND	NRN	
BS	6	Music Practice Room 6B	Fiberglass Ceiling Tile 2' x 4'	x	Non Suspect ACM	396	SF	x	x	
BS	6	Music Practice Room 6B	Concrete Block Wall	x	Non Suspect ACM	720	SF	x	x	
BS	6	Music Practice Room 6B	Floor Tile VAT 9" x 9"	NF1	Confirmed	361	SF	ND	NRN	
BS	6	Music Practice Room 6B	Floor Tile VAT 12" x 12"	NF1	Assumed	35	SF	ND	NRN	
BS	4F	Storage Room near Gymnasium	Pipe Fitting Insulation	x	NAD	36	EA	x	x	Pipe Chase in Room
BS	4F	Storage Room near Gymnasium	Fiberglass Pipe Insulation	x	Non Suspect ACM	110	LF	x	x	Pipe Chase in Room
BS	4F	Storage Room near Gymnasium	Concrete Ceiling	x	Non Suspect ACM	512	SF	x	x	Pipe Chase in Room
BS	4F	Storage Room near Gymnasium	Concrete Block Wall	x	Non Suspect ACM	864	SF	x	x	Pipe Chase in Room
BS	4F	Storage Room near Gymnasium	Concrete Wall	x	Non Suspect ACM	288	SF	x	x	Pipe Chase in Room
BS	4F	Storage Room near Gymnasium	Cement Floor	x	Non Suspect ACM	512	SF	x	x	Pipe Chase in Room
BS	PC4F	Pipe Chase in Storage Room near Gymnasium	Pipe Fitting Insulation	x	NAD	2	EA	x	x	

BS	PC4F	Pipe Chase in Storage Room near Gymnasium	Fiberglass Pipe Insulation	x	Non Suspect ACM	30	LF	x	x	
BS	PC4F	Pipe Chase in Storage Room near Gymnasium	Concrete Ceiling	x	Non Suspect ACM	30	SF	x	x	
BS	PC4F	Pipe Chase in Storage Room near Gymnasium	Concrete Block Wall	x	Non Suspect ACM	300	SF	x	x	
BS	PC4F	Pipe Chase in Storage Room near Gymnasium	Cement Floor	x	Non Suspect ACM	30	SF	x	x	
BS	H02	Hallway from Storage Room near Girl's	Ceiling Tile 2' x 2'	x	NAD	720	SF	x	x	
BS	H02	Hallway from Storage Room near Girl's	Concrete Block Wall	x	Non Suspect ACM	1476	SF	x	x	
BS	H02	Hallway from Storage Room near Girl's	Floor Tile VAT 9" x 9"	NF1	Confirmed	720	SF	ND	NRN	
BS	5	Gymnasium	Pipe Fitting Insulation	x	NAD	4	EA	x	x	
BS	5	Gymnasium	Fiberglass Pipe Insulation	x	Non Suspect ACM	20	LF	x	x	
BS	5	Gymnasium	Acoustic Ceiling Tile 1' x 1'	FRI	Assumed	6175	SF	ND	NRN	
BS	5	Gymnasium	Plaster Ceiling	x	NAD	6635	SF	x	x	
BS	5	Gymnasium	Concrete Block Wall	x	Non Suspect ACM	7040	SF	x	x	
BS	5	Gymnasium	Floor Tile VAT 9" x 9"	NF1	Confirmed	5685	SF	ND	NRN	
BS	5	Gymnasium	Floor Tile VAT 12" x 12"	NF1	Assumed	490	SF	ND	NRN	
BS	5	Gymnasium	Soffit	x	NAD		SF	x	x	
BS	5E	Boy's Locker Room in Gym	Plaster Ceiling	x	NAD	576	SF	x	x	
BS	5E	Boy's Locker Room in Gym	Concrete Block Wall	x	Non Suspect ACM	800	SF	x	x	
BS	5E	Boy's Locker Room in Gym	Sheetrock Wall	x	Non Suspect ACM	122	SF	x	x	
BS	5E	Boy's Locker Room in Gym	Cement Floor	x	Non Suspect ACM	576	SF	x	x	
BS	5H	Boy's Locker Room Restroom	Plaster Ceiling	x	NAD	96	SF	x	x	
BS	5H	Boy's Locker Room Restroom	Concrete Block Wall	x	Non Suspect ACM	320	SF	x	x	
BS	5H	Boy's Locker Room Restroom	Ceramic Tile Floors	x	Non Suspect ACM	96	SF	x	x	
BS	5F	Girl's Locker Room in Gym	Plaster Ceiling	x	NAD	576	SF	x	x	
BS	5F	Girl's Locker Room in Gym	Concrete Block Wall	x	Non Suspect ACM	800	SF	x	x	
BS	5F	Girl's Locker Room in Gym	Cement Floor	x	Non Suspect ACM	576	SF	x	x	
BS	5F	Girl's Locker Room in Gym	Convactor Insulation	FRI	Assumed	4	SF	ND	NRN	* Coordination required if material will be impacted
BS	5G	Girl's Locker Room Restroom	Plaster Ceiling	x	NAD	60	SF	x	x	
BS	5G	Girl's Locker Room Restroom	Concrete Block Wall	x	Non Suspect ACM	256	SF	x	x	
BS	5G	Girl's Locker Room Restroom	Ceramic Tile Floors	x	Non Suspect ACM	60	SF	x	x	
BS	5A	Storage Room in the Gym	Fiberglass Pipe Insulation	x	Non Suspect ACM	36	LF	x	x	
BS	5A	Storage Room in the Gym	Concrete Ceiling	x	Non Suspect ACM	360	SF	x	x	
BS	5A	Storage Room in the Gym	Concrete Block Wall	x	Non Suspect ACM	1008	SF	x	x	
BS	5A	Storage Room in the Gym	Floor Tile VAT 9" x 9"	NF1	Confirmed	315	SF	ND	NRN	
BS	5A	Storage Room in the Gym	Floor Tile VAT 12" x 12"	NF1	Assumed	45	SF	ND	NRN	
BS	5C	Hallway from Gym to outdoors Stairs leading to	Ceiling Tile 2' x 2'	x	NAD	60	SF	x	x	
BS	5C	Hallway from Gym to outdoors Stairs leading to	Concrete Block Wall	x	Non Suspect ACM	256	SF	x	x	
BS	5C	Hallway from Gym to outdoors Stairs leading to	Floor Tile VAT 9" x 9"	NF1	Confirmed	48	SF	ND	NRN	
BS	5C	Hallway from Gym to outdoors Stairs leading to	Floor Tile VAT 12" x 12"	NF1	Assumed	12	SF	ND	NRN	
BS	5C	Hallway from Gym to outdoors Stairs leading to	Convactor Insulation	FRI	Assumed	9	SF	ND	NRN	* Coordination required if material will be impacted
BS	5B	Gym Office	Ceiling Tile 2' x 2'	x	NAD	220	SF	x	x	
BS	5B	Gym Office	Concrete Block Wall	x	Non Suspect ACM	512	SF	x	x	
BS	5B	Gym Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	220	SF	ND	NRN	
BS	5BB	Gym Office Closet	Concrete Ceiling	x	Non Suspect ACM	6	SF	x	x	
BS	5BB	Gym Office Closet	Concrete Block Wall	x	Non Suspect ACM	120	SF	x	x	
BS	5BB	Gym Office Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	6	SF	ND	NRN	
BS	5T	Gym Office Restroom	Plaster Ceiling	x	NAD	100	SF	x	x	
BS	5T	Gym Office Restroom	Concrete Block Wall	x	Non Suspect ACM	240	SF	x	x	
BS	5T	Gym Office Restroom	Concrete Wall	x	Non Suspect ACM	80	SF	x	x	
BS	5T	Gym Office Restroom	Ceramic Tile Floors	x	Non Suspect ACM	100	SF	x	x	
BS	H6	Hallway from Gym's Rear Door to Rear	Fiberglass Pipe Insulation	x	Non Suspect ACM	16	LF	x	x	
BS	H6	Hallway from Gym's Rear Door to Rear	Ceiling Tile 2' x 2'	x	NAD	100	SF	x	x	
BS	H6	Hallway from Gym's Rear Door to Rear	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
BS	H6	Hallway from Gym's Rear Door to Rear	Concrete Wall	x	Non Suspect ACM	200	SF	x	x	
BS	H6	Hallway from Gym's Rear Door to Rear	Floor Tile VAT 9" x 9"	NF1	Confirmed	90	SF	ND	NRN	
BS	H6	Hallway from Gym's Rear Door to Rear	Floor Tile VAT 9" x 9"	NF1	Confirmed	10	SF	ND	NRN	
BS	S02	Rear Stairwell from Gym's Rear Door	Plaster Ceiling	x	NAD	220	SF	x	x	
BS	S02	Rear Stairwell from Gym's Rear Door	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
BS	S02	Rear Stairwell from Gym's Rear Door	Concrete Wall	x	Non Suspect ACM	576	SF	x	x	
BS	S02	Rear Stairwell from Gym's Rear Door	Floor Tile VAT 9" x 9"	NF1	Confirmed	45	SF	ND	NRN	
BS	S02	Rear Stairwell from Gym's Rear Door	Floor Tile VAT 12" x 12"	NF1	Assumed	100	SF	ND	NRN	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Fiberglass Pipe Insulation	x	Non Suspect ACM	8	LF	x	x	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Ceiling Tile 2' x 2'	x	NAD	80	SF	x	x	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Concrete Block Wall	x	Non Suspect ACM	144	SF	x	x	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Concrete Wall	x	Non Suspect ACM	144	SF	x	x	
BS	3A	Elevator Mechanical Room with Hydraulic Oil	Cement Floor	x	Non Suspect ACM	80	SF	x	x	
BS		Basement Hallway Storage	Pipe Saddle Insulation	FRI	Confirmed	1	LF	ND	NRN	* Coordination required if material will be impacted
BS		Gymnasium (concealed in soffit)	Pipe Saddle Insulation	FRI	Confirmed	32	LF	ND	NRN	* Coordination required if material will be impacted

BS		Room 2D Home and School	Pipe Saddle Insulation	FRI	Confirmed	2	LF	ND	NRN	* Coordination required if material will be impacted
BS		Basement Hallway outside Room 2D	Pipe Saddle Insulation	FRI	Confirmed	3	LF	ND	NRN	* Coordination required if material will be impacted
BS		Art Room Vestibule	Pipe Saddle Insulation	FRI	Confirmed	1	LF	ND	NRN	* Coordination required if material will be impacted
BS		School Police Room	Pipe Saddle Insulation	FRI	Confirmed	1	LF	ND	NRN	* Coordination required if material will be impacted
BS		Art Room	Pipe Saddle Insulation	FRI	Confirmed	5	LF	ND	NRN	* Coordination required if material will be impacted
BS		Side of Stage and Dressing Room	Pipe Saddle Insulation	FRI	Confirmed	3	LF	ND	NRN	* Coordination required if material will be impacted
BS		Auditorium (concealed above ceiling)	Pipe Saddle Insulation	FRI	Confirmed	10	LF	ND	NRN	* Coordination required if material will be impacted
BS		Hallway outside Mechanical Room near 106	Pipe Saddle Insulation	FRI	Confirmed	6	LF	ND	NRN	* Coordination required if material will be impacted
BS	H03	Elevator Mechanical Room	Pipe Insulation	FRI	Assumed	12	LF	DD	REM	
CS	C	Crawlspace	None Present	x	x	x	x	x	x	None Present
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Fiberglass Pipe Insulation	x	Non Suspect ACM	15	LF	x	x	
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Concrete Ceiling	x	Non Suspect ACM	90	SF	x	x	
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Concrete Block Wall	x	Non Suspect ACM	228	SF	x	x	
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Concrete Wall	x	Non Suspect ACM	228	SF	x	x	
GD	UGMR-1	Upper Gym Mechanical Room off of Rear	Cement Floor	x	Non Suspect ACM	90	SF	x	x	
GD	S15	Stairwell next to School Entrance and near	Ceiling Tile 2' x 2'	x	NAD	352	SF	x	x	
GD	S15	Stairwell next to School Entrance and near	Brick Wall	x	Non Suspect ACM	720	SF	x	x	
GD	S15	Stairwell next to School Entrance and near	Ceramic Tile Floors	x	Non Suspect ACM	352	SF	x	x	
GD	H4	Hallway from Entrance to Center Hallway near	Ceiling Tile 2' x 2'	x	NAD	468	SF	x	x	
GD	H4	Hallway from Entrance to Center Hallway near	Brick Wall	x	Non Suspect ACM	286	SF	x	x	
GD	H4	Hallway from Entrance to Center Hallway near	Ceramic Tile Floors	x	Non Suspect ACM	468	SF	x	x	
GD	H15	Center Hallway from Front Entrance to Rear	Ceiling Tile 2' x 2'	x	NAD	689	SF	x	x	
GD	H15	Center Hallway from Front Entrance to Rear	Brick Wall	x	Non Suspect ACM	848	SF	x	x	
GD	H15	Center Hallway from Front Entrance to Rear	Ceramic Tile Floors	x	Non Suspect ACM	689	SF	x	x	
GD	H5	Hallway from Main Center Hallway to	Ceiling Tile 2' x 2'	x	NAD	246	SF	x	x	
GD	H5	Hallway from Main Center Hallway to	Concrete Block Wall	x	Non Suspect ACM	656	SF	x	x	
GD	H5	Hallway from Main Center Hallway to	Floor Tile VAT 12" x 12"	NF1	Assumed	246	SF	ND	NRN	
GD	110	Classroom 110	Ceiling Tile 2' x 2'	x	NAD	1312	SF	x	x	
GD	110	Classroom 110	Concrete Block Wall	x	Non Suspect ACM	1314	SF	x	x	
GD	110	Classroom 110	Floor Tile VAT 12" x 12"	NF1	Assumed	1312	SF	ND	REM	60 SF Total - 30 SF at each CUV - Non-Friable Removal
GD	110	Classroom 110	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
GD	110D	Classroom 110 Closet in Left Corner	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
GD	110D	Classroom 110 Closet in Left Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	10	LF	x	x	
GD	110D	Classroom 110 Closet in Left Corner	Concrete Ceiling	x	Non Suspect ACM	12	SF	x	x	
GD	110D	Classroom 110 Closet in Left Corner	Concrete Block Wall	x	Non Suspect ACM	140	SF	x	x	
GD	110D	Classroom 110 Closet in Left Corner	Floor Tile VAT 9" x 9"	NF1	Confirmed	12	SF	ND	NRN	
GD	110E	Classroom 110 Closet in Right Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	110E	Classroom 110 Closet in Right Corner	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
GD	110E	Classroom 110 Closet in Right Corner	Floor Tile VAT 9" x 9"	NF1	Confirmed	15	SF	ND	NRN	
GD	110C	Classroom 110 Storage Room in Rear	Fiberglass Pipe Insulation	x	Non Suspect ACM	14	LF	x	x	
GD	110C	Classroom 110 Storage Room in Rear	Concrete Ceiling	x	Non Suspect ACM	63	SF	x	x	
GD	110C	Classroom 110 Storage Room in Rear	Concrete Block Wall	x	Non Suspect ACM	384	SF	x	x	
GD	110C	Classroom 110 Storage Room in Rear	Floor Tile VAT 9" x 9"	NF1	Confirmed	63	SF	ND	NRN	
GD	110A	Classroom 110 Storage Room near Sink Area	Concrete Ceiling	x	Non Suspect ACM	35	SF	x	x	
GD	110A	Classroom 110 Storage Room near Sink Area	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	110A	Classroom 110 Storage Room near Sink Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	35	SF	ND	NRN	
GD	110B	Classroom 110 Restroom	Plaster Ceiling	x	NAD	42	SF	x	x	
GD	110B	Classroom 110 Restroom	Concrete Block Wall	x	Non Suspect ACM	208	SF	x	x	
GD	110B	Classroom 110 Restroom	Ceramic Tile Floors	x	Non Suspect ACM	42	SF	x	x	
GD	H6	Hallway from Classrooms 111 to 112	Ceiling Tile 2' x 2'	x	NAD	60	SF	x	x	
GD	H6	Hallway from Classrooms 111 to 112	Concrete Block Wall	x	Non Suspect ACM	100	SF	x	x	
GD	H6	Hallway from Classrooms 111 to 112	Floor Tile VAT 12" x 12"	NF1	Assumed	60	SF	ND	NRN	
GD	114	Custodial Closet between Classrooms 111 and	Ceiling Tile 2' x 2'	x	NAD	56	SF	x	x	
GD	114	Custodial Closet between Classrooms 111 and	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	114	Custodial Closet between Classrooms 111 and	Floor Tile VAT 9" x 9"	NF1	Confirmed	56	SF	ND	NRN	
GD	111	Classroom 111	Ceiling Tile 2' x 2'	x	NAD	1152	SF	x	x	
GD	111	Classroom 111	Concrete Block Wall	x	Non Suspect ACM	1224	SF	x	x	
GD	111	Classroom 111	Floor Tile VAT 12" x 12"	NF1	Assumed	1152	SF	ND	REM	60 SF Total - 30 SF at each CUV - Non-Friable Removal
GD	111	Classroom 111	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
GD	111D	Classroom 111 Closet in Right Corner	Pipe Fitting Insulation	x	NAD	6	EA	x	x	
GD	111D	Classroom 111 Closet in Right Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	6	LF	x	x	
GD	111D	Classroom 111 Closet in Right Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	111D	Classroom 111 Closet in Right Corner	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	111D	Classroom 111 Closet in Right Corner	Floor Tile VAT 12" x 12"	NF1	Assumed	15	SF	ND	NRN	
GD	111E	Classroom 111 Closet in Left Corner	Pipe Fitting Insulation	x	NAD	3	EA	x	x	
GD	111E	Classroom 111 Closet in Left Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	22	LF	x	x	
GD	111E	Classroom 111 Closet in Left Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	

GD	111E	Classroom 111 Closet in Left Corner	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	111E	Classroom 111 Closet in Left Corner	Floor Tile VAT 9" x 9"	NF1	Confirmed	15	SF	ND	NRN	
GD	111C	Classroom 111 Storage Room in Rear	Fiberglass Pipe Insulation	x	Non Suspect ACM	32	LF	x	x	
GD	111C	Classroom 111 Storage Room in Rear	Concrete Ceiling	x	Non Suspect ACM	63	SF	x	x	
GD	111C	Classroom 111 Storage Room in Rear	Concrete Block Wall	x	Non Suspect ACM	384	SF	x	x	
GD	111C	Classroom 111 Storage Room in Rear	Floor Tile VAT 9" x 9"	NF1	Confirmed	63	SF	ND	NRN	
GD	111A	Classroom 111 Storage Room near Sink Area	Fiberglass Pipe Insulation	x	Non Suspect ACM	10	LF	x	x	
GD	111A	Classroom 111 Storage Room near Sink Area	Concrete Ceiling	x	Non Suspect ACM	35	SF	x	x	
GD	111A	Classroom 111 Storage Room near Sink Area	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	111A	Classroom 111 Storage Room near Sink Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	35	SF	ND	NRN	
GD	111B	Classroom 111 Restroom	Plaster Ceiling	x	NAD	36	SF	x	x	
GD	111B	Classroom 111 Restroom	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	111B	Classroom 111 Restroom	Ceramic Tile Floors	x	Non Suspect ACM	36	SF	x	x	
GD	112	Classroom 112	Ceiling Tile 2' x 2'	x	NAD	1376	SF	x	x	
GD	112	Classroom 112	Concrete Block Wall	x	Non Suspect ACM	1350	SF	x	x	
GD	112	Classroom 112	Floor Tile VAT 12" x 12"	NF1	Assumed	1376	SF	ND	REM	60 SF Total - 30 SF at each CUV - Non-Friable Removal
GD	112	Classroom 112	Sink Undercoat Mastic	NF2	Assumed	5	SF	ND	NRN	
GD	112D	Classroom 112 Closet in Left Corner	Pipe Fitting Insulation	x	NAD	7	EA	x	x	
GD	112D	Classroom 112 Closet in Left Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	12	LF	x	x	
GD	112D	Classroom 112 Closet in Left Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	112D	Classroom 112 Closet in Left Corner	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	112D	Classroom 112 Closet in Left Corner	Floor Tile VAT 9" x 9"	NF1	Confirmed	15	SF	ND	NRN	
GD	112E	Classroom 112 Closet in Right Corner	Pipe Fitting Insulation	x	NAD	3	EA	x	x	
GD	112E	Classroom 112 Closet in Right Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	12	LF	x	x	
GD	112E	Classroom 112 Closet in Right Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	112E	Classroom 112 Closet in Right Corner	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	112E	Classroom 112 Closet in Right Corner	Floor Tile VAT 9" x 9"	NF1	Confirmed	15	SF	ND	NRN	
GD	112C	Classroom 112 Storage Room in Rear	Concrete Ceiling	x	Non Suspect ACM	63	SF	x	x	
GD	112C	Classroom 112 Storage Room in Rear	Concrete Block Wall	x	Non Suspect ACM	384	SF	x	x	
GD	112C	Classroom 112 Storage Room in Rear	Floor Tile VAT 9" x 9"	NF1	Confirmed	63	SF	ND	NRN	
GD	112A	Classroom 112 Storage Room near Sink Area	Concrete Ceiling	x	Non Suspect ACM	35	SF	x	x	
GD	112A	Classroom 112 Storage Room near Sink Area	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	112A	Classroom 112 Storage Room near Sink Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	35	SF	ND	NRN	
GD	112B	Classroom 112 Restroom	Plaster Ceiling	x	NAD	36	SF	x	x	
GD	112B	Classroom 112 Restroom	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	112B	Classroom 112 Restroom	Ceramic Tile Floors	x	Non Suspect ACM	36	SF	x	x	
GD	113B	Special Education 113B	Ceiling Tile 2' x 2'	x	NAD	533	SF	x	x	
GD	113B	Special Education 113B	Concrete Block Wall	x	Non Suspect ACM	486	SF	x	x	
GD	113B	Special Education 113B	Sheetrock Wall	x	NAD	321	SF	x	x	
GD	113B	Special Education 113B	Floor Tile VAT 12" x 12"	NF1	Assumed	533	SF	ND	REM	30 SF at CUV - Non-Friable Removal
GD	113G	Special Education 113B Closet in Right Corner	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
GD	113G	Special Education 113B Closet in Right Corner	Fiberglass Pipe Insulation	x	Non Suspect ACM	9	LF	x	x	
GD	113G	Special Education 113B Closet in Right Corner	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	113G	Special Education 113B Closet in Right Corner	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	113G	Special Education 113B Closet in Right Corner	Floor Tile VAT 12" x 12"	NF1	Assumed	15	SF	ND	NRN	
GD	113	Entrance Hallway to 113 Suite Area	Ceiling Tile 2' x 2'	x	NAD	81	SF	x	x	
GD	113	Entrance Hallway to 113 Suite Area	Concrete Block Wall	x	Non Suspect ACM	45	SF	x	x	
GD	113	Entrance Hallway to 113 Suite Area	Sheetrock Wall	x	NAD	170	SF	x	x	
GD	113	Entrance Hallway to 113 Suite Area	Floor Tile VAT 12" x 12"	NF1	Assumed	81	SF	ND	NRN	
GD	113E	Special Education Restroom	Plaster Ceiling	x	NAD	49	SF	x	x	
GD	113E	Special Education Restroom	Concrete Block Wall	x	Non Suspect ACM	224	SF	x	x	
GD	113E	Special Education Restroom	Ceramic Tile Floors	x	Non Suspect ACM	49	SF	x	x	
GD	113D	Special Education Area Front Storage Room	Concrete Ceiling	x	Non Suspect ACM	35	SF	x	x	
GD	113D	Special Education Area Front Storage Room	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	113D	Special Education Area Front Storage Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	35	SF	ND	NRN	
GD	113A	Special Education 113A	Ceiling Tile 2' x 2'	x	NAD	600	SF	x	x	
GD	113A	Special Education 113A	Concrete Block Wall	x	Non Suspect ACM	450	SF	x	x	
GD	113A	Special Education 113A	Sheetrock Wall	x	NAD	450	SF	x	x	
GD	113A	Special Education 113A	Floor Tile VAT 12" x 12"	NF1	Assumed	600	SF	ND	REM	30 SF at CUV - Non-Friable Removal
GD	113A	Special Education 113A	Sink Undercoat Mastic	NF2	Assumed	6	SF	ND	NRN	
GD	113C	Special Education 113A Rear Storage Room	Concrete Ceiling	x	Non Suspect ACM	63	SF	x	x	
GD	113C	Special Education 113A Rear Storage Room	Concrete Block Wall	x	Non Suspect ACM	384	SF	x	x	
GD	113C	Special Education 113A Rear Storage Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	63	SF	ND	NRN	
GD	113F	Special Education 113A Closet in Rear Left	Fiberglass Pipe Insulation	x	Non Suspect ACM	3	LF	x	x	
GD	113F	Special Education 113A Closet in Rear Left	Concrete Ceiling	x	Non Suspect ACM	15	SF	x	x	
GD	113F	Special Education 113A Closet in Rear Left	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	113F	Special Education 113A Closet in Rear Left	Floor Tile VAT 9" x 9"	NF1	Confirmed	15	SF	ND	NRN	
GD	H17	Hallway from Rear School Entrance to Elevator	Ceiling Tile 2' x 2'	x	NAD	224	SF	x	x	

GD	H17	Hallway from Rear School Entrance to Elevator	Brick Wall	x	Non Suspect ACM	702	SF	x	x	
GD	H17	Hallway from Rear School Entrance to Elevator	Ceramic Tile Floors	x	Non Suspect ACM	224	SF	x	x	
GD	H17	Hallway from Rear School Entrance to Elevator	Convector Insulation	FRI	Assumed	6	SF	ND	NRN	* Coordination required if material will be impacted
GD	H18	Hallway near Elevator to Stairwell	Ceiling Tile 2' x 2'	x	NAD	54	SF	x	x	
GD	H18	Hallway near Elevator to Stairwell	Concrete Block Wall	x	Non Suspect ACM	162	SF	x	x	
GD	H18	Hallway near Elevator to Stairwell	Ceramic Tile Floors	x	Non Suspect ACM	54	SF	x	x	
GD	H18	Hallway near Elevator to Stairwell	Convector Insulation	FRI	Assumed	6	SF	ND	NRN	* Coordination required if material will be impacted
GD	S12	Stairwell adjacent to Hallway near Elevator	Plaster Ceiling	x	NAD	325	SF	x	x	
GD	S12	Stairwell adjacent to Hallway near Elevator	Concrete Block Wall	x	Non Suspect ACM	912	SF	x	x	
GD	S12	Stairwell adjacent to Hallway near Elevator	Floor Tile VAT 12" x 12"	NF1	Assumed	104	SF	ND	NRN	
GD	S12	Stairwell adjacent to Hallway near Elevator	Cement Floor	x	Non Suspect ACM	220	SF	x	x	
GD	105L	Fan Room near Men's and Women's	Fiberglass Pipe Insulation	x	Non Suspect ACM	300	LF	x	x	
GD	105L	Fan Room near Men's and Women's	Fiberglass Pipe Fitting Insulation	x	Non Suspect ACM	30	EA	x	x	
GD	105L	Fan Room near Men's and Women's	Concrete Ceiling	x	Non Suspect ACM	360	SF	x	x	
GD	105L	Fan Room near Men's and Women's	Concrete Block Wall	x	Non Suspect ACM	1008	SF	x	x	
GD	105L	Fan Room near Men's and Women's	Cement Floor	x	Non Suspect ACM	360	SF	x	x	
GD	105L	Fan Room near Men's and Women's	Vibration Damper Cloth	x	NAD	16	SF	x	x	
GD	105A	Men's Restroom next to Fan Room	Plaster Ceiling	x	NAD	25	SF	x	x	
GD	105A	Men's Restroom next to Fan Room	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
GD	105A	Men's Restroom next to Fan Room	Ceramic Tile Floors	x	Non Suspect ACM	25	SF	x	x	
GD	105C	Women's Restroom near Fan Room	Plaster Ceiling	x	NAD	25	SF	x	x	
GD	105C	Women's Restroom near Fan Room	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
GD	105C	Women's Restroom near Fan Room	Ceramic Tile Floors	x	Non Suspect ACM	25	SF	x	x	
GD	H13	Hallway from Women's Restroom to Fan Room	Ceiling Tile 2' x 2'	x	NAD	72	SF	x	x	
GD	H13	Hallway from Women's Restroom to Fan Room	Concrete Block Wall	x	Non Suspect ACM	240	SF	x	x	
GD	H13	Hallway from Women's Restroom to Fan Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	72	SF	ND	NRN	
GD	H1	Hallway near Staff Restrooms to Stairwell	Ceiling Tile 2' x 2'	x	NAD	100	SF	x	x	
GD	H1	Hallway near Staff Restrooms to Stairwell	Concrete Block Wall	x	Non Suspect ACM	240	SF	x	x	
GD	H1	Hallway near Staff Restrooms to Stairwell	Floor Tile VAT 9" x 9"	NF1	Confirmed	100	SF	ND	NRN	
GD	H1	Hallway near Staff Restrooms to Stairwell	Convector Insulation	FRI	Assumed	6	SF	ND	NRN	* Coordination required if material will be impacted
GD	S11	Stairwell near Staff Restrooms and Fan Room	Plaster Ceiling	x	NAD	230	SF	x	x	
GD	S11	Stairwell near Staff Restrooms and Fan Room	Concrete Block Wall	x	Non Suspect ACM	792	SF	x	x	
GD	S11	Stairwell near Staff Restrooms and Fan Room	Floor Tile VAT 12" x 12"	NF1	Assumed	90	SF	ND	NRN	
GD	S11	Stairwell near Staff Restrooms and Fan Room	Cement Floor	x	Non Suspect ACM	140	SF	x	x	
GD	106A	Custodial Closet near Storage/Conference	Concrete Ceiling	x	Non Suspect ACM	18	SF	x	x	
GD	106A	Custodial Closet near Storage/Conference	Concrete Block Wall	x	Non Suspect ACM	90	SF	x	x	
GD	106A	Custodial Closet near Storage/Conference	Concrete Wall	x	Non Suspect ACM	90	SF	x	x	
GD	106A	Custodial Closet near Storage/Conference	Floor Tile VAT 9" x 9"	NF1	Confirmed	18	SF	ND	NRN	
GD	106	Storage/Conference Room 106	Fiberglass Pipe Insulation	x	Non Suspect ACM	5	LF	x	x	
GD	106	Storage/Conference Room 106	Pipe Fitting Insulation	x	NAD	1	EA	x	x	
GD	106	Storage/Conference Room 106	Ceiling Tile 2' x 2'	x	NAD	528	SF	x	x	
GD	106	Storage/Conference Room 106	Concrete Block Wall	x	Non Suspect ACM	414	SF	x	x	
GD	106	Storage/Conference Room 106	Concrete Wall	x	Non Suspect ACM	414	SF	x	x	
GD	106	Storage/Conference Room 106	Floor Tile VAT 9" x 9"	NF1	Confirmed	528	SF	ND	NRN	
GD	104	General Office Space 104	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
GD	104	General Office Space 104	Concrete Block Wall	x	Non Suspect ACM	352	SF	x	x	
GD	104	General Office Space 104	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
GD	103	Psychologist Office 103	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
GD	103	Psychologist Office 103	Concrete Block Wall	x	Non Suspect ACM	352	SF	x	x	
GD	103	Psychologist Office 103	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
GD	H3	Hallway between Laminating Machines Room	Ceiling Tile 2' x 2'	x	NAD	96	SF	x	x	
GD	H3	Hallway between Laminating Machines Room	Concrete Block Wall	x	Non Suspect ACM	256	SF	x	x	
GD	H3	Hallway between Laminating Machines Room	Floor Tile VAT 9" x 9"	NF1	Confirmed	96	SF	ND	NRN	
GD	102	Laminating Machines Room 102	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
GD	102	Laminating Machines Room 102	Concrete Block Wall	x	Non Suspect ACM	352	SF	x	x	
GD	102	Laminating Machines Room 102	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
GD	108	Conference Room 108	Ceiling Tile 2' x 2'	x	NAD	252	SF	x	x	
GD	108	Conference Room 108	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
GD	108	Conference Room 108	Concrete Wall	x	Non Suspect ACM	144	SF	x	x	
GD	108	Conference Room 108	Floor Tile VAT 9" x 9"	NF1	Confirmed	252	SF	ND	NRN	
GD	108A	Conference Room 108 Closet	Pipe Fitting Insulation	x	NAD	6	EA	x	x	
GD	108A	Conference Room 108 Closet	Fiberglass Pipe Insulation	x	Non Suspect ACM	18	LF	x	x	
GD	108A	Conference Room 108 Closet	Concrete Ceiling	x	Non Suspect ACM	18	SF	x	x	
GD	108A	Conference Room 108 Closet	Concrete Block Wall	x	Non Suspect ACM	216	SF	x	x	
GD	108A	Conference Room 108 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	18	SF	ND	NRN	
GD	107A	Nurse's Office Exam Room (between Waiting	Ceiling Tile 2' x 2'	x	NAD	198	SF	x	x	
GD	107A	Nurse's Office Exam Room (between Waiting	Concrete Block Wall	x	Non Suspect ACM	496	SF	x	x	
GD	107A	Nurse's Office Exam Room (between Waiting	Floor Tile VAT 9" x 9"	NF1	Confirmed	198	SF	ND	NRN	

GD	107	Nurse's Office Waiting Area	Ceiling Tile 2' x 2'	x	NAD	100	SF	x	x	
GD	107	Nurse's Office Waiting Area	Concrete Block Wall	x	Non Suspect ACM	240	SF	x	x	
GD	107	Nurse's Office Waiting Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	100	SF	ND	NRN	
GD	107B	Nurse's Office	Ceiling Tile 2' x 2'	x	NAD	100	SF	x	x	
GD	107B	Nurse's Office	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
GD	107B	Nurse's Office	Concrete Wall	x	Non Suspect ACM	80	SF	x	x	
GD	107B	Nurse's Office	Floor Tile VAT 12" x 12"	NF1	Assumed	100	SF	ND	NRN	
GD	107D	Nurse's Office Exam Room Left of the	Ceiling Tile 2' x 2'	x	NAD	72	SF	x	x	
GD	107D	Nurse's Office Exam Room Left of the	Concrete Block Wall	x	Non Suspect ACM	288	SF	x	x	
GD	107D	Nurse's Office Exam Room Left of the	Floor Tile VAT 9" x 9"	NF1	Confirmed	72	SF	ND	NRN	
GD	107C	Nurse's Office Restroom	Plaster Ceiling	x	NAD	35	SF	x	x	
GD	107C	Nurse's Office Restroom	Concrete Block Wall	x	Non Suspect ACM	192	SF	x	x	
GD	107C	Nurse's Office Restroom	Ceramic Tile Floors	x	Non Suspect ACM	35	SF	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Pipe Fitting Insulation	x	NAD	2	EA	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Fiberglass Pipe Insulation	x	Non Suspect ACM	3	LF	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Concrete Block Wall	x	Non Suspect ACM	264	SF	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Concrete Wall	x	Non Suspect ACM	88	SF	x	x	
GD	107E	Nurse's Office Exam Room Right of the	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
GD	H19	Hallway from Main Office to	Ceiling Tile 2' x 2'	x	NAD	504	SF	x	x	
GD	H19	Hallway from Main Office to	Concrete Block Wall	x	Non Suspect ACM	1392	SF	x	x	
GD	H19	Hallway from Main Office to	Floor Tile VAT 9" x 9"	NF1	Confirmed	504	SF	ND	NRN	
GD	109	Playworks Office 109	Ceiling Tile 2' x 2'	x	NAD	140	SF	x	x	
GD	109	Playworks Office 109	Concrete Block Wall	x	Non Suspect ACM	432	SF	x	x	
GD	109	Playworks Office 109	Cement Floor	x	Non Suspect ACM	140	SF	x	x	
GD	109A	Playworks Office 109 Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
GD	109A	Playworks Office 109 Closet	Concrete Block Wall	x	Non Suspect ACM	144	SF	x	x	
GD	109A	Playworks Office 109 Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
GD	101	Main Office	Ceiling Tile 2' x 2'	x	NAD	468	SF	x	x	
GD	101	Main Office	Concrete Block Wall	x	Non Suspect ACM	792	SF	x	x	
GD	101	Main Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	468	SF	ND	NRN	
GD	101B	Upper Level Storage Area behind Main Office	Pipe Fitting Insulation	x	NAD	10	EA	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Fiberglass Pipe Insulation	x	Non Suspect ACM	200	LF	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Fiberglass Pipe Fitting Insulation	x	Non Suspect ACM	3	EA	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Concrete Ceiling	x	Non Suspect ACM	798	SF	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Concrete Block Wall	x	Non Suspect ACM	488	SF	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Concrete Wall	x	Non Suspect ACM	488	SF	x	x	
GD	101B	Upper Level Storage Area behind Main Office	Cement Floor	x	Non Suspect ACM	798	SF	x	x	
GD	101C	Lower Level Storage Area behind Main Office	Pipe Fitting Insulation	x	NAD	23	EA	x	x	
GD	101C	Lower Level Storage Area behind Main Office	Fiberglass Pipe Insulation	x	Non Suspect ACM	130	LF	x	x	
GD	101C	Lower Level Storage Area behind Main Office	Concrete Ceiling	x	Non Suspect ACM	504	SF	x	x	
GD	101C	Lower Level Storage Area behind Main Office	Concrete Block Wall	x	Non Suspect ACM	1032	SF	x	x	
GD	101C	Lower Level Storage Area behind Main Office	Cement Floor	x	Non Suspect ACM	504	SF	x	x	
GD	101A	Storage Area and Hallway from Main Office to	Ceiling Tile 2' x 2'	x	NAD	120	SF	x	x	
GD	101A	Storage Area and Hallway from Main Office to	Concrete Block Wall	x	Non Suspect ACM	368	SF	x	x	
GD	101A	Storage Area and Hallway from Main Office to	Floor Tile VAT 9" x 9"	NF1	Confirmed	120	SF	ND	NRN	
GD	101AA	Main Office Kitchen Area	Fiberglass Pipe Insulation	x	Non Suspect ACM	18	LF	x	x	
GD	101AA	Main Office Kitchen Area	Ceiling Tile 2' x 2'	x	NAD	144	SF	x	x	
GD	101AA	Main Office Kitchen Area	Concrete Block Wall	x	Non Suspect ACM	384	SF	x	x	
GD	101AA	Main Office Kitchen Area	Floor Tile VAT 9" x 9"	NF1	Confirmed	144	SF	ND	NRN	
GD	101AA	Main Office Kitchen Area	Sink Undercoat Mastic	NF2	Assumed	10	SF	ND	NRN	
GD	100	Principal's Office	Ceiling Tile 2' x 2'	x	NAD	220	SF	x	x	
GD	100	Principal's Office	Concrete Block Wall	x	Non Suspect ACM	576	SF	x	x	
GD	100	Principal's Office	Carpet	x	Non Suspect ACM	220	SF	x	x	
GD	100A	Principal's Office Closet	Concrete Ceiling	x	Non Suspect ACM	9	SF	x	x	
GD	100A	Principal's Office Closet	Concrete Block Wall	x	Non Suspect ACM	144	SF	x	x	
GD	100A	Principal's Office Closet	Floor Tile VAT 9" x 9"	NF1	Confirmed	9	SF	ND	NRN	
GD	100T	Principal's Office Restroom	Plaster Ceiling	x	NAD	25	SF	x	x	
GD	100T	Principal's Office Restroom	Concrete Block Wall	x	Non Suspect ACM	160	SF	x	x	
GD	100T	Principal's Office Restroom	Ceramic Tile Floors	x	Non Suspect ACM	25	SF	x	x	
GD	101BB	Main Office Closet next to Principal's Office	Concrete Ceiling	x	Non Suspect ACM	12	SF	x	x	
GD	101BB	Main Office Closet next to Principal's Office	Concrete Block Wall	x	Non Suspect ACM	168	SF	x	x	
GD	101BB	Main Office Closet next to Principal's Office	Floor Tile VAT 9" x 9"	NF1	Confirmed	12	SF	ND	NRN	

	All window related metal panels throughout	Transite	NF2	Confirmed	2,135	SF	ND	NRN	* Coordination required if material will be impacted
--	--	----------	-----	-----------	-------	----	----	-----	--