



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

April 29, 2019

Dear Juniata Park Academy Community,

As a part of the School District of Philadelphia’s effort to provide students and staff with safe, accessible and appealing drinking water, 67 water outlets at your school were initially tested for lead on March 13, 2019, March 14, 2019, and March 15, 2019. Of those outlets, 57 outlets produced water that was below the action level of 10 ppb. Ten (10) water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those five water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
03/13/2019	1	3	FP	Pot filler in kitchen next to oven	152.9	0.3	1.0	Flushing protocol implemented by food services. ¹
03/13/2019	1	9	FT	In kitchen by pot washer left	35.7	0.3	1.0	Flushing protocol implemented by food services. ¹
03/13/2019	1	10	FT	In RM 6	14.7	0.3	1.0	Made hand wash sink only. Will apply signage.
03/13/2019	1	12	FT	In RM 5	10.4	0.3	1.0	Made hand wash sink only. Will apply signage.
03/13/2019	1	22	FT	In music room	11.1	0.3	1.0	Made hand wash sink only. Will apply signage.
03/14/2019	1	31	FP	In kitchen by steamer	47.6	0.3	1.0	Flushing protocol implemented by food services. ¹
03/14/2019	1	37	FT	In RM 110	47.9	0.3	1.0	Made hand wash sink only. Will apply signage.
03/14/2019	1	41	FT	In RM 108	24.0	0.3	1.0	Made hand wash sink only. Will apply signage.
03/15/2019	1	55	FT	In RM 113	18.0	0.3	1.0	Made hand wash sink only. Will apply signage.



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
 440 North Broad Street
 Philadelphia, Pennsylvania 19130
 215-400-4750

03/15/2019	2	58	FT	In RM 201	11.2	0.3	1.0	Made hand wash sink only. Will apply signage.
------------	---	----	----	-----------	------	-----	-----	--

Notes:

AA = Above Action limit of 10 ppb
 BA = Below Action limit of 10 ppb
 MDL = Method Detection Limit
 PQL = Practical Quantitation Limit
 J = Result estimated below the PQL
 < = not detected above PQL
 ppb = parts per billion

Outlet Types:

WF=Water Fountain/Bubbler
 HS=Hydration Station/Bottle Filling Station
 FT=Faucet/Tap
 FP - Food Prep/Pot-Filler/Kitchen Kettle
 IM - Ice-Maker

¹Flushing Protocol for Food Service Water Outlets: All water outlets in kitchens that are used daily should be flushed for 15 minutes daily before use. For sinks/fixtures that are not used daily, they must be flushed for 30 minutes prior to use.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District’s website. If you wish to review the results from your school and for more information, you may visit the District’s website at:

www.philasd.org/waterresults.

Sincerely,

Francine Locke, MS
 Environmental Director