

**THE SCHOOL DISTRICT OF PHILADELPHIA
Office of Capital Programs
440 North Broad Street, 3rd Floor – Suite 371
Philadelphia, PA 19130**

TELEPHONE: (215) 400-4730

Addendum No. 02

Subject: Swenson Arts & Technology HS – CTE Improvements
SDP Contract Nos. B-120C, B121C, B123C of 2017/18

Location: Swenson HS
2750 Red Lion Rd.
Philadelphia, Pennsylvania 19114

This Addendum, dated 18th of June, 2019, shall modify and become part of the Contract Documents for the work of this project. Any items not mentioned herein, or affected by, shall be performed strictly in accordance with the original documents.

BIDDER'S QUESTIONS

The below is a follow-up question and response to Q7 in Addendum No.01, issued 17 of June 2019.

Q1: The Ultima comes in Class A, fire performance but it is not fire-rated. Can you please clarify the tile to be used?

A1: Provide Armstrong Fine Fissured as the Basis of Design product for Fire Guard square lay-in ceiling tiles.

End of Addendum 02