



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division
 Office of Environmental Management and Services
 440 North Broad Street
 Philadelphia, Pennsylvania 19130
 215-400-4750

August 02, 2019

Dear **Sheridan Elementary School** Community,

As a part of the School District of Philadelphia’s effort to provide students and staff with safe, accessible and appealing drinking water, **15** water outlets at your school were initially tested for lead on **April 30, 2019 and May 02, 2019**. Of those outlets, **13** outlets produced water that was below the action level of 10 ppb. **Two (2)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those five water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
04/30/2019	1	6	WF	In sink in RM 102	22.2*	0.3	1.0	Permanently removed water fountain. Made adjacent sink handwash only and applied sign.
04/30/2019	3	12	FT	In RM 310 center	78.5	0.3	1.0	Made handwash sink. Applied sign.

Notes:

AA = Above Action limit of 10 ppb
 BA = Below Action limit of 10 ppb
 MDL = Method Detection Limit
 PQL = Practical Quantitation Limit
 J = Result estimated below the PQL
 < = not detected above PQL
 ppb = parts per billion

Outlet Types:

WF=Water Fountain/Bubbler
 HS=Hydration Station/Bottle Filling Station
 FT=Faucet/Tap
 FP - Food Prep/Pot-Filler/Kitchen Kettle
 IM - Ice-Maker

*Denotes an outlet location that has not been in use (the outlet was temporarily turned on for testing).

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District’s website. If you wish to review the results from your school and for more information, you may visit the District’s website at:

www.philasd.org/waterresults.

Sincerely,

Brian Joseph
 Environmental Director