



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

**August 02, 2019**

Dear **Stearne Elementary School** Community,

As a part of the School District of Philadelphia’s effort to provide students and staff with safe, accessible and appealing drinking water, **32** water outlets at your school were initially tested for lead on **May 08, 2019 and May 09, 2019**. Of those outlets, **28** outlets produced water that was below the action level of 10 ppb. **Four (4)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those five water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
05/08/2019	2	15	FT	In RM 206	11.9	0.3	1.0	Made handwash sink. <b>Applied sign.</b>
05/08/2019	3	26	FT	In RM 307	17.0	0.3	1.0	Made handwash sink. <b>Applied sign.</b>
05/08/2019	3	28	FT	In RM 305	15.8	0.3	1.0	Made handwash sink. <b>Applied sign.</b>
05/09/2019	3	31	FT	Inside RM 303	74.3*	0.3	1.0	Made handwash sink. <b>Applied sign.</b>

**Notes:**

AA = Above Action limit of 10 ppb  
BA = Below Action limit of 10 ppb  
MDL = Method Detection Limit  
PQL = Practical Quantitation Limit  
J = Result estimated below the PQL  
< = not detected above PQL  
ppb = parts per billion

**Outlet Types:**

WF=Water Fountain/Bubbler  
HS=Hydration Station/Bottle Filling Station  
FT=Faucet/Tap  
FP - Food Prep/Pot-Filler/Kitchen Kettle  
IM - Ice-Maker

\*Denotes an outlet location that has not been in use (the outlet was temporarily turned on for testing).

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District’s website. If you wish to review the results from your school and for more information, you may visit the District’s website at:

[www.philasd.org/waterresults](http://www.philasd.org/waterresults).



THE SCHOOL DISTRICT OF  
PHILADELPHIA

**Operations Division**

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

Sincerely,

Brian Joseph  
Environmental Director