

OHCS inc.

Occupational Health Consultation Services  
209 Catharine Street, Philadelphia, PA 19147  
Cell: 215-407-3900 Office: 215-925-3870 Fax: 215-925-3872  
-Roseman@dca.net

①

CHAIN OF CUSTODY - Air Samples

CLIENT: PFT.	SITE: BEN FRANKLIN.
PROJECT #: MECA ROOM 20.	PAGE #: 10F1.
SAMPLED BY: TIM DAVEY.	DATE: 10.9.19
CONTAMINANTS: ASBESTOS	ANALYSIS NEEDED BY: 12 HOUR

AGGRESSIVE LEAF BLOWN 2 AFOS

SAMPLE#	VOLUME	TYPE	COMMENTS: 10CPM
1541 100719 BEN 01	1800	TEM	INSIDE CONTAINMENT MECA ROOM 20 6895091 1841
1541 100719 BEN 02	1800		INSIDE CONTAINMENT MECA ROOM 20 6895092 1841
1541 100719 BEN 03	1800		INSIDE CONTAINMENT MECA ROOM 20 6895093 1841
1541 100719 BEN 04	1800		INSIDE CONTAINMENT MECA ROOM 20 6895094 1841
1541 100719 BEN 05	1800		INSIDE CONTAINMENT MECA ROOM 20 6895095 1841
1543 100719 BEN 06	1800		OUT SIDE PANEL BOX ENTRANCE TO MECA 20 6895096 1843
1543 100719 BEN 07	1800		OUT SIDE HALLWAY ACROSS FROM 18 CENTER TEST 6895097 1843
1544 100719 BEN 08	1800		OUT SIDE HALLWAY ENTRANCE TO 1ST FLOOR STAIRS 6895098 1844
1545 100719 BEN 09	1800		OUT SIDE ROOM 18 RTOC ENTRANCE 6895099 1845
1546 100719 BEN 10	1800		OUT SIDE, OUT STAIR FOR UP ROOM 18 6895100 1846

SAMPLE PACKAGED AND SEALED BY: Tim Davey DATE: 10.9.19

SENT TO: IATL

CONDITION UPON RECEIPT (DAMAGED / UNDAIMAGED)

analyzed: 53 10/10/19

RECEIVED

OCT - 9 2019

IATL - BY DG

**PRELIMINARY RESULTS**  
**Airborne Asbestos Analysis**  
**TEM AHERA**

Client: OHCS Inc.  
209 Catharine St.  
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 601517  
Project: Ben Franklin  
Project No.: Mech Room 20  
Philly Regs: Y  
Turn-Around Time: 12 Hour Rush

Client Contacts:	Laboratory Contacts:
Contacts: _____	Contacts: Frank E. Ehrenfeld III
Phone: _____	Phone: (856) 231-9449
Fax: _____	Fax: (856) 231-9818
Cell/Pager: _____	Cell/Pager: (609) 929-4211
E-Mail: _____	E-Mail: <a href="mailto:frankehrenfeld@iatl.com">frankehrenfeld@iatl.com</a>

Chain of Custody:			
Samples Taken in Field:	<u>Client</u>	Date: <u>10/9/2019</u>	Time: _____
Samples Rec'd at Laboratory:	<u>DG</u>	Date: <u>10/9/2019</u>	Time: _____
Samples Analyzed:	<u>J. Jeon</u>	Date: <u>10/10/2019</u>	Time: _____
Preliminary Results Faxed:	_____	Date: _____	Time: _____
Preliminary Results E-Mail:	_____	Date: _____	Time: _____

**Summary Data**  
**Transmission Electron Microscopy**  
**AHERA 40CFR 763**

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm <sup>2</sup>	Results s/cc
100919BEN01	6895091	1800	None Detected	< 19.2	< 0.0041
100919BEN02	6895092	1800	None Detected	< 19.2	< 0.0041
100919BEN03	6895093	1800	None Detected	< 19.2	< 0.0041
100919BEN04	6895094	1800	None Detected	< 19.2	< 0.0041
100919BEN05	6895095	1800	None Detected	< 19.2	< 0.0041

AHERA Clearance Criteria is 70 s/mm<sup>2</sup>.      Average (s/mm<sup>2</sup>) = 19.2  
 Phila. Regulations Clearance Criteria is 0.00554 s/cc      Geo = 0.0041  
 Z Test Results (see attached, if applicable)

Grid Box #: 1750  
Instrument (I, II, III) II

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.

**PRELIMINARY RESULTS**  
**Airborne Asbestos Analysis**  
**TEM AHERA**

Client: OHCS Inc.  
209 Catharine St.  
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 601517  
Project: Ben Franklin  
Project No.: Mech Room 20  
Philly Regs: Y  
Turn-Around Time: 12 Hour Rush

Client Contacts:	Laboratory Contacts:
Contacts: _____	Contacts: Frank E. Ehrenfeld III
Phone: _____	Phone: (856) 231-9449
Fax: _____	Fax: (856) 231-9818
Cell/Pager: _____	Cell/Pager: (609) 929-4211
E-Mail: _____	E-Mail: <a href="mailto:frankehrenfeld@iatl.com">frankehrenfeld@iatl.com</a>

Chain of Custody:			
Samples Taken in Field:	<u>Client</u>	Date: <u>10/9/2019</u>	Time: _____
Samples Rec'd at Laboratory:	<u>DG</u>	Date: <u>10/9/2019</u>	Time: _____
Samples Analyzed:	<u>J. Jeon</u>	Date: <u>10/10/2019</u>	Time: _____
Preliminary Results Faxed:	_____	Date: _____	Time: _____
Preliminary Results E-Mail:	_____	Date: _____	Time: _____

**Summary Data**  
**Transmission Electron Microscopy**  
**AHERA 40CFR 763**

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm <sup>2</sup>	Results s/cc
100919BEN06	6895096	1800	None Detected	< 19.2	< 0.0041
100919BEN07	6895097	1800	None Detected	< 19.2	< 0.0041
100919BEN08	6895098	1800	None Detected	< 19.2	< 0.0041
100919BEN09	6895099	1800	None Detected	< 19.2	< 0.0041
100919BEN10	6895100	1800	None Detected	< 19.2	< 0.0041

AHERA Clearance Criteria is 70 s/mm<sup>2</sup>.      Average (s/mm<sup>2</sup>) = 19.2  
 Phila. Regulations Clearance Criteria is 0.00554 s/cc      Geo = 0.0041  
 Z Test Results (see attached, if applicable)

Grid Box #: 1750  
Instrument (I, II, III)      II

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.