

OHCS Inc.

Occupational Health Consultation Services

209 Catharine Street, Philadelphia, PA 19147

Cell: 215-407-3900 Office: 215-925-3870 Fax: 215-925-3872

J.Roseman@ohcs.net j.roseman@icloud.com

CHAIN OF CUSTODY--Air Samples

CLIENT: PFT	SITE: FRANCLIN CHORNING CENTER
PROJECT #: ROSEMENT FAN RM. / AUDITORIUM	PAGE #: 1 OF 1.
SAMPLED BY: TIM DACEY	DATE: 12.19.19.
CONTAMINANTS: ASBESTOS	ANALYSIS NEEDED BY: 12 HOUR.

	SAMPLE #	VOLUME	TYPE	COMMENTS	
0921	1219A FLL 01	1800	TEM	ENTRANCE TO WALLACE ST. FAN ROOM	1221 0920953
0922	1219A FLL 02	1800		IN FRONT OF FAN UNIT. WALLACE ST SIDE.	1222 0920954
0923	1219A FLL 03	1800		CENTER WALK WAY BETWEEN THE TWO FANS.	1223 0920955
0924	1219A FLL 04	1800		IN FRONT OF FAN UNIT MOUNT VERNON SIDE.	1224 0920953
0924	1219A FLL 05	1800		ENTRANCE TO FAN ROOM MOUNT VERNON SIDE.	1224 0920957
0933	1219A FLL 06	1800		AUDITORIUM FAN RM EXHAUST WALLACE ST SIDE. FEED.	1233 0920958
0933	1219A FLL 07	1800		AUDITORIUM FAN RM FEED MOUNT VERNON SIDE.	1233 0920953
0934	1219A FLL 08	1800		AUDITORIUM WALLACE SIDE MIDDLE	1234 0920960
0934	1219A FLL 09	1800		AUDITORIUM CENTER SOUND BOOTH AREA.	1234 0920961
0935	1219A FLL 10	1800	✓	AUDITORIUM MOUNT VERNON SIDE BY CAFE. MIDDLE.	1235 0920962

SAMPLE PACKAGED AND SEALED BY:

Tim Dacey

DATE: TIME:

12.19.19.

SENT TO:

ICL

CONDITION UPON RECEIPT (DAMAGED / UNDAAGED)

Analyzed by [Signature] 12/20/19

RECEIVED
DEC 19 2019
ICL - BY [Signature]

Se 12/20/19

PRELIMINARY RESULTS
Airborne Asbestos Analysis
TEM AHERA

Client: OHCS Inc.
209 Catharine St.
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 606651
Project: FLC
Project No.: _____
Turn-Around Time: 12 Hour Rush

Client Contacts:		Laboratory Contacts:	
Contacts:	_____	Contacts:	Frank E. Ehrenfeld III
Phone:	_____	Phone:	(856) 231-9449
Fax:	_____	Fax:	(856) 231-9818
Cell/Pager:	_____	Cell/Pager:	(609) 929-4211
E-Mail:	_____	E-Mail:	frankehrenfeld@iatl.com

Chain of Custody:			
Samples Taken in Field:	_____	Date:	_____ Time: _____
Samples Rec'd at Laboratory:	<u>S. Glanville</u>	Date:	<u>12/19/2019</u> Time: _____
Samples Analyzed:	<u>S. Chinnamaneni</u>	Date:	<u>12/20/2019</u> Time: _____
Preliminary Results Faxed:	_____	Date:	_____ Time: _____
Preliminary Results E-Mail:	_____	Date:	_____ Time: _____

Summary Data
Transmission Electron Microscopy
AHERA 40CFR 763

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm ²	Results s/cc
121919FLC-1	6939953	1800	None Detected	< 19.2	< 0.0041
2	6939954	1800	None Detected	< 19.2	< 0.0041
3	6939955	1800	None Detected	< 19.2	< 0.0041
4	6939956	1800	None Detected	< 19.2	< 0.0041
5	6939957	1800	None Detected	< 19.2	< 0.0041
6	6939958	1800	None Detected	< 19.2	< 0.0041
7	6939959	1800	None Detected	< 19.2	< 0.0041
8	6939960	1800	None Detected	< 19.2	< 0.0041
9	6939961	1800	None Detected	< 19.2	< 0.0041
10	6939962	1800	None Detected	< 19.2	< 0.0041

AHERA Clearance Criteria is 70 s/mm². Average (s/mm²) = 19.2

Z Test Results (see attached, if applicable)

Grid Box #: 1812

Instrument (I, II, III) II

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.