

Occupational Health Consultation Services  
209 Catharine Street, Philadelphia, PA 19147  
Cell: 215-407-3900 Office: 215-925-3870 Fax: 215-925-3872

J.Roseman@ohcs.net jeralisa@icloud.com

2

CHAIN OF CUSTODY - Air Samples

CLIENT: <b>PFT.</b>	SITE: <b>FRANKLIN TURNING CENTER</b>
PROJECT #:	PAGE #: <b>1 OF 1.</b>
SAMPLED BY: <b>TIM DAVEY</b>	DATE: <b>12.19.19.</b>
CONTAMINANTS: <b>ASBESTOS</b>	ANALYSIS NEEDED BY: <b>12 HOUR.</b>

	SAMPLE #	VOLUME	TYPE	COMMENTS	
1230	12199 FLL 11	1800	TEM	IN FRONT OF FAN UNIT WALLACE ST. SIDE.	153063
1231	12199 FLL 12	1800		IN FRONT OF FAN UNIT MOUNT VERNON SIDE.	153164
1238	12199 FLL 13	1800		ATTIC OUT SIDE SHIFTS DOOR 4TH FLOOR RETURN.	153265
1245	12199 FLL 14	1800		AUDITORIUM FEED FRONT WALLACE ST. SIDE.	154566
1245	12199 FLL 15	1800		AUDITORIUM FEED FRONT MOUNT VERNON SIDE.	154567
1250	12199 FLL 16	1800		CAFETERIA KITCHEN ENTRANCE.	155068
1251	12199 FLL 17	1800		CAFETERIA MT VERNON WINDOW WALL WINDOW (C)	155169
1251	12199 FLL 18	1300		CAFETERIA MT VERNON WINDOW WALL (D)	155170
1252	12199 FLL 19	1800		CAFETERIA CENTER	155271
1253	12199 FLL 20	1800		CAFETERIA ENTRANCE.	155372

SAMPLE PACKAGED AND SEALED BY: Tim Davey DATE: 12.19.19 TIME: 12:19 PM

SENT TO: IOCC

CONDITION UPON RECEIPT (DAMAGED / UNDAIMAGED):

Analyzed by [Signature] 12/20/19  
ANALYZED BY [Signature] 12/20/19

RECEIVED  
DEC 19 2019  
IATL BY [Signature]

**PRELIMINARY RESULTS**  
**Airborne Asbestos Analysis**  
**TEM AHERA**

Client: OHCS Inc.  
209 Catharine St.  
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 606652  
Project: FLC  
Project No.:

Turn-Around Time: 12 Hour Rush

Client Contacts:	Laboratory Contacts:
Contacts: _____	Contacts: Frank E. Ehrenfeld III
Phone: _____	Phone: (856) 231-9449
Fax: _____	Fax: (856) 231-9818
Cell/Pager: _____	Cell/Pager: (609) 929-4211
E-Mail: _____	E-Mail: <a href="mailto:frankehrenfeld@iatl.com">frankehrenfeld@iatl.com</a>

Chain of Custody:			
Samples Taken in Field:	_____	Date: _____	Time: _____
Samples Rec'd at Laboratory:	<u>S. Glanville</u>	Date: <u>12/19/2019</u>	Time: _____
Samples Analyzed:	<u>BR/CL</u>	Date: <u>12/20/2019</u>	Time: _____
Preliminary Results Faxed:	_____	Date: _____	Time: _____
Preliminary Results E-Mail:	_____	Date: _____	Time: _____

**Summary Data**  
**Transmission Electron Microscopy**  
**AHERA 40CFR 763**

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm <sup>2</sup>	Results s/cc
121919FLC-11	6939963	1800	None Detected	< 19.2	< 0.0041
12	6939964	1800	None Detected	< 19.2	< 0.0041
13	6939965	1800	Chrysotile	19.2	0.0041
14	6939966	1800	None Detected	< 19.2	< 0.0041
15	6939967	1800	None Detected	< 19.2	< 0.0041
16	6939968	1800	None Detected	< 19.2	< 0.0041
17	6939969	1800	None Detected	< 19.2	< 0.0041
18	6939970	1800	None Detected	< 19.2	< 0.0041
19	6939971	1800	None Detected	< 19.2	< 0.0041
20	6939972	1800	None Detected	< 19.2	< 0.0041

AHERA Clearance Criteria is 70 s/mm<sup>2</sup>. Average (s/mm<sup>2</sup>) = 19.2

Z Test Results (see attached, if applicable)

Grid Box #: 1814

Instrument (I, II, III) I

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.