

OHCS Inc.

Occupational Health Consultation Services
209 Catharine Street; Philadelphia, PA 19147
Cell: 215-407-3900 Office: 215-925-3870 Fax: 215-925-3872

J.Roseman@ohcs.net j.roseman@icloud.com

①

CHAIN OF CUSTODY - Air Samples

CLIENT: PFT.	SITE: FLL.
PROJECT #: MT. VERNON FAN SHORT.	PAGE #: 1 OF 1
SAMPLED BY: TIM DALY.	DATE: 12.23.19.
CONTAMINANTS: ASBESTOS	ANALYSIS NEEDED BY: 12 HOUR.

AGGRESSIVE LEAF BLOWN

1 ADD.

	SAMPLE #	VOLUME	TYPE	COMMENTS	
1021	122319 FLL 01	1900	TEM	INSIDE CONTAINMENT MT VERNON SIDE AIR SHORT	1331 6941517
1021	122319 FLL 02	1900		INSIDE CONTAINMENT MT VERNON SIDE AIR SHORT.	1331 6941518
1021	122319 FLL 03	1900		INSIDE CONTAINMENT MT. VERNON SIDE AIR SHORT.	1331 6941519
1021	122319 FLL 04	1900		INSIDE CONTAINMENT MT. VERNON SIDE AIR SHORT.	1331 6941520
1021	122319 FLL 05	1900		INSIDE CONTAINMENT MT VERNON SIDE AIR SHORT.	1331 6941521
1050	122319 FLL 06	1800		OUT SIDE MT. VERNON SIDE CLEAN ROOM.	1330 6941522
1050	122319 FLL 07	1800		OUT SIDE MT VERNON SIDE CENTER BY FAN UNIT.	1330 6941523
1051	122319 FLL 08	1800		OUT SIDE MT VERNON SIDE ENTRANCE.	1330 6941524
1052	122319 FLL 09	1800		OUT SIDE CENTER OF FANS ① OF PANTL.	1330 6941525
1052	122319 FLL 10	1800	✓	OUT SIDE CENTER OF FANS, ⑫ OF PANTL.	1330 6941526

SAMPLE PACKAGED AND SEALED BY:

Tim Daly

DATE: TIME:

12.23.19.

SENT TO:

ITC

RECEIVED

CONDITION UPON RECEIPT (DAMAGED / UNDAAGED):

DEC 23 2019

ATL - By [Signature]

ANALYZED TRM

12/24/19

Safya C SC 12/24/19

PRELIMINARY RESULTS
Airborne Asbestos Analysis
TEM AHERA

Client: OHCS Inc.
209 Catharine St.
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 606844
Project: FRANKLIN LEARNING CENTER
Project No.: MT.VERNAN FAN SHIFT
Philly Regs: Y
Turn-Around Time: 12 Hour Rush

Client Contacts:	Laboratory Contacts:
Contacts: _____	Contacts: Frank E. Ehrenfeld III
Phone: _____	Phone: (856) 231-9449
Fax: _____	Fax: (856) 231-9818
Cell/Pager: _____	Cell/Pager: (609) 929-4211
E-Mail: _____	E-Mail: frankehrenfeld@iatl.com

Chain of Custody:			
Samples Taken in Field:	_____	Date: _____	Time: _____
Samples Rec'd at Laboratory:	<u>L. D'Ornellas</u>	Date: <u>12/23/2019</u>	Time: _____
Samples Analyzed:	<u>S. Chinnamaneni</u>	Date: <u>12/24/2019</u>	Time: _____
Preliminary Results Faxed:	_____	Date: _____	Time: _____
Preliminary Results E-Mail:	_____	Date: _____	Time: _____

Summary Data
Transmission Electron Microscopy
AHERA 40CFR 763

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm ²	Results s/cc
122319FLC 01	6941517	1900	None Detected	< 19.2	< 0.0039
122319FLC 02	6941518	1900	Chrysotile	57.7	0.012
122319FLC 03	6941519	1900	None Detected	< 19.2	< 0.0039
122319FLC 04	6941520	1900	None Detected	< 19.2	< 0.0039
122319FLC 05	6941521	1900	None Detected	< 19.2	< 0.0039

AHERA Clearance Criteria is 70 s/mm². Average (s/mm²) = 26.9
 Phila. Regulations Clearance Criteria is 0.00554 s/cc Geo = 0.00488
 Z Test Results (see attached, if applicable)

Grid Box #: 1815
Instrument (I, II, III) II

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.

PRELIMINARY RESULTS
Airborne Asbestos Analysis
TEM AHERA

Client: OHCS Inc.
209 Catharine St.
Philadelphia, PA 19147

Client No.: OHC164

Batch No.: 606844
Project: Franklin Learning Center
Project No.: Mt. Vernan Fan Shaft
Philly Regs: Y
Turn-Around Time: 12 Hour Rush

Client Contacts:	Laboratory Contacts:
Contacts: _____	Contacts: Frank E. Ehrenfeld III
Phone: _____	Phone: (856) 231-9449
Fax: _____	Fax: (856) 231-9818
Cell/Pager: _____	Cell/Pager: (609) 929-4211
E-Mail: _____	E-Mail: frankehrenfeld@iatl.com

Chain of Custody:		
Samples Taken in Field: _____	Date: _____	Time: _____
Samples Rec'd at Laboratory: <u>S. Glanville</u>	Date: <u>12/23/2019</u>	Time: _____
Samples Analyzed: <u>C. Liska</u>	Date: <u>12/24/2019</u>	Time: _____
Preliminary Results Faxed: _____	Date: _____	Time: _____
Preliminary Results E-Mail: _____	Date: _____	Time: _____

Summary Data
Transmission Electron Microscopy
AHERA 40CFR 763

Client Sample ID #	IATL Sample ID #	Volume (L)	Comments	Results s/mm ²	Results s/cc
122319FLC06	6941522	1800	Chrysotile Actinolite	38.5	0.0082
122319FLC07	6941523	1800	None Detected	< 19.2	< 0.0041
122319FLC08	6941524	1800	None Detected	< 19.2	< 0.0041
122319FLC09	6941525	1800	None Detected	< 19.2	< 0.0041
122319FLC10	6941526	1800	None Detected	< 19.2	< 0.0041

AHERA Clearance Criteria is 70 s/mm². Average (s/mm²) = 23.1
Phila. Regulations Clearance Criteria is 0.00554 s/cc Geo = 0.00471
Z Test Results (see attached, if applicable)

Grid Box #: 1814
Instrument (I, II, III) I

These preliminary results are issued by IATL to expedite procedures by the clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificates of Analysis will follow these preliminary results. The signed COAs are to be considered the official results.
TEM.AHERA.001