



Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

January 14, 2020

Dear **Pennypacker Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **December 11, 2019 and December 12, 2019**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were **25** outlets tested at your school. Of those outlets, **18** outlets produced water that was below the action level of 10 ppb. **Seven (7)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

An action plan is being developed to determine the best way to address the outlet(s) that was shut-off (if applicable to your school), including replacing the outlet with a new hydration station or, if the outlet is not needed because another outlet is available nearby, the outlet may be permanently removed from the school. Once a decision is made, the Maintenance Department will perform the new installation or remove the existing outlet.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Brian Joseph
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

| Sample Date | Floor | Outlet Number | Outlet Type | Outlet Description | Lead Result (ppb) | MDL | PQL | Action Limits |
|-------------|-------|---------------|-------------|---------------------------------|-------------------|-----|-----|---------------|
| 12/11/2019 | 0 | 1 | WF | Outside Girls bathroom left | 34.0* | 0.3 | 1.0 | AA |
| 12/11/2019 | 0 | 2 | WF | Outside Girls Bathroom right | 8.8 | 0.3 | 1.0 | BA |
| 12/11/2019 | 0 | 3 | FT | In Cafeteria Office in Gym | 2.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 0 | 4 | WF | In Head Start Room 4 | 12.4* | 0.3 | 1.0 | AA |
| 12/11/2019 | 1 | 5 | FT | RM 101(Left) | 287.4* | 0.3 | 1.0 | AA |
| 12/11/2019 | 1 | 6 | FT | RM 101 (Right) | 6.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 7 | FT | In Nurse's Exam Room | 16.2* | 0.3 | 1.0 | AA |
| 12/11/2019 | 2 | 8 | FT | In Nurse's office | 8.5 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 9 | FT | In Nurse's Office Restroom | 1.4 | 0.3 | 1.0 | BA |
| 12/11/2019 | 3 | 10 | HS | Outside Room 307 | <1.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 3 | 11 | HS | Outside RM 304 | <1.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 12 | FT | In RM 201 (Life Skills) | <1.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 13 | HS | Outside RM 204 | <1.0 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 14 | WF | Outside IMC | 4.2 | 0.3 | 1.0 | BA |
| 12/11/2019 | 2 | 15 | FT | In IMC | 12.4 | 0.3 | 1.0 | AA |
| 12/11/2019 | 1 | 16 | WF | Outside RM 107 | 4.5 | 0.3 | 1.0 | BA |
| 12/11/2019 | 1 | 17 | FT | In RM 107 Closet (Kindergarten) | 3.7 | 0.3 | 1.0 | BA |
| 12/11/2019 | 1 | 18 | FT | In RM 110 (Special Needs) | <1.0 | 0.3 | 1.0 | BA |
| 12/12/2019 | 1 | 19 | HS | Outside RM 104 | <1.0 | 0.3 | 1.0 | BA |
| 12/12/2019 | 0 | 20 | FT | Inside Head Start RM 4 | 1.5 | 0.3 | 1.0 | BA |
| 12/12/2019 | 0 | 21 | WF | In Head Start RM 3 | 29.1 | 0.3 | 1.0 | AA |
| 12/12/2019 | 0 | 22 | FT | In Head Start RM 3 | 1.6 | 0.3 | 1.0 | BA |
| 12/12/2019 | 0 | 23 | FT | In Head Start Kitchen | 6.9 | 0.3 | 1.0 | BA |
| 12/12/2019 | 0 | 24 | FT | Back Wall RM 8/9 | 15.2 | 0.3 | 1.0 | AA |
| 12/12/2019 | 0 | 25 | HS | Outside RM 10 | <1.0 | 0.3 | 1.0 | BA |

Notes:

AA = Above Action limit of 10 ppb

BA = Below Action limit of 10 ppb

MDL = Method Detection Limit

PQL = Practical Quantitation Limit

J = Result estimated below the PQL

< = not detected above PQL

ppb = parts per billion

*Denotes an outlet location that has not been in use (the outlet was temporarily turned on for testing).

Outlet Types:

WF=Water Fountain/Bubbler

HS=Hydration Station/Bottle Filling Station

FT=Faucet/Tap

FP - Food Prep/Pot-Filler/Kitchen Kettle

IM - Ice-Maker