

THE SCHOOL DISTRICT OF PHILADLPHIA  
SCHOOL REFORM COMMISSION  
Office of Capital Programs  
440 North Broad Street, 3<sup>rd</sup> Floor – Suite 371  
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

**Addendum No. 5**

**Subject:** Thomas G. Morton: HVAC Renovation Project  
SDP Contract No. B-096 (C) of 2017/18  
SDP Contract No. B-097 (C) of 2017/18  
SDP Contract No. B-098 (C) of 2017/18

**Location:** Thomas G. Morton Elementary School  
2501 South 63<sup>rd</sup> Street,  
Philadelphia, PA 19142

---

**This Addendum, dated 7 of October, 2020, shall modify and become part of the Contract Documents for the work of this project. Any items not mentioned herein, or affected by, shall be performed strictly in accordance with the original documents.**

---

The following clarification is regarding, Addendum 4, Item 2 (c).

Response: The BAS Contractor shall be responsible to furnish and install ALL rigid and EMT conduit for the control wiring for all equipment documented on the 100% Bid Submission Set. This coincides with the RFI documented in Addendum No.1, RFI #4.

**End of Addendum**