



THE SCHOOL DISTRICT OF  
PHILADELPHIA

BOARD OF EDUCATION  
Office of Capital Programs  
440 North Broad Street, 3<sup>rd</sup> Floor – Suite 371  
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

**Addendum No. 1**

**Subject: Bid 2022-004-G for General Contractor Services on Site Improvement Project**

**Location: G.W. Childs Elementary School**

---

**This Addendum, dated October 28, 2021, shall modify and become part of the Contract Documents. Any items not mentioned herein, or affected by, shall remain strictly in accordance with the original document.**

---

**Questions from Bidders:**

1. Due to the limited scope of work on this project, can the MBE/WBE requirements be reduced/combined?

***Response: The combined total for M/WBE participation goal of this project has been lowered to 15%.***

2. What panel are we pulling from for the stair lift?

***Response: There is a panel at the corner of the wall, approximately 35 feet away from the steps, with space for a 20 amp dedicated connection.***

**End of Addendum #1**