

THE SCHOOL DISTRICT OF PHILADELPHIA
Office of Capital Programs
440 North Broad Street, 3rd Floor – Suite 371
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

ADDENDUM No. 02

Subject: Vare-Washington Major HVAC Upgrade
SDP Contract No. B-085c, 086c, 087c, 088c of 2019/20

Location: Vare-Washington Elementary School
1114-50 S. 5th St.
Philadelphia PA 19147

This ADDENDUM dated 09 December 2021 shall modify and become part of the Contract Documents for the work of this project. Any items not mentioned herein, or affected by, shall be performed strictly in accordance with the original documents.

Questions

- N/A
-

Drawings:

- N/A
-

Specifications

- 22 0523 – General-Duty Valves for plumbing Piping
 - 2.01.C.1.b: DELETE “Grooved or”
 - 2.01.C.1.c: DELETE “Grooved or”
 - 2.01.C.2.b: DELETE “Grooved or”
 - 2.01.C.2.c: DELETE “Grooved or”
- 22 1005 – Plumbing Piping
 - DELETE 2.06 C
- 23 0523 – General-Duty Valves for HVAC Piping
 - 2.01.C.1.b: REPLACE “Grooved ends” with “Flanged”
 - 2.01.C.2.b: REPLACE “Grooved ends” with “Flanged”
 - DELETE 2.01.D.2.e
 - DELETE 2.01.D.2.i
 - DELETE 2.02.F.5
 - DELETE 2.09
- 23 2113 – Hydronic Piping
 - DELETE 1.05.F

- DELETE 2.01.B.1.c
- 2.01.C: DELETE “or grooved couplings”
- 2.01.D.2: DELETE “or grooved mechanical couplings”
- DELETE 2.02.A.3
- DELETE 2.02.B.3
- DELETE 2.02.C.2
- DELETE 2.03.A.2
- DELETE 2.03.B.2
- DELETE 2.04.C
- DELETE 2.05 C
- DELETE 3.01.B
- DELETE 3.02.G
- 23 5216 – Condensing Boilers
 - 2.05.A: REPLACE “grooved” with “flanged”
 - 2.05.B: REPLACE “grooved” with “flanged”
 - 2.05.C: REPLACE “grooved” with “flanged”

End of Addendum