



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

**September 10, 2021**

Dear **Greenberg Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible, and appealing drinking water, your school's water was tested for lead on **August 27, 2021**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

There were **21** outlets tested at your school. Of those outlets, **15** outlets produced water that was below the action level of 10 ppb. **Six (6)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off. In the event that an outlet was inaccessible for testing during this initial sampling event, the outlet will remain off until the outlet can be sampled. These results will be included in the final letters.

An action plan is being developed to determine the best way to address the outlet(s) that was shut-off (if applicable to your school), including replacing the outlet with a new hydration station or, if the outlet is not needed because another outlet is available nearby, the outlet may be permanently removed from the school. Once a decision is made, the Maintenance Department will perform the new installation or remove the existing outlet.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: [www.philasd.org/waterresults](http://www.philasd.org/waterresults).

Sincerely,

**Steve Link**  
Environmental Director



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	PQL	Action Limits
08/27/2021	00	01	HS	In cafe left	<1	1	BA
08/27/2021	00	02	WF	In cafe right	2.2	1	BA
08/27/2021	00	03	FT	In kitchen	4.4	1	BA
08/27/2021	01	05	FT	In nurses office	4.1	1	BA
08/27/2021	01	06	FT	In teachers lounge	5.7	1	BA
08/27/2021	01	07	FT	In teachers lounge BR	2.7	1	BA
08/27/2021	01	08	HS	Outside principles office	<1	1	BA
08/27/2021	01	09	WF	Outside auditorium left	24	1	AA
08/27/2021	01	10	WF	Outside auditorium right	66	1	AA
08/27/2021	01	11	WF	In gym	2.3	1	BA
08/27/2021	01	12	WF	Outside RM 108	290	1	AA
08/27/2021	01	13	HS	In RM 108 k	<1	1	BA
08/27/2021	01	14	FT	In RM 108 k	8.9	1	BA
08/27/2021	01	15	FT	In RM 108 BR k	10	1	AA
08/27/2021	01	16	HS	In RM 106 k	<1	1	BA
08/27/2021	01	17	FT	In RM 106 k	14	1	AA
08/27/2021	01	18	FT	In RM 106 BR k	17	1	AA
08/27/2021	02	20	HS	Outside RM 211b	<1	1	BA
08/27/2021	02	21	WF	Outside RM 216	<1	1	BA
08/27/2021	03	23	HS	Outside RM 309	<1	1	BA
08/27/2021	03	24	WF	Outside RM 318	1.2	1	BA

**Notes:**

AA = Above Action limit of 10 ppb

BA = Below Action limit of 10 ppb

MDL = Method Detection Limit

PQL = Practical Quantitation Limit

J = Result estimated below the PQL

< = not detected above PQL

ppb = parts per billion

**Outlet Types:**

WF = Water Fountain/Bubbler

HS = Hydration Station/Bottle Filling Station

FT = Faucet/Tap

FP = Food Prep/Pot-Filler/Kitchen Kettle

IM = Ice-Maker