



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

August 10, 2021

Dear **deBurgos Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **May 19, 2021**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were **27** outlets tested at your school. Of those outlets, **27** outlets produced water that was below the action level of 10 ppb.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Steve Link
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
 440 North Broad Street
 Philadelphia, Pennsylvania 19130
 215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL	PQL	Action Limits
05/19/2021	1	1	FT	In RM 121 (1st Grade)	1.012	NA	1	BA
05/19/2021	1	2	FT	In RM 123 (Special Education)	<1	NA	1	BA
05/19/2021	1	3	FT	In RM 120 (1st Grade)	<1	NA	1	BA
05/19/2021	1	4	FT	In RM 125	1.603	NA	1	BA
05/19/2021	1	5	FT	In RM 116 (Gym Room)	1.447	NA	1	BA
05/19/2021	1	11	FT	In RM 102 Teachers Lounge	<1	NA	1	BA
05/19/2021	1	14	HS	Across RM 129	<1	NA	1	BA
05/19/2021	1	15	WF	Across RM 129 - Right	2.116	NA	1	BA
05/19/2021	1	16	WF	Across RM 129 Left side - Left	1.776	NA	1	BA
05/19/2021	1	17	WF	Across RM 129 Left side - Right	3.038	NA	1	BA
05/19/2021	1	18	FT	In RM 129 (Special Ed)	<1	NA	1	BA
05/19/2021	1	19	FT	In RM 130 (Special Education)	<1	NA	1	BA
05/19/2021	1	23	FT	In RM 148A Kitchen	2.088	NA	1	BA
05/19/2021	1	24	HS	Across RM 148	<1	NA	1	BA
05/19/2021	1	25	FT	In RM 132 Kindergarten	1.694	NA	1	BA
05/19/2021	1	26	FT	In RM 132 BR	1.031	NA	1	BA
05/19/2021	1	27	FT	In RM 133 Kindergarten	1.582	NA	1	BA
05/19/2021	1	28	FT	RM - 134 ESL Room (7th and 8th)	2.554	NA	1	BA
05/19/2021	1	29	FT	In Nurses Exam RM 151C	1.268	NA	1	BA
05/19/2021	1	30	FT	Nurses Exam RM 151C BR	1.038	NA	1	BA
05/19/2021	1	31	FT	In RM 135 Kindergarten	<1	NA	1	BA
05/19/2021	1	32	FT	In RM 135/136 BR Kindergarten	<1	NA	1	BA
05/19/2021	1	33	FT	In RM 136 Kindergarten	<1	NA	1	BA
05/19/2021	2	20	HS	Across RM 213	<1	NA	1	BA
05/19/2021	2	21	WF	Across RM 213	2.332	NA	1	BA
05/19/2021	3	6	HS	Across RM 312	<1	NA	1	BA
05/19/2021	3	7	WF	Across Rm 312 - Right	6.074	NA	1	BA

Notes:

Outlet Types:



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services

440 North Broad Street

Philadelphia, Pennsylvania 19130

215-400-4750

AA = Above Action limit of 10 ppb

BA = Below Action limit of 10 ppb

MDL = Method Detection Limit

PQL = Practical Quantitation Limit

J = Result estimated below the PQL

< = not detected above PQL

ppb = parts per billion

WF = Water Fountain/Bubbler

HS = Hydration Station/Bottle Filling Station

FT = Faucet/Tap

FP = Food Prep/Pot-Filler/Kitchen Kettle

IM = Ice-Maker

NA = Not Available