



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

July 30, 2021

Dear **Franklin Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, your school's water was tested for lead on **May 26, 2021**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

There were **24** outlets tested at your school. Of those outlets, **18** outlets produced water that was below the action level of 10 ppb. **Six (6)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

An action plan is being developed to determine the best way to address the outlet(s) that was shut-off (if applicable to your school), including replacing the outlet with a new hydration station or, if the outlet is not needed because another outlet is available nearby, the outlet may be permanently removed from the school. Once a decision is made, the Maintenance Department will perform the new installation or remove the existing outlet.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: [www.philasd.org/waterresults](http://www.philasd.org/waterresults).

Sincerely,

**Steve Link**  
Environmental Director



# THE SCHOOL DISTRICT OF PHILADELPHIA

## Operations Division

Office of Environmental Management and Services  
440 North Broad Street  
Philadelphia, Pennsylvania 19130  
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL	PQL	Action Limits
05/26/2021	0	2	WF	Outside BE office left right	9.205	NA	1	BA
05/26/2021	0	3	WF	Outside BE office right left	4.245	NA	1	BA
05/26/2021	0	4	WF	Outside BE office right right	3.943	NA	1	BA
05/26/2021	0	9	HS	Outside caf	<1	NA	1	BA
05/26/2021	0	10	FT	Kitchen back wall	5.815	NA	1	BA
05/26/2021	0	11	FT	Kitchen window wall left	12.48	NA	1	AA
05/26/2021	0	12	FT	Kitchen window wall right	27.02	NA	1	AA
05/26/2021	1	14	FT	Psychologists office in IMC	2.464	NA	1	BA
05/26/2021	1	15	FT	In rm 110 k	1.841	NA	1	BA
05/26/2021	1	16	HS	Outside rm 110 k left	<1	NA	1	BA
05/26/2021	1	17	WF	Outside rm 110 k right	1.343	NA	1	BA
05/26/2021	1	18	FT	Room 111 k	4.396	NA	1	BA
05/26/2021	1	19	FT	Rm 112 1st grade	24.6	NA	1	AA
05/26/2021	1	20	FT	Rm 113 1st grade	2.824	NA	1	BA
05/26/2021	1	21	FT	Rm 114 1st grade	5.682	NA	1	BA
05/26/2021	1	22	FT	Room 115 1st grade	21.19	NA	1	AA
05/26/2021	1	23	HS	Outside main office. 1st grade	<1	NA	1	BA
05/26/2021	1	24	FT	Rm 117 1st grade	9.401	NA	1	BA
05/26/2021	2	25	FT	Rm 210 faculty lounge	52.29	NA	1	AA
05/26/2021	2	26	HS	Outside rm 214	<1	NA	1	BA
05/26/2021	2	27	HS	Outside rm 207	<1	NA	1	BA
05/26/2021	2	28	FT	Nurses office sink	1.998	NA	1	BA
05/26/2021	2	29	FT	Nurses office br	3.376	NA	1	BA
05/26/2021	2	30	FT	Rm 212 laboratory / special Ed	16.64	NA	1	AA

**Notes:**

AA = Above Action limit of 10 ppb  
BA = Below Action limit of 10 ppb  
MDL = Method Detection Limit  
PQL = Practical Quantitation Limit  
J = Result estimated below the PQL  
< = not detected above PQL  
ppb = parts per billion

**Outlet Types:**

WF = Water Fountain/Bubbler  
HS = Hydration Station/Bottle Filling Station  
FT = Faucet/Tap  
FP = Food Prep/Pot-Filler/Kitchen Kettle  
IM = Ice-Maker  
NA = Not Available