



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

December 30, 2021

Dear **Franklin Elementary School** Community,

As a part of the School District of Philadelphia's effort to provide students and staff with safe, accessible and appealing drinking water, **24** water outlets at your school were initially tested for lead on **May 26, 2021**. Of those outlets, **18** outlets produced water that was below the action level of 10 ppb. **Six (6)** water outlets were found to have results above the water safety threshold and these outlets were immediately shut-off.

Below outlines the confirmed corrective action steps that were taken for those **Six (6)** water outlets that tested above the action limit.

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
05/26/2021	0	11	FT	Kitchen window wall left	12.48	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	0	11	FT	Kitchen window wall left	<1	NA	1	Remediation Complete
05/26/2021	0	12	FT	Kitchen window wall right	27.02	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	0	12	FT	Kitchen window wall right	<5.2	NA	5.2	Remediation Complete
05/26/2021	1	19	FT	Rm 112 1st grade	24.6	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	1	19	FT	Rm 112 1st grade	2	NA	1	Remediation Complete
05/26/2021	1	22	FT	Room 115 1st grade	21.19	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	1	22	FT	Room 115 1st grade	2.1	NA	1	Remediation Complete



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	MDL (ppb)	PQL (ppb)	Confirmed Corrective Action Description
05/26/2021	2	25	FT	Rm 210 faculty lounge	52.29	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	2	25	FT	Rm 210 faculty lounge	<1	NA	1	Remediation Complete
05/26/2021	2	30	FT	Rm 212 laboratory / special Ed	16.64	NA	1	Replaced fixture and any accessible lines, elbows back to the shutoff valve and retested
07/15/2021	2	30	FT	Rm 212 laboratory / special Ed	3	NA	1	Remediation Complete

Notes:

AA = Above Action limit of 10 ppb
BA = Below Action limit of 10 ppb
MDL = Method Detection Limit
PQL = Practical Quantitation Limit
J = Result estimated below the PQL
< = not detected above PQL
ppb = parts per billion
NA = Not Available

Outlet Types:

WF = Water Fountain/Bubbler
HS = Hydration Station/Bottle Filling Station
FT = Faucet/Tap
FP = Food Prep/Pot-Filler/Kitchen Kettle
IM = Ice-Maker

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at:

www.philasd.org/waterresults.

Sincerely,

Steve Link
Environmental Director